

ALICE, TX, USA

WMO: 722517

Lat: 27.741N

Lon: 98.025W

Elev: 173

StdP: 14.60

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12932

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.1	37.2	15.4	12.1	48.9	20.4	15.4	51.9	26.5	64.8	24.3	64.5	8.3	0	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.1	100.8	76.4	99.0	76.6	97.1	76.5	80.6	91.3	79.9	90.0	79.2	88.8	12.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.9	150.9	82.7	77.7	144.8	82.2	77.1	142.1	82.0	44.3	91.9	43.5	89.6	42.8	88.4	94.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.8	20.7	19.1	DB	28.6	105.0	3.5	3.1	26.1	107.2	24.0	109.0	22.1	110.7	19.5	113.0
			WB	25.7	83.7	3.0	3.0	23.6	85.9	21.8	87.7	20.2	89.4	18.0	91.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.4	58.0	61.8	67.4	74.0	80.1	84.4	85.7	86.2	81.9	75.0	66.2	59.3
	DBStd	12.24	9.57	9.90	8.53	6.68	4.96	3.00	2.96	2.82	4.10	6.91	8.59	9.49
	HDD50	86	36	18	4	0	0	0	0	0	0	0	4	24
	HDD65	837	256	162	76	11	0	0	0	0	0	12	88	232
	CDD50	8626	285	349	545	719	932	1031	1107	1123	958	776	490	311
	CDD65	3902	41	73	152	280	468	581	642	658	508	322	123	54
	CDH74	41098	304	557	1060	2339	4669	6783	7765	8007	5238	3042	978	356
	CDH80	19724	59	167	328	915	2075	3499	4200	4378	2513	1241	276	73
(14) Wind	WSAvg	9.6	9.5	10.0	10.7	11.1	11.1	10.2	9.9	8.9	7.6	8.4	8.7	8.7
(15) Precipitation	PrecAvg	27.1	1.2	1.5	1.2	1.5	3.0	3.3	1.9	2.8	5.0	3.1	1.7	1.3
	PrecMax	42.7	4.0	4.5	4.8	7.2	9.6	12.6	6.2	13.9	18.8	10.9	8.3	6.5
	PrecMin	13.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.0
	PrecStd	7.2	0.9	1.2	1.1	1.6	2.2	2.8	1.7	2.8	4.2	3.1	1.6	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.6	90.1	92.4	97.3	98.8	101.9	103.4	103.6	101.2	95.0	89.9	86.2
		MCWB	66.7	67.2	68.8	72.0	75.5	76.7	76.4	76.2	74.7	75.1	72.5	69.6
	2%	DB	81.3	84.9	87.2	91.8	95.0	98.5	100.1	100.9	97.2	92.1	86.4	81.6
		MCWB	65.7	67.5	69.1	71.5	76.2	77.1	76.5	76.7	75.7	75.1	71.2	68.0
	5%	DB	77.3	81.1	83.5	88.4	92.4	96.2	98.3	99.0	94.6	89.9	83.1	78.2
		MCWB	64.1	66.4	68.9	71.8	76.0	76.9	76.8	76.8	75.7	74.2	70.1	66.8
	10%	DB	73.0	76.8	80.5	85.4	90.2	93.9	96.1	96.8	91.7	87.4	80.1	73.9
		MCWB	63.1	65.1	67.5	70.4	75.3	76.8	76.8	76.9	75.7	73.1	68.6	66.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.3	72.2	74.1	78.0	81.4	82.2	81.2	81.1	80.7	79.7	76.1	73.2
		MCDB	78.3	82.2	84.1	89.2	91.3	92.9	93.8	93.5	89.9	87.3	82.8	78.8
	2%	WB	69.7	70.8	72.5	76.1	79.3	80.6	80.1	80.1	79.5	78.3	74.5	71.5
		MCDB	75.3	79.1	81.1	85.9	89.8	90.6	91.6	91.3	87.6	85.7	80.8	77.5
	5%	WB	68.1	69.5	71.3	74.8	78.2	79.7	79.3	79.2	78.8	77.4	73.1	70.1
		MCDB	73.6	75.9	78.5	83.3	87.6	88.7	89.9	89.7	86.8	84.7	79.0	75.4
	10%	WB	66.1	68.3	70.3	73.6	77.2	78.7	78.5	78.5	78.1	76.2	71.5	68.2
		MCDB	71.7	73.8	76.6	80.7	85.8	87.5	88.4	88.5	86.1	83.1	77.8	72.8
(35) Mean Daily Temperature Range	5% DB	MDBR	22.0	22.1	21.1	21.8	19.8	20.5	21.5	22.1	20.1	21.7	21.5	20.9
		MCDBR	26.1	26.5	23.7	23.9	22.0	23.2	24.5	25.1	23.5	22.7	23.6	24.4
		MCWBR	13.9	12.3	10.1	9.4	7.2	6.2	5.6	5.5	6.7	8.4	10.8	13.3
	5% WB	MCDBR	20.0	20.8	19.3	19.6	18.6	19.0	20.9	21.6	18.7	18.8	19.2	20.5
		MCWBR	12.0	10.9	9.3	8.2	7.0	6.2	5.9	5.5	6.3	8.4	10.1	13.1
(40) Clear-Sky Solar Irradiance	taub		0.351	0.359	0.379	0.423	0.458	0.438	0.443	0.439	0.429	0.383	0.369	0.343
	taud		2.458	2.439	2.387	2.280	2.217	2.332	2.333	2.345	2.336	2.452	2.437	2.496
	Ebn at Noon		283	290	289	278	267	271	269	270	270	278	274	280
	Edh at Noon		31	34	37	43	46	41	41	40	39	33	31	28
(44) All-Sky Solar Radiation	RadAvg		971	1154	1450	1721	1890	2111	2094	2013	1657	1434	1082	871
	RadStd		108	199	170	170	163	102	171	109	149	163	117	126

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (29 neighbors)		N/A	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	+214	+189	

Nomenclature: See separate page