

HONDO, TX, USA

WMO: 722533

Lat: 29.360N

Lon: 99.174W

Elev: 280

StdP: 98.00

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12962

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.4	-0.7	-11.8	1.4	4.4	-9.5	1.7	6.5	12.2	12.9	10.9	14.3	2.9	0	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	38.1	22.9	37.2	23.0	36.1	23.0	25.7	31.9	25.3	31.3	25.0	30.8	4.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	19.7	27.2	23.9	19.4	27.1	23.5	18.9	26.8	80.6	32.2	78.7	31.4	77.1	30.6	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.8	7.9	-6.6	39.7	2.1	1.8	-8.1	41.0	-9.3	42.1	-10.4	43.1	-11.9	44.4		
(5)			-7.8	26.6	2.0	0.5	-9.3	26.9	-10.4	27.2	-11.6	27.5	-13.1	27.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	11.1	13.6	17.2	21.1	25.0	28.1	29.0	29.4	26.6	21.8	16.0	11.6	(6)
(7)		DBStd	7.61	4.80	5.37	4.66	3.95	3.20	2.00	1.83	1.76	2.78	4.31	4.88	4.76	(7)
(8)		HDD10.0	118	44	23	5	0	0	0	0	0	0	1	9	37	(8)
(9)		HDD18.3	807	228	147	77	19	2	0	0	0	1	19	99	216	(9)
(10)		CDD10.0	4105	78	125	229	332	465	543	589	603	498	366	190	87	(10)
(11)		CDD18.3	1751	4	16	43	101	209	293	331	344	248	127	30	6	(11)
(12)		CDH23.3	19464	45	142	346	902	2024	3378	4062	4413	2702	1178	223	49	(12)
(13)		CDH26.7	9621	5	33	92	321	886	1737	2235	2518	1327	421	42	5	(13)
(14)	Wind	WSAvg	3.8	3.5	3.9	4.2	4.4	4.4	4.1	3.9	3.7	3.4	3.6	3.5	3.5	(14)
(15)	Precipitation	PrecAvg	713	34	39	55	56	88	75	71	56	81	68	46	32	(15)
(16)		PrecMax	1312	100	153	196	217	200	230	315	299	233	240	150	218	(16)
(17)		PrecMin	289	0	1	0	0	8	0	0	2	15	1	1	1	(17)
(18)		PrecStd	272	30	36	41	48	54	63	90	62	54	65	42	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	30.3	31.6	35.5	36.7	38.7	39.3	39.4	38.1	34.1	30.1	27.2	(19)
(20)			MCWB	15.8	16.5	18.8	20.4	22.7	23.4	22.4	22.9	22.1	22.1	20.5	17.9	(20)
(21)		2%	DB	24.5	27.2	29.2	32.3	34.8	37.0	37.9	38.0	36.1	32.3	27.8	24.6	(21)
(22)			MCWB	15.6	16.8	18.4	20.2	22.7	23.3	22.8	23.2	22.4	21.9	19.2	16.5	(22)
(23)		5%	DB	22.2	24.8	27.2	30.1	33.2	35.5	36.9	37.2	34.6	30.8	26.0	22.5	(23)
(24)			MCWB	14.8	16.2	18.2	20.0	22.7	23.2	23.0	23.3	22.3	21.4	18.4	16.3	(24)
(25)		10%	DB	20.0	22.4	25.0	28.3	31.5	34.1	35.5	36.2	33.0	29.2	24.1	20.5	(25)
(26)			MCWB	14.5	15.9	17.6	19.6	22.6	23.4	23.2	23.2	22.6	20.6	18.0	15.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.9	20.9	21.8	24.0	25.8	26.4	25.8	25.8	25.7	25.1	22.9	21.0	(27)
(28)			MCDWB	22.4	24.4	26.8	29.2	31.5	32.4	32.2	33.4	30.8	29.3	26.1	23.9	(28)
(29)		2%	WB	18.7	19.9	20.9	22.9	25.0	25.7	25.4	25.4	25.1	24.2	21.7	19.8	(29)
(30)			MCDWB	21.3	23.2	25.1	28.0	30.6	31.6	31.7	32.4	30.1	27.9	25.0	22.3	(30)
(31)		5%	WB	17.5	19.0	20.3	22.2	24.3	25.2	25.0	25.0	24.6	23.6	20.7	18.4	(31)
(32)			MCDWB	19.8	22.1	24.1	26.9	29.7	31.0	31.1	31.7	29.5	27.4	23.8	20.7	(32)
(33)		10%	WB	15.7	17.8	19.5	21.6	23.7	24.7	24.6	24.6	24.1	22.9	19.6	16.7	(33)
(34)			MCDWB	18.9	20.6	23.0	25.9	28.8	30.3	30.3	31.0	28.9	26.7	23.0	19.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.7	13.7	13.0	13.0	11.7	11.8	12.2	12.9	12.3	12.8	13.0	13.6	(35)
(36)			MCDBR	17.4	16.4	15.4	15.2	13.9	13.8	14.5	14.5	14.3	13.2	14.2	16.3	(36)
(37)			MCWBR	10.2	9.1	7.6	6.6	4.6	3.3	3.2	3.4	4.2	5.4	7.7	9.9	(37)
(38)		5% WB	MCDWB	11.6	11.6	11.4	10.9	10.8	10.8	11.5	12.1	10.5	9.7	10.8	11.7	(38)
(39)			MCWBR	8.2	7.5	6.5	5.3	4.3	3.5	3.2	3.1	3.5	4.5	7.0	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.326	0.334	0.355	0.391	0.427	0.418	0.423	0.412	0.404	0.371	0.351	0.321	(40)	
(41)		taud	2.498	2.475	2.435	2.349	2.299	2.378	2.394	2.411	2.382	2.463	2.454	2.518	(41)	
(42)		Ebn at Noon	913	935	933	904	867	870	864	873	871	882	875	901	(42)	
(43)		Edh at Noon	91	101	112	126	133	122	120	117	117	101	94	85	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.08	3.66	4.57	5.41	5.75	6.64	6.68	6.39	5.22	4.30	3.27	2.74	(44)	
(45)		RadStd	0.35	0.62	0.48	0.55	0.65	0.48	0.58	0.36	0.51	0.60	0.40	0.37	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.60	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	+245	+193
(47) Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+87

Nomenclature: See separate page