

KERRVILLE, TX, USA

WMO: 722537

Lat: 29.983N

Lon: 99.083W

Elev: 1617

StdP: 13.86

Time Zone: -6.00 (NAC)

Period: 02-19

WBAN: 12961

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.4	27.9	5.3	7.6	48.7	10.6	10.0	48.6	24.6	51.6	20.9	51.5	5.2	350	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.3	98.6	70.5	96.9	71.0	94.1	71.6	77.0	88.1	76.0	86.6	75.2	85.3	9.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.3	136.2	80.8	73.3	131.7	79.7	72.7	128.9	79.3	41.6	88.3	40.6	86.9	39.8	85.3	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.5	18.4	16.7	18.4	101.9	3.7	2.3	15.8	103.6	13.6	104.9	11.5	106.2	8.8	107.9		
			16.6	78.5	3.1	1.8	14.4	79.8	12.6	80.9	10.9	81.9	8.6	83.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	48.1	52.8	60.1	66.6	73.5	80.1	82.1	82.8	76.7	67.8	57.5	50.2
	DBStd	14.08	8.86	10.16	8.45	6.97	6.34	3.91	3.38	3.35	5.20	7.86	9.04	8.49
	HDD50	377	141	80	18	1	0	0	0	0	0	2	32	103
	HDD65	1930	526	354	194	63	11	0	0	0	1	63	254	464
	CDD50	6436	83	157	332	499	729	902	994	1015	801	555	259	110
	CDD65	2510	3	11	43	111	275	452	529	550	351	150	30	5
	CDH74	25241	37	132	341	966	2374	4648	5670	6245	3318	1271	196	43
	CDH80	11464	3	27	55	261	895	2197	2886	3309	1459	345	24	3
Wind	WSAvg	6.8	6.1	7.1	7.9	8.5	8.2	8.0	6.9	6.1	5.1	5.8	6.3	6.0
Precipitation	PrecAvg	33.2	1.8	1.9	3.0	2.5	3.8	3.6	3.5	2.4	3.7	3.6	2.4	1.9
	PrecMax	53.7	3.7	5.6	9.4	7.7	9.1	11.4	19.0	10.2	9.7	10.1	6.9	13.1
	PrecMin	16.2	0.0	0.0	0.6	0.1	0.8	0.0	0.1	0.1	0.6	0.3	0.0	0.2
	PrecStd	10.1	1.4	1.5	2.0	1.9	2.0	3.0	4.4	2.3	2.2	2.5	2.1	2.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	83.8	85.0	91.5	96.8	99.4	100.3	99.9	97.5	91.7	83.1	79.1
		MCWB	57.6	59.9	60.0	64.1	69.2	71.5	70.7	70.3	69.1	69.3	65.5	60.2
	2%	DB	72.8	78.6	81.3	86.1	91.5	96.8	97.4	98.5	93.9	86.5	79.2	73.8
		MCWB	57.1	58.2	61.2	64.6	70.4	71.1	71.1	70.7	70.4	68.9	64.4	59.4
	5%	DB	68.7	73.0	77.9	82.2	88.9	93.1	96.1	97.0	91.9	83.7	76.6	71.6
		MCWB	56.9	58.1	61.9	64.6	70.4	71.7	71.4	71.4	70.6	69.0	63.0	59.3
	10%	DB	64.0	69.3	73.8	79.4	84.5	91.1	92.6	94.0	88.7	81.5	72.4	65.8
		MCWB	55.6	58.6	60.8	64.0	69.5	71.9	72.4	71.9	70.6	66.9	62.4	57.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.5	68.1	69.9	73.7	77.4	78.4	78.0	77.7	76.5	75.4	72.1	68.9
		MCDB	70.9	74.6	75.3	80.7	86.8	90.3	89.9	89.5	86.9	83.4	77.3	73.9
	2%	WB	63.7	65.6	68.1	71.3	75.1	76.6	76.6	76.3	75.3	73.7	69.6	66.0
		MCDB	67.3	71.7	74.2	77.7	83.4	87.4	88.0	87.5	84.9	80.9	73.1	70.3
	5%	WB	60.8	63.3	66.6	69.9	73.7	75.4	75.6	75.4	74.3	72.4	67.6	62.9
		MCDB	65.2	67.9	73.0	76.5	82.3	85.5	86.4	86.0	83.3	79.1	72.7	66.5
	10%	WB	57.0	60.8	64.8	68.5	72.5	74.4	74.8	74.7	73.4	71.0	65.6	60.0
		MCDB	62.0	65.8	70.8	75.2	80.6	83.9	84.9	85.0	81.8	77.1	71.2	64.3
Mean Daily Temperature Range	5% DB	MDBR	24.0	24.2	23.4	23.3	20.8	20.8	20.5	22.3	21.6	23.3	23.6	24.7
		MCDBR	31.6	29.5	26.5	27.0	25.2	24.4	24.8	25.4	25.6	23.5	25.9	31.1
		MCWBR	17.8	16.3	13.7	12.7	9.3	6.6	6.5	6.3	7.9	10.1	14.6	18.9
	5% WB	MCDBR	21.6	20.7	18.7	18.6	18.5	19.0	19.9	21.1	18.8	17.6	18.3	21.7
		MCWBR	15.9	14.7	12.0	10.9	8.7	6.9	6.3	6.3	6.7	9.6	12.4	17.5
Clear-Sky Solar Irradiance	taub	0.311	0.319	0.340	0.380	0.413	0.410	0.420	0.407	0.394	0.360	0.338	0.310	
	taud	2.532	2.510	2.466	2.369	2.329	2.388	2.401	2.417	2.399	2.481	2.479	2.538	
	Ebn at Noon	294	301	300	290	279	278	275	278	279	283	281	289	
	Edh at Noon	28	31	34	39	41	38	38	37	36	31	29	26	
All-Sky Solar Radiation	RadAvg	992	1183	1480	1760	1854	2132	2128	2021	1655	1363	1044	885	
	RadStd	110	187	142	168	203	159	183	115	160	193	130	117	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page