

BURNET, TX, USA

WMO: 722542

Lat: 30.741N

Lon: 98.235W

Elev: 1288

StdP: 14.02

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 03999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.2	29.5	9.9	9.5	39.5	14.1	11.8	41.2	22.9	54.0	20.0	55.7	6.5	0	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.8	99.2	71.5	97.2	71.9	95.0	72.2	76.2	87.4	75.4	86.3	74.8	85.7	8.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.3	129.9	78.7	72.8	127.5	78.5	72.3	125.5	78.3	40.5	87.1	39.7	86.1	39.1	85.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.0	17.2	15.8	DB	20.1	103.0	3.9	3.5	17.3	105.5	15.0	107.5	12.8	109.5	10.0	112.1	
			WB	17.6	77.7	3.5	0.9	15.0	78.4	13.0	79.0	11.0	79.5	8.5	80.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	49.5	53.2	60.1	67.5	74.5	81.1	83.5	84.2	78.6	68.7	58.6	50.0
	DBStd	14.42	9.38	10.04	8.54	7.00	5.73	3.66	3.08	3.42	5.20	7.86	9.06	9.11
	HDD50	363	124	74	20	1	0	0	0	0	0	2	29	113
	HDD65	1840	485	343	196	55	6	0	0	0	1	55	227	472
	CDD50	6758	109	163	332	526	758	932	1038	1061	858	581	287	113
	CDD65	2758	4	12	43	130	299	482	573	596	409	170	34	6
	CDH74	29013	41	91	303	1008	2569	5201	6807	7405	4073	1301	187	27
	CDH80	13736	4	15	49	284	973	2486	3605	4042	1865	388	24	1
Wind	WSAvg	7.2	7.0	7.7	8.3	8.7	8.2	7.8	6.9	6.3	5.8	6.5	6.7	6.9
Precipitation	PrecAvg	33.1	2.0	2.1	2.8	2.8	3.1	3.6	2.2	2.0	3.3	3.3	2.8	2.2
	PrecMax	47.4	5.3	6.3	8.6	7.2	7.0	11.3	9.2	6.1	8.5	11.4	10.7	9.7
	PrecMin	21.4	0.0	0.1	0.6	0.3	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	8.0	1.6	1.7	1.7	1.8	1.9	2.7	2.2	1.7	2.1	2.8	2.8	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.2	81.9	84.4	91.0	94.9	99.7	100.4	102.1	100.0	90.3	83.0	77.6
		MCWB	57.8	59.5	62.8	65.9	71.1	72.1	71.0	71.8	70.0	69.0	66.5	62.5
	2%	DB	73.1	76.5	81.0	86.4	91.1	96.2	98.6	99.3	95.1	87.8	79.2	72.8
		MCWB	58.0	58.6	62.6	66.4	71.3	72.6	71.4	71.9	70.8	69.5	64.5	60.4
	5%	DB	69.6	72.5	77.5	82.7	88.6	93.2	96.6	97.4	92.2	84.3	75.3	69.7
		MCWB	57.8	59.8	62.3	66.1	70.9	72.3	72.1	72.1	70.9	67.6	63.1	60.1
	10%	DB	65.3	68.6	73.3	80.5	85.7	91.0	93.8	95.2	90.0	81.4	72.5	65.7
		MCWB	56.7	59.1	60.8	65.4	69.8	72.6	72.3	72.5	70.7	67.0	62.9	58.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.2	67.4	68.9	73.3	76.3	77.6	76.9	76.7	76.0	75.1	71.4	67.4
		MCDB	69.9	72.3	76.5	83.3	86.8	89.1	89.5	88.9	85.3	83.0	77.4	71.7
	2%	WB	63.9	65.5	67.2	71.1	74.9	76.2	75.6	75.5	75.0	73.4	68.7	65.6
		MCDB	67.8	70.3	73.6	79.6	84.4	87.2	87.2	87.3	84.1	79.9	73.6	69.7
	5%	WB	61.2	63.8	65.9	69.6	73.6	75.2	75.0	74.9	74.2	72.1	66.9	62.9
		MCDB	66.2	67.9	72.6	77.8	83.3	86.0	86.5	86.9	83.4	78.7	72.3	66.6
	10%	WB	57.5	61.4	64.3	68.3	72.4	74.4	74.3	74.3	73.4	70.8	65.0	59.4
		MCDB	63.1	66.9	70.5	75.9	81.5	84.9	85.6	86.3	82.6	77.3	70.4	64.7
Mean Daily Temperature Range	5% DB	MDBR	21.2	20.8	20.8	20.8	19.2	19.1	20.2	20.8	19.8	20.2	19.8	20.5
		MCDBR	27.3	25.1	24.5	23.5	22.3	21.9	23.5	23.7	23.0	21.7	22.3	24.7
		MCWBR	15.6	13.9	12.1	10.5	7.8	5.2	4.9	5.0	6.3	8.8	11.8	15.5
	5% WB	MCDBR	20.6	18.6	18.8	17.8	18.2	17.8	18.9	19.7	17.5	16.6	16.6	19.2
		MCWBR	15.6	13.9	11.3	9.6	7.8	5.9	5.1	5.0	5.5	8.5	11.6	15.5
Clear-Sky Solar Irradiance	taub		0.310	0.318	0.345	0.385	0.418	0.411	0.423	0.414	0.388	0.362	0.336	0.313
	taud		2.531	2.515	2.448	2.359	2.318	2.381	2.392	2.394	2.417	2.474	2.483	2.528
	Ebn at Noon		293	301	298	288	277	278	274	276	280	281	281	286
	Edh at Noon		27	30	35	39	41	39	38	38	36	31	29	26
All-Sky Solar Radiation	RadAvg		979	1156	1474	1768	1859	2134	2140	2009	1657	1348	1027	868
	RadStd		105	183	134	162	185	156	172	114	152	198	128	116

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144

Nomenclature: See separate page