

GEORGETOWN, TX, USA

WMO: 722547

Lat: 30.679N

Lon: 97.679W

Elev: 240

StdP: 98.48

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 53942

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.2	-2.1	-12.0	1.4	2.0	-9.1	1.8	4.0	11.2	14.3	10.3	14.8	2.7	0	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	37.3	22.9	36.2	23.1	35.1	23.3	25.2	31.9	24.9	31.4	24.5	30.8	3.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.6	19.0	27.2	23.0	18.3	26.7	22.8	18.0	26.7	78.0	32.0	76.4	31.3	74.9	30.8	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.4	7.6	-6.8	39.8	1.7	2.0	-8.1	41.3	-9.0	42.4	-10.0	43.5	-11.2	45.0		
(5)			-8.1	25.9	1.5	0.8	-9.2	26.5	-10.1	27.0	-10.9	27.4	-12.0	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	9.7	11.5	14.9	19.3	24.0	26.9	28.6	29.1	25.9	20.7	14.7	10.1	(6)
(7)		DBStd	8.14	5.38	5.66	5.17	4.23	3.29	2.18	1.84	1.81	3.24	4.67	5.11	5.16	(7)
(8)		HDD10.0	212	72	45	17	1	0	0	0	0	0	1	14	62	(8)
(9)		HDD18.3	1066	271	201	129	39	3	0	0	0	2	31	131	259	(9)
(10)		CDD10.0	3739	63	86	169	281	433	506	577	592	477	333	156	66	(10)
(11)		CDD18.3	1550	3	8	23	69	178	256	318	334	228	104	23	4	(11)
(12)		CDH23.3	16696	18	62	158	557	1619	2724	3848	4201	2422	922	146	20	(12)
(13)		CDH26.7	7922	3	16	23	149	632	1244	2039	2309	1167	317	21	1	(13)
(14)	Wind	WSAvg	3.4	3.6	3.6	3.8	4.0	3.8	3.4	3.4	3.0	2.7	3.0	3.3	3.3	(14)
(15)	Precipitation	PrecAvg	922	65	61	73	75	103	98	52	61	89	96	75	70	(15)
(16)		PrecMax	1341	175	201	175	233	199	244	199	170	268	250	244	300	(16)
(17)		PrecMin	493	0	2	0	11	9	13	1	2	12	0	0	7	(17)
(18)		PrecStd	223	46	47	39	50	52	60	46	51	65	77	66	65	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	28.0	28.9	33.0	35.6	36.2	38.6	38.1	38.9	33.0	28.9	26.0	(19)
(20)			MCWB	14.8	16.8	18.2	21.4	22.6	24.0	22.4	23.0	22.2	22.0	20.3	17.4	(20)
(21)		2%	DB	22.8	25.0	27.1	30.0	33.3	34.6	37.2	37.4	36.0	32.1	27.1	23.0	(21)
(22)			MCWB	15.7	16.5	18.0	19.5	22.2	23.7	22.8	23.1	22.5	21.6	18.9	16.2	(22)
(23)		5%	DB	21.2	22.6	25.2	27.9	32.1	33.3	36.0	36.3	33.9	30.2	25.0	21.3	(23)
(24)			MCWB	15.4	16.3	17.4	19.4	22.3	23.4	23.0	23.2	22.6	21.4	18.6	16.0	(24)
(25)		10%	DB	19.0	21.0	22.8	27.0	30.3	32.5	34.2	35.3	32.5	28.0	23.0	19.0	(25)
(26)			MCWB	14.7	16.2	16.5	18.8	22.1	23.3	23.0	23.7	22.4	20.3	18.1	15.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.4	20.2	20.9	23.1	25.2	26.0	25.5	25.6	25.2	24.5	22.5	20.0	(27)
(28)			MCDWB	21.5	23.4	25.7	28.7	30.6	32.4	33.0	33.3	30.8	29.1	25.9	22.6	(28)
(29)		2%	WB	18.0	19.4	20.0	22.0	24.2	25.2	25.0	25.1	24.6	23.8	21.4	18.9	(29)
(30)			MCDWB	20.8	22.2	24.1	26.9	29.6	31.6	32.0	32.5	30.1	28.1	24.6	21.6	(30)
(31)		5%	WB	17.0	18.4	19.2	21.2	23.6	24.7	24.5	24.6	24.1	23.0	20.2	17.5	(31)
(32)			MCDWB	19.8	21.0	22.9	25.8	28.8	30.7	31.2	31.8	29.6	27.2	23.6	20.4	(32)
(33)		10%	WB	15.3	17.0	18.2	20.3	22.9	24.1	24.1	24.2	23.7	22.3	19.1	15.6	(33)
(34)			MCDWB	18.8	20.2	21.7	24.7	28.0	29.7	30.6	31.2	29.1	26.5	22.4	18.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.1	11.6	11.7	12.2	10.7	10.3	11.1	11.8	11.8	11.8	11.8	12.0	(35)
(36)			MCDBR	14.6	14.0	13.4	13.3	12.1	11.3	12.9	13.1	13.1	12.4	13.0	14.0	(36)
(37)			MCWBR	9.2	8.4	7.3	6.3	4.2	3.4	3.0	3.0	3.8	5.1	7.3	9.0	(37)
(38)		5% WB	MCDWB	10.9	10.4	10.7	10.0	10.0	9.8	10.7	11.2	10.4	9.9	9.8	11.0	(38)
(39)			MCWBR	8.4	7.7	7.0	5.6	4.6	3.6	3.1	3.0	3.5	4.7	6.5	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.318	0.331	0.356	0.398	0.438	0.425	0.438	0.427	0.402	0.371	0.350	0.318	(40)	
(41)		taud	2.515	2.483	2.423	2.328	2.264	2.345	2.343	2.359	2.379	2.449	2.448	2.522	(41)	
(42)		Ebn at Noon	916	933	928	896	857	863	850	858	870	876	868	897	(42)	
(43)		Edh at Noon	87	99	112	128	137	126	126	123	116	101	93	83	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.02	3.50	4.53	5.44	5.78	6.62	6.69	6.29	5.20	4.24	3.19	2.66	(44)	
(45)		RadStd	0.32	0.61	0.41	0.49	0.52	0.48	0.53	0.34	0.46	0.61	0.38	0.35	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+73

Nomenclature: See separate page