

VICTORIA, TX, USA

WMO: 722550

Lat: 28.861N

Lon: 96.930W

Elev: 115

StdP: 14.63

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12912

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.3	34.4	18.4	14.0	43.3	22.9	17.3	46.2	27.6	63.1	25.2	61.2	8.5	0	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.0	98.1	76.6	96.1	76.7	94.3	76.7	80.4	88.1	79.8	87.7	79.2	87.1	11.5	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	149.9	82.3	78.1	146.4	82.0	77.4	142.9	81.7	43.9	88.5	43.2	87.6	42.7	87.1	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.4	21.0	19.2	DB	25.5	102.0	3.4	3.6	23.1	104.5	21.0	106.6	19.1	108.6	16.6	111.2	
			WB	23.5	81.8	3.1	0.8	21.2	82.4	19.4	82.8	17.6	83.3	15.3	83.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.8	54.8	58.6	64.1	70.4	77.4	82.5	84.2	84.8	80.4	72.5	63.3	56.2
	DBStd	12.70	9.41	9.63	8.18	6.41	4.74	2.92	2.51	2.82	4.47	7.07	8.57	9.46
	HDD50	147	58	31	7	0	0	0	0	0	0	0	8	43
	HDD65	1156	335	220	117	25	1	0	0	0	0	23	132	303
	CDD50	7754	208	271	445	614	850	976	1061	1078	912	697	406	236
	CDD65	3286	20	40	90	188	387	526	596	613	462	254	80	30
	CDH74	32762	84	176	443	1298	3489	5757	6884	7165	4530	2219	575	142
	CDH80	14411	4	21	60	301	1286	2704	3435	3683	2033	775	101	8
Wind	WSAvg	9.2	9.6	10.1	10.6	11.1	10.7	9.2	8.2	7.6	7.1	8.1	8.6	9.0
Precipitation	PrecAvg	39.3	2.4	2.0	2.3	2.7	5.0	4.5	3.5	3.1	5.1	3.8	2.7	2.2
	PrecMax	73.7	7.8	9.1	11.6	11.7	14.6	13.5	20.4	17.6	19.1	12.4	16.1	7.0
	PrecMin	12.8	0.0	0.2	0.2	0.0	0.0	0.0	0.0	0.3	1.0	0.0	0.0	0.4
	PrecStd	11.9	1.7	1.7	2.2	2.8	4.0	3.5	3.7	2.8	3.6	3.0	2.7	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.9	83.1	85.1	89.3	93.7	98.4	99.3	101.1	99.3	92.2	85.8	81.2
		MCWB	65.6	67.5	67.9	69.8	75.1	76.0	76.7	76.4	74.8	75.0	72.2	69.7
	2%	DB	76.3	79.0	81.4	85.9	90.9	95.3	97.1	98.5	95.0	89.4	82.9	78.0
		MCWB	65.3	67.3	68.5	71.3	74.9	76.6	76.8	77.0	75.8	74.9	71.0	68.3
	5%	DB	73.3	75.7	78.9	83.4	88.9	93.4	95.3	96.6	92.4	87.3	80.4	74.9
		MCWB	65.3	66.2	68.1	70.9	74.7	76.6	76.9	77.1	75.8	73.6	69.8	67.3
	10%	DB	70.4	72.7	76.1	81.1	86.9	91.4	93.4	94.4	90.2	84.7	77.3	72.1
		MCWB	64.1	65.9	66.7	69.9	74.6	76.9	77.1	77.2	75.9	72.5	68.9	67.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.9	71.8	73.3	76.7	79.7	81.1	80.7	81.0	81.1	80.1	76.2	73.7
		MCDB	74.1	77.6	79.3	83.5	87.2	89.0	88.7	89.6	87.4	85.0	81.1	76.7
	2%	WB	69.4	70.3	71.8	75.2	78.3	80.1	80.0	80.2	80.0	78.3	74.5	71.5
		MCDB	72.9	75.0	76.9	80.9	85.3	87.7	88.2	88.9	86.6	83.9	79.2	75.0
	5%	WB	68.0	69.2	70.8	74.0	77.4	79.4	79.3	79.5	79.0	77.2	72.9	70.2
		MCDB	71.5	73.2	75.4	79.4	84.1	86.8	87.7	88.3	85.9	83.2	77.4	73.4
	10%	WB	65.9	67.9	69.7	73.0	76.5	78.6	78.6	78.9	78.2	75.8	71.0	67.9
		MCDB	69.5	71.5	73.8	78.0	83.0	86.0	87.0	87.6	85.1	81.5	75.4	71.3
Mean Daily Temperature Range	5% DB	MDBR	20.9	20.0	19.6	19.4	18.0	18.0	18.9	20.0	19.2	21.3	21.4	20.8
		MCDBR	23.1	21.5	19.7	20.3	19.8	20.9	21.7	23.0	22.0	22.0	22.7	22.3
		MCWBR	14.5	12.1	9.6	9.4	6.9	5.6	5.3	5.4	6.7	9.5	12.2	14.3
	5% WB	MCDBR	18.2	17.2	15.8	15.7	15.5	16.4	18.3	19.4	17.1	17.4	18.8	18.8
		MCWBR	13.5	11.7	9.2	8.3	6.5	5.6	5.4	5.5	6.5	9.0	12.2	14.4
Clear-Sky Solar Irradiance	taub	0.350	0.361	0.382	0.433	0.475	0.452	0.476	0.450	0.438	0.387	0.375	0.336	
	taud	2.461	2.439	2.378	2.246	2.166	2.289	2.236	2.316	2.310	2.437	2.415	2.519	
	Ebn at Noon	281	288	287	275	262	267	260	267	266	275	270	281	
	Edh at Noon	30	33	38	44	48	43	45	41	40	33	31	27	
All-Sky Solar Radiation	RadAvg	930	1076	1416	1685	1889	2080	2057	1959	1636	1407	1057	839	
	RadStd	101	184	131	151	135	125	186	111	151	156	116	105	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+176	+171
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+194	+166

Nomenclature: See separate page