

VICTORIA, TX, USA

WMO: 722550

Lat: 28.861N

Lon: 96.930W

Elev: 35

StdP: 100.90

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12912

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.4	1.3	-7.6	2.0	6.3	-5.0	2.5	7.9	12.4	17.3	11.2	16.2	3.8	0	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	36.7	24.8	35.6	24.8	34.6	24.8	26.9	31.2	26.6	30.9	26.2	30.6	5.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	27.9	25.6	20.9	27.8	25.2	20.4	27.6	84.3	31.4	82.7	30.9	81.4	30.6	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.9	9.4	8.6	-3.6	38.9	1.9	2.0	-5.0	40.3	-6.1	41.5	-7.2	42.6	-8.6	44.0
			-4.7	27.7	1.7	0.4	-6.0	28.0	-7.0	28.2	-8.0	28.5	-9.3	28.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.6	12.7	14.8	17.8	21.4	25.2	28.1	29.0	29.3	26.9	22.5	17.4	13.4
	DBStd	7.06	5.23	5.35	4.54	3.56	2.63	1.62	1.39	1.57	2.49	3.93	4.76	5.26
	HDD10.0	82	32	17	4	0	0	0	0	0	0	0	4	24
	HDD18.3	642	186	122	65	14	1	0	0	0	0	13	73	168
	CDD10.0	4308	116	151	247	341	472	542	589	599	507	387	226	131
	CDD18.3	1826	11	22	50	104	215	292	331	341	257	141	44	17
	CDH23.3	18201	47	98	246	721	1938	3198	3824	3981	2517	1233	319	79
	CDH26.7	8006	2	12	33	167	714	1502	1908	2046	1129	431	56	4
Wind	WSAvg	4.1	4.3	4.5	4.8	5.0	4.8	4.1	3.7	3.4	3.2	3.6	3.8	4.0
Precipitation	PrecAvg	997	60	50	59	69	126	114	88	80	129	97	69	56
	PrecMax	1873	197	231	295	297	372	343	517	446	484	316	410	177
	PrecMin	324	0	5	5	0	0	0	1	7	26	0	0	9
	PrecStd	302	42	43	55	71	102	90	94	70	91	75	68	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.6	28.4	29.5	31.9	34.3	36.9	37.4	38.4	37.4	33.5	29.9	27.3
		MCWB	18.6	19.7	20.0	21.0	23.9	24.5	24.8	24.7	23.8	23.9	22.3	21.0
	2%	DB	24.6	26.1	27.5	29.9	32.7	35.2	36.2	36.9	35.0	31.9	28.3	25.5
		MCWB	18.5	19.6	20.3	21.8	23.8	24.8	24.9	25.0	24.3	23.8	21.7	20.2
	5%	DB	22.9	24.3	26.1	28.6	31.6	34.1	35.2	35.9	33.6	30.7	26.9	23.8
		MCWB	18.5	19.0	20.0	21.6	23.7	24.8	24.9	25.0	24.3	23.1	21.0	19.6
	10%	DB	21.3	22.6	24.5	27.3	30.5	33.0	34.1	34.7	32.3	29.3	25.2	22.3
		MCWB	17.9	18.8	19.3	21.1	23.6	25.0	25.1	25.1	24.4	22.5	20.5	19.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.6	22.1	22.9	24.8	26.5	27.3	27.1	27.2	27.3	26.7	24.6	23.2
		MCDB	23.4	25.3	26.3	28.6	30.7	31.6	31.5	32.0	30.8	29.5	27.3	24.8
	2%	WB	20.8	21.3	22.1	24.0	25.7	26.7	26.7	26.8	26.6	25.7	23.6	21.9
		MCDB	22.7	23.9	24.9	27.2	29.6	31.0	31.2	31.6	30.3	28.8	26.2	23.9
	5%	WB	20.0	20.7	21.6	23.3	25.2	26.3	26.3	26.4	26.1	25.1	22.7	21.2
		MCDB	21.9	22.9	24.1	26.3	28.9	30.4	30.9	31.3	29.9	28.5	25.2	23.0
	10%	WB	18.8	20.0	21.0	22.8	24.7	25.9	25.9	26.0	25.6	24.4	21.7	19.9
		MCDB	20.8	22.0	23.2	25.5	28.3	30.0	30.5	30.9	29.5	27.5	24.1	21.8
Mean Daily Temperature Range	5% DB	MDBR	11.6	11.1	10.9	10.8	10.0	10.0	10.5	11.1	10.7	11.9	11.9	11.6
		MCDBR	12.9	12.0	10.9	11.3	11.0	11.6	12.0	12.8	12.2	12.2	12.6	12.4
		MCWBR	8.1	6.7	5.3	5.2	3.8	3.1	2.9	3.0	3.7	5.3	6.8	7.9
	5% WB	MCDBR	10.1	9.6	8.8	8.7	8.6	9.1	10.1	10.8	9.5	9.7	10.4	10.5
	MCWBR	7.5	6.5	5.1	4.6	3.6	3.1	3.0	3.0	3.6	5.0	6.8	8.0	
Clear-Sky Solar Irradiance	taub	0.350	0.361	0.382	0.433	0.475	0.452	0.476	0.450	0.438	0.387	0.375	0.336	
	taud	2.461	2.439	2.378	2.246	2.166	2.289	2.236	2.316	2.310	2.437	2.415	2.519	
	Ebn at Noon	886	907	906	866	827	841	819	841	840	867	850	887	
	Edh at Noon	95	105	119	140	152	134	141	129	126	104	99	86	
All-Sky Solar Radiation	RadAvg	2.93	3.39	4.46	5.31	5.96	6.56	6.49	6.17	5.16	4.44	3.33	2.64	
	RadStd	0.32	0.58	0.41	0.48	0.43	0.39	0.58	0.35	0.48	0.49	0.37	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+98	+95
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+108	+92

Nomenclature: See separate page