

BEEVILLE CHASE FIELD, TX, USAWMO: **722556**Lat: **28.367N**Lon: **97.667W**Elev: **66**StdP: **14.66**Time Zone: **-6.00 (NAC)**Period: **82-92**WBAN: **12925****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.9	33.6	11.7	10.0	41.6	17.0	13.0	40.0	27.2	61.5	24.4	56.8	12.2	350	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.5	100.2	77.2	98.2	77.5	96.4	77.4	82.1	91.1	80.9	90.6	80.0	90.1	9.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.0	155.9	85.5	78.6	149.1	84.5	77.5	143.5	83.7	45.7	90.9	44.4	90.7	43.5	90.4	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	19.5	17.8	22.9	104.5	7.0	2.6	17.9	106.3	13.9	107.8	10.0	109.3	4.9	111.2
			19.4	85.8	6.8	2.0	14.5	87.3	10.5	88.4	6.7	89.6	1.7	91.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.2	55.0	59.0	65.9	72.4	78.7	83.7	85.4	86.4	82.1	74.7	65.6	56.7
	DBStd	13.14	9.26	9.65	7.69	7.07	4.88	3.45	2.59	2.39	4.89	6.47	9.19	11.72
	HDD50	162	54	31	3	0	0	0	0	0	0	0	5	69
	HDD65	1068	331	205	85	24	0	0	0	0	1	9	108	305
	CDD50	8264	208	284	495	673	888	1010	1098	1128	964	767	473	276
	CDD65	3695	19	38	112	247	424	560	633	663	515	311	126	47
	CDH74	37935	100	273	718	1967	3856	6337	7535	8093	5423	2664	751	218
	CDH80	17955	12	76	182	704	1560	3201	3974	4405	2627	1019	170	25
(14) Wind	WSAvg	8.1	7.8	8.8	9.7	8.8	8.5	7.6	7.6	7.1	7.5	7.3	8.0	8.4
(15) Precipitation	PrecAvg	31.0	1.6	1.8	1.1	2.0	3.7	3.5	3.5	2.8	5.0	2.8	1.7	1.6
	PrecMax	43.0	3.3	4.8	3.4	8.3	11.0	13.4	18.5	8.5	20.9	9.2	5.0	7.4
	PrecMin	10.7	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.3	0.5	0.1	0.0	0.1
	PrecStd	9.3	0.9	1.4	1.0	2.0	2.9	3.3	4.0	2.2	4.8	2.6	1.2	1.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.2	88.5	90.1	94.4	97.3	101.0	102.0	102.6	100.3	95.9	88.2	83.2
		MCWB	66.8	64.5	66.8	72.1	77.8	77.4	76.8	77.8	77.4	74.6	72.9	70.2
	2%	DB	76.6	80.6	84.4	90.2	94.0	97.9	99.3	100.5	96.8	91.8	84.5	79.3
		MCWB	64.7	64.4	67.6	70.9	77.0	78.0	76.9	77.9	77.3	74.8	72.7	68.3
	5%	DB	73.2	76.6	81.0	87.1	90.8	95.5	97.1	98.3	94.7	88.8	81.5	76.2
		MCWB	63.4	63.6	66.9	70.9	76.1	77.4	77.2	78.1	77.1	73.9	70.8	66.7
	10%	DB	69.9	73.0	77.8	84.2	88.1	93.3	95.1	96.3	92.4	85.9	78.4	72.9
		MCWB	62.5	63.0	65.6	70.3	75.0	77.4	77.1	77.9	76.5	72.4	69.6	66.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	71.6	74.6	78.5	80.5	82.5	83.4	84.0	83.3	80.7	76.3	73.1
		MCDB	77.3	78.8	80.8	87.8	91.4	91.0	89.6	93.7	91.2	86.6	83.9	78.1
	2%	WB	68.8	69.4	72.6	76.4	79.1	80.9	81.2	82.0	81.0	78.5	74.3	70.8
		MCDB	73.7	75.2	78.6	85.1	89.8	90.9	90.3	92.1	90.0	85.4	80.4	75.7
	5%	WB	66.4	67.7	71.1	74.8	77.9	79.9	80.1	80.7	79.7	77.2	73.0	69.4
		MCDB	71.3	72.9	76.2	82.2	87.6	90.5	90.0	91.1	89.1	84.0	78.2	73.7
	10%	WB	63.4	65.3	69.7	73.2	76.8	78.8	79.1	79.8	78.4	75.5	71.4	67.9
		MCDB	68.6	71.0	74.6	80.0	85.2	89.2	89.4	90.5	87.9	81.8	76.6	72.9
(35) Mean Daily Temperature Range	5% DB	MDBR	19.5	20.0	21.1	20.8	18.2	19.5	20.4	21.5	20.4	20.8	19.4	19.2
		MCDBR	24.1	24.7	23.5	25.0	20.7	22.4	23.6	24.2	22.5	22.7	19.6	21.6
		MCWBR	16.0	13.9	12.7	12.9	8.8	8.1	7.7	7.8	9.0	10.2	11.4	14.2
	5% WB	MCDBR	18.2	20.2	16.9	18.5	18.2	19.5	20.1	21.5	19.7	18.3	17.5	17.9
		MCWBR	14.2	14.1	10.6	11.2	8.8	8.8	8.5	8.4	9.4	9.3	11.4	14.3
(40) Clear-Sky Solar Irradiance	taub		0.351	0.359	0.383	0.430	0.473	0.446	0.457	0.441	0.436	0.389	0.370	0.337
	taud		2.456	2.441	2.373	2.260	2.175	2.310	2.302	2.341	2.318	2.436	2.433	2.513
	Ebn at Noon		282	289	287	276	263	268	265	269	268	275	272	282
	Edh at Noon		30	33	38	44	48	42	42	40	40	33	31	28
(44) All-Sky Solar Radiation	RadAvg		941	1101	1405	1663	1862	2092	2061	1978	1639	1413	1061	849
	RadStd		106	191	147	160	155	114	189	112	152	161	114	115

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207	+175

Nomenclature: See separate page