

BEEVILLE CHASE FIELD, TX, USAWMO: **722556**Lat: **28.367N**Lon: **97.667W**Elev: **20**StdP: **101.08**Time Zone: **-6.00 (NAC)**Period: **82-92**WBAN: **12925****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.3	0.9	-11.3	1.4	5.3	-8.3	1.9	4.4	12.2	16.4	10.9	13.8	5.4	350	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	37.9	25.1	36.8	25.3	35.8	25.2	27.8	32.8	27.1	32.5	26.7	32.3	4.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.6	22.3	29.7	25.9	21.3	29.2	25.3	20.5	28.7	88.3	32.7	85.4	32.6	83.2	32.4	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	8.7	7.9	DB	-5.0	40.3	3.9	1.4	-7.8	41.3	-10.1	42.1	-12.2	42.9	-15.1	44.0	
(5)			WB	-7.0	29.9	3.8	1.1	-9.7	30.7	-11.9	31.4	-14.1	32.0	-16.8	32.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.3	12.8	15.0	18.8	22.5	25.9	28.7	29.7	30.2	27.9	23.7	18.7	13.7
	DBStd	7.30	5.15	5.36	4.27	3.93	2.71	1.92	1.44	1.33	2.72	3.59	5.11	6.51
	HDD10.0	90	30	17	2	0	0	0	0	0	0	0	3	38
	HDD18.3	593	184	114	47	13	0	0	0	0	1	5	60	169
	CDD10.0	4591	116	158	275	374	493	561	610	627	536	426	263	153
	CDD18.3	2053	11	21	62	137	236	311	352	368	286	173	70	26
	CDH23.3	21075	56	152	399	1093	2142	3521	4186	4496	3013	1480	417	121
	CDH26.7	9975	7	42	101	391	867	1778	2208	2447	1459	566	94	14
Wind	WSAvg	3.6	3.5	3.9	4.3	4.0	3.8	3.4	3.4	3.2	3.4	3.3	3.6	3.8
Precipitation	PrecAvg	788	40	45	29	51	95	90	88	70	126	71	43	41
	PrecMax	1091	83	122	86	211	280	341	471	217	532	234	126	188
	PrecMin	271	0	1	0	1	1	4	0	8	12	2	1	3
	PrecStd	237	22	36	25	50	74	83	102	55	123	66	31	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.4	31.4	32.3	34.7	36.3	38.4	38.9	39.2	38.0	35.5	31.2	28.4
		MCWB	19.4	18.1	19.3	22.3	25.5	25.2	24.9	25.4	25.2	23.7	22.7	21.2
	2%	DB	24.8	27.0	29.1	32.4	34.4	36.6	37.4	38.0	36.0	33.2	29.2	26.3
		MCWB	18.2	18.0	19.8	21.6	25.0	25.6	24.9	25.5	25.2	23.8	22.6	20.2
	5%	DB	22.9	24.8	27.2	30.6	32.7	35.3	36.2	36.8	34.8	31.5	27.5	24.6
		MCWB	17.5	17.6	19.4	21.6	24.5	25.2	25.1	25.6	25.0	23.3	21.5	19.3
	10%	DB	21.0	22.8	25.4	29.0	31.2	34.0	35.1	35.7	33.5	30.0	25.8	22.7
		MCWB	16.9	17.2	18.7	21.3	23.9	25.2	25.1	25.5	24.7	22.4	20.9	19.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.0	23.6	25.9	26.9	28.0	28.6	28.9	28.5	27.0	24.6	22.8
		MCDB	25.2	26.0	27.1	31.0	33.0	32.8	32.0	34.3	32.9	30.3	28.8	25.6
	2%	WB	20.4	20.8	22.6	24.7	26.2	27.2	27.3	27.8	27.2	25.8	23.5	21.6
		MCDB	23.2	24.0	25.9	29.5	32.1	32.7	32.4	33.4	32.2	29.7	26.9	24.3
	5%	WB	19.1	19.8	21.7	23.8	25.5	26.6	26.7	27.0	26.5	25.1	22.8	20.8
		MCDB	21.8	22.7	24.6	27.9	30.9	32.5	32.2	32.8	31.7	28.9	25.7	23.2
	10%	WB	17.4	18.5	20.9	22.9	24.9	26.0	26.2	26.5	25.8	24.2	21.9	19.9
		MCDB	20.3	21.6	23.7	26.6	29.5	31.8	31.9	32.5	31.0	27.7	24.8	22.7
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.1	11.7	11.5	10.1	10.8	11.3	12.0	11.4	11.5	10.8	10.7
		MCDBR	13.4	13.7	13.0	13.9	11.5	12.4	13.1	13.4	12.5	12.6	10.9	12.0
		MCWBR	8.9	7.7	7.1	7.2	4.9	4.5	4.3	4.4	5.0	5.7	6.3	7.9
	5% WB	MCDBR	10.1	11.2	9.4	10.3	10.1	10.8	11.2	11.9	10.9	10.2	9.7	9.9
		MCWBR	7.9	7.8	5.9	6.2	4.9	4.9	4.7	4.7	5.2	5.2	6.3	7.9
Clear-Sky Solar Irradiance	taub	0.351	0.359	0.383	0.430	0.473	0.446	0.457	0.441	0.436	0.389	0.370	0.337	
	taud	2.456	2.441	2.373	2.260	2.175	2.310	2.302	2.341	2.318	2.436	2.433	2.513	
	Ebn at Noon	888	911	906	870	829	846	836	849	844	868	858	888	
	Edh at Noon	96	105	120	138	151	131	132	126	125	105	98	87	
All-Sky Solar Radiation	RadAvg	2.97	3.47	4.43	5.24	5.87	6.59	6.50	6.24	5.17	4.46	3.35	2.68	
	RadStd	0.33	0.60	0.46	0.50	0.49	0.36	0.60	0.35	0.48	0.51	0.36	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	+97

Nomenclature: See separate page