

DRAUGHON-MILLER CENTRAL TEXAS, TX, USA

WMO: 722577

Lat: 31.150N

Lon: 97.417W

Elev: 682

StdP: 14.34

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93984

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.0	27.9	10.4	9.6	31.8	15.7	12.5	37.2	28.0	58.0	25.7	58.4	8.2	0	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.5	100.1	74.2	98.9	74.3	96.9	74.5	78.4	90.1	77.6	89.7	77.0	89.0	10.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.5	136.8	81.4	74.7	133.5	81.2	73.4	127.6	80.9	42.3	90.9	41.4	89.6	40.7	89.2	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	22.5	20.0	18.1	104.1	4.0	4.8	15.2	107.6	12.9	110.4	10.6	113.1	7.7	116.6
			16.4	79.9	3.8	1.6	13.6	81.1	11.4	82.0	9.2	82.9	6.4	84.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	48.7	52.4	59.2	67.0	74.5	81.2	84.3	84.6	78.4	68.9	58.0	49.9	
	DBStd	14.95	9.84	10.44	9.38	7.34	6.06	4.00	3.24	3.57	5.93	7.89	9.28	9.57	
	HDD50	415	144	86	29	2	0	0	0	0	0	1	32	121	
	HDD65	1953	511	368	225	64	7	0	0	0	3	53	244	478	
	CDD50	6744	103	153	315	511	760	935	1063	1074	853	586	273	118	
	CDD65	2807	5	15	45	124	303	485	598	609	406	173	35	9	
	CDH74	31136	37	112	307	1003	2787	5462	7517	7790	4280	1555	237	49	
	CDH80	15501	4	22	49	269	1095	2718	4212	4449	2094	546	40	3	
Wind	WSAvg	9.9	9.9	10.4	11.2	11.7	11.1	10.3	9.6	8.7	7.8	8.9	9.3	9.3	
Precipitation	PrecAvg	36.6	2.4	2.5	3.1	2.6	4.8	3.4	2.1	2.4	3.3	3.8	2.9	2.6	
	PrecMax	52.4	6.7	6.5	8.5	7.9	11.5	10.7	5.9	10.7	9.4	11.6	9.5	9.4	
	PrecMin	21.5	0.0	0.0	0.0	0.4	0.4	0.4	0.0	0.0	0.5	0.5	0.3	0.2	
	PrecStd	9.5	1.7	1.7	1.9	1.7	2.4	2.3	1.6	2.6	2.5	3.1	2.3	2.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	82.4	84.3	90.9	95.7	100.2	102.5	102.5	100.1	92.5	84.1	79.4	
		MCWB	60.2	62.8	65.7	69.4	73.4	74.9	74.0	74.6	73.4	71.0	69.0	63.6	
	2%	DB	73.1	77.3	81.1	86.3	91.3	97.2	100.0	100.2	96.9	89.8	80.7	73.7	
		MCWB	60.2	61.9	65.3	68.3	73.9	75.0	74.1	74.2	73.5	70.9	66.2	62.6	
	5%	DB	69.9	72.8	77.5	82.3	89.6	93.8	98.6	99.1	93.2	86.1	75.9	70.3	
		MCWB	59.4	61.2	64.3	68.2	73.1	74.9	74.3	74.3	73.1	69.7	64.4	61.4	
	10%	DB	65.6	69.7	73.3	80.5	86.3	91.4	96.2	97.0	90.6	82.2	72.7	66.0	
		MCWB	58.2	61.2	62.3	66.9	72.7	74.9	74.8	74.5	72.9	67.7	63.7	59.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.9	69.2	70.7	75.1	78.2	80.1	79.5	78.9	78.4	76.5	72.9	69.2
			MCDB	71.9	74.4	79.1	84.4	88.4	89.8	91.6	91.3	89.0	84.2	79.5	73.3
2%		WB	64.7	67.0	68.6	72.9	76.7	78.3	78.2	77.9	77.2	74.7	70.1	66.4	
		MCDB	69.2	71.8	75.7	81.8	86.5	89.7	90.6	91.0	87.6	82.8	75.6	71.4	
5%		WB	62.6	64.8	67.2	71.1	75.3	77.3	77.3	77.1	76.2	73.2	67.9	63.7	
		MCDB	66.9	69.7	73.5	79.6	84.4	89.2	89.9	90.5	86.3	81.0	73.5	68.4	
10%		WB	58.9	62.1	65.4	69.4	74.0	76.4	76.5	76.3	75.0	71.5	65.7	60.2	
		MCDB	64.7	68.3	71.4	76.4	83.1	87.4	89.0	89.6	85.0	79.0	71.4	64.9	
Mean Daily Temperature Range	5% DB	MDBR	21.9	21.5	21.6	22.1	20.1	20.1	21.9	22.5	22.0	22.7	21.7	21.4	
		MCDBR	27.9	26.2	23.8	23.9	22.7	22.7	25.4	25.6	24.7	24.7	23.9	25.6	
		MCWBR	17.0	15.8	13.2	12.1	9.1	6.9	6.4	6.6	7.7	11.1	13.7	16.5	
	5% WB	MCDBR	20.6	20.5	19.6	18.7	18.8	19.2	21.1	21.7	20.0	19.0	19.3	20.5	
		MCWBR	15.5	14.9	12.5	10.7	8.9	6.8	6.3	6.4	7.3	10.0	13.5	15.7	
Clear-Sky Solar Irradiance	taub	0.316	0.332	0.357	0.399	0.432	0.429	0.442	0.432	0.401	0.371	0.349	0.321		
	taud	2.514	2.473	2.415	2.322	2.281	2.330	2.327	2.340	2.376	2.445	2.451	2.502		
	Ebn at Noon	291	295	293	284	273	272	268	270	276	277	275	282		
	Edh at Noon	28	31	36	41	43	41	41	40	37	32	29	27		
All-Sky Solar Radiation	RadAvg	945	1092	1427	1719	1831	2088	2128	1981	1652	1330	998	831		
	RadStd	99	190	126	154	162	161	159	113	141	194	119	112		

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+137

Nomenclature: See separate page