

DALLAS LOVE FIELD, TX, USA

WMO: 722580

Lat: 32.852N

Lon: 96.856W

Elev: 440

StdP: 14.46

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13960

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.7	28.5	8.2	8.5	32.3	12.5	10.6	35.7	25.8	47.1	23.6	49.0	9.8	350	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.1	101.6	74.7	99.4	75.3	97.4	75.1	79.1	92.7	78.1	91.5	77.3	90.5	9.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.4	135.3	84.3	74.6	131.5	83.7	73.5	126.6	82.9	42.8	92.9	41.7	91.3	40.9	90.5	91.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.4	20.5	18.8	18.7	105.0	3.2	2.9	16.4	107.2	14.6	108.9	12.8	110.5	10.5	112.6		
			16.2	80.6	3.0	2.9	14.0	82.7	12.3	84.4	10.6	86.0	8.4	88.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.0	47.9	51.8	59.3	67.1	75.4	83.1	87.0	87.2	80.1	69.2	58.1	49.3
	DBStd	16.04	10.08	10.67	9.46	7.29	6.32	4.31	4.14	4.63	6.45	8.10	9.03	9.50
	HDD50	448	161	97	30	2	0	0	0	0	0	1	29	128
	HDD65	1996	536	382	222	61	8	0	0	0	2	52	240	493
	CDD50	7035	95	147	319	516	788	993	1146	1153	904	596	271	107
	CDD65	3104	4	13	45	125	330	543	681	688	456	181	31	7
	CDH74	37407	23	85	302	942	3158	6694	9508	9662	5252	1563	185	33
	CDH80	19120	1	15	50	216	1206	3373	5489	5669	2556	517	26	2
Wind	WSAvg	9.5	9.2	9.9	10.9	11.5	11.0	10.3	9.1	8.2	7.8	8.7	9.0	8.8
Precipitation	PrecAvg	36.5	1.9	2.7	3.0	3.7	4.7	3.7	2.3	2.2	3.3	4.1	2.4	2.5
	PrecMax	55.3	4.1	7.9	9.1	15.4	10.6	10.9	8.5	6.0	10.7	16.1	7.0	9.3
	PrecMin	17.5	0.0	0.2	0.3	0.0	0.6	0.3	0.0	0.0	0.0	0.0	0.2	0.0
	PrecStd	9.2	1.2	1.7	2.0	2.8	2.7	2.7	2.0	1.7	2.4	3.4	1.7	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.3	81.8	84.9	89.2	95.6	100.1	104.3	105.5	101.3	92.4	83.6	78.5
		MCWB	60.6	60.9	65.6	69.8	74.0	75.5	74.6	73.9	73.1	71.8	67.2	63.7
	2%	DB	72.5	76.2	80.8	85.1	92.2	97.5	101.3	102.1	97.3	89.1	78.9	72.8
		MCWB	59.4	61.8	64.9	68.7	73.7	75.1	74.7	74.8	74.0	71.0	66.0	61.4
	5%	DB	68.5	72.2	77.3	82.3	89.3	95.1	99.2	99.9	94.5	85.7	75.5	69.2
		MCWB	58.7	60.8	63.0	67.3	72.7	75.0	75.4	75.2	73.4	69.1	64.2	60.1
	10%	DB	64.5	68.6	73.9	79.6	86.6	92.9	96.9	97.6	91.6	82.4	72.4	65.2
		MCWB	56.0	59.6	62.1	66.0	71.8	74.8	75.4	75.0	72.8	67.7	63.0	57.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.5	68.4	70.2	74.3	78.5	80.7	80.6	80.4	78.3	76.1	71.5	67.8
		MCDB	71.6	73.8	78.5	83.3	88.5	93.1	95.7	94.4	92.0	84.4	78.6	73.1
	2%	WB	64.2	66.4	68.2	72.0	76.6	78.7	78.8	78.5	77.1	74.5	69.1	65.4
		MCDB	68.8	71.7	76.0	80.7	86.7	91.1	93.2	92.6	89.7	83.0	74.9	71.1
	5%	WB	61.4	64.1	66.5	70.4	75.2	77.4	77.9	77.6	76.1	73.0	66.9	62.3
		MCDB	66.7	69.9	74.1	78.5	85.1	89.5	91.9	92.0	87.6	81.5	73.3	67.4
	10%	WB	56.8	60.6	64.5	68.9	73.8	76.5	77.0	76.9	75.1	71.2	64.6	58.6
		MCDB	62.9	67.4	72.2	76.4	83.8	88.2	90.7	91.0	86.0	79.5	71.3	63.9
Mean Daily Temperature Range	5% DB	MDBR	18.7	18.7	19.1	19.1	17.7	17.3	17.8	18.1	18.3	19.1	18.5	17.9
		MCDBR	24.4	23.4	22.4	21.0	19.7	19.1	19.7	20.1	20.3	21.5	21.1	22.9
		MCWBR	14.9	14.2	11.8	10.4	7.4	5.4	5.0	4.9	5.9	8.9	11.8	14.2
	5% WB	MCDBR	19.2	19.5	18.6	17.4	17.3	17.2	17.8	18.0	16.9	17.2	18.0	19.0
MCWBR		15.1	14.8	12.7	10.9	8.4	6.2	5.7	5.3	6.0	8.7	13.7	15.2	
Clear-Sky Solar Irradiance	taub	0.317	0.331	0.361	0.399	0.430	0.443	0.445	0.447	0.404	0.361	0.340	0.322	
	taud	2.496	2.467	2.399	2.314	2.288	2.285	2.318	2.296	2.366	2.471	2.470	2.486	
	Ebn at Noon	286	293	291	283	273	268	267	266	273	279	275	278	
	Edh at Noon	27	31	36	41	43	43	41	41	37	31	28	26	
All-Sky Solar Radiation	RadAvg	907	1060	1405	1708	1843	2076	2118	1946	1634	1282	963	798	
	RadStd	90	166	110	130	168	198	143	126	142	190	122	102	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+191	N/A
Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page