

DALLAS HENSLEY FIELD, TX, USA

WMO: 722585

Lat: 32.733N

Lon: 96.967W

Elev: 492

StdP: 14.44

Time Zone: -6.00 (NAC)

Period: 86-96

WBAN: 93901

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.5	27.2	6.3	7.8	27.5	11.8	10.2	32.2	25.7	55.2	23.7	53.6	10.5	0	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	99.6	75.5	97.5	75.4	95.3	75.0	79.0	92.0	77.9	91.2	77.0	90.2	7.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.4	135.5	85.6	74.2	130.1	84.2	73.2	125.7	83.3	42.8	91.8	41.6	91.4	40.6	90.3	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	18.7	17.0	18.1	103.1	7.5	2.6	12.7	105.0	8.3	106.5	4.1	108.0	-1.4	109.9
			15.8	82.3	7.3	2.3	10.5	83.9	6.2	85.3	2.1	86.6	-3.3	88.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.5	47.2	51.1	57.7	65.8	73.9	81.2	85.0	84.6	78.1	67.9	56.3	48.2
	DBStd	15.61	8.69	10.72	9.42	7.46	6.07	4.23	3.36	4.74	6.75	7.81	9.73	9.98
	HDD50	499	157	105	39	2	0	0	0	0	0	4	45	147
	HDD65	2171	553	395	254	80	9	0	0	0	6	60	290	524
	CDD50	6528	70	138	279	477	741	937	1086	1072	842	559	235	92
	CDD65	2723	1	7	29	105	285	487	621	607	398	150	29	4
	CDH74	30127	10	94	208	789	2354	5455	8016	7677	4098	1230	185	11
	CDH80	14258	0	24	34	194	804	2538	4282	4148	1803	394	37	0
Wind	WSAvg	7.8	7.8	7.9	9.2	9.1	8.9	7.5	8.1	6.8	6.4	7.4	8.0	7.1
Precipitation	PrecAvg	33.1	1.9	2.2	2.6	3.4	4.6	3.2	2.2	2.3	3.3	3.3	1.9	2.1
	PrecMax	45.6	3.9	5.0	7.8	9.9	10.2	8.5	8.5	7.0	6.9	9.2	4.8	7.5
	PrecMin	18.5	0.0	0.1	0.2	0.1	0.6	0.0	0.1	0.0	0.4	0.0	0.3	0.2
	PrecStd	7.2	1.1	1.3	1.9	2.4	3.1	2.6	1.9	1.8	2.0	2.5	1.3	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.0	83.3	84.3	90.5	93.3	98.9	102.4	102.5	97.8	92.0	84.9	75.3
		MCWB	58.5	59.5	62.5	66.7	72.7	77.5	75.9	75.1	74.1	68.7	66.0	61.3
	2%	DB	69.9	76.2	79.2	85.3	90.0	95.7	99.4	100.2	94.6	87.9	78.9	70.4
		MCWB	56.4	58.3	61.2	67.0	72.9	76.7	75.3	75.4	73.4	68.1	64.3	59.4
	5%	DB	65.8	71.3	75.6	81.4	87.4	93.5	97.3	98.1	92.2	84.6	75.1	67.3
		MCWB	55.0	57.4	61.4	66.2	72.3	75.7	75.5	75.1	73.3	67.8	63.3	58.9
	10%	DB	61.9	66.6	72.2	78.5	84.8	91.2	94.9	95.5	89.5	81.0	71.6	63.3
		MCWB	53.6	55.5	60.5	65.4	71.1	75.1	75.4	74.7	73.1	65.8	61.4	54.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.1	64.2	69.0	73.9	78.8	80.6	80.6	79.4	78.2	75.4	70.2	66.2
		MCDB	69.2	72.3	76.4	81.7	88.0	93.2	93.9	93.9	90.0	84.6	77.6	70.5
	2%	WB	60.3	62.1	67.0	71.4	76.1	79.0	78.8	77.9	76.8	72.2	68.0	63.8
		MCDB	66.0	70.4	73.7	79.5	85.2	91.8	92.2	93.2	88.4	81.6	75.3	69.0
	5%	WB	57.6	59.8	64.5	69.4	74.6	77.7	77.6	76.9	75.8	69.4	65.9	59.9
		MCDB	63.0	68.8	71.5	77.1	83.1	90.0	91.5	92.2	86.8	79.5	72.8	64.9
	10%	WB	53.9	56.8	62.1	67.7	72.8	76.6	76.7	75.9	74.9	67.9	63.4	55.8
		MCDB	60.7	64.8	69.8	76.0	81.6	87.9	90.5	90.8	85.5	78.4	70.1	62.2
Mean Daily Temperature Range	5% DB	MDBR	18.6	19.2	20.0	20.0	17.2	18.3	19.3	19.0	19.2	20.9	19.4	17.5
		MCDBR	26.2	27.4	24.2	23.4	19.8	20.7	22.4	21.8	21.0	24.4	22.6	23.5
		MCWBR	17.1	15.4	13.3	12.5	9.2	8.4	7.7	6.7	7.6	11.8	12.6	15.5
	5% WB	MCDBR	19.4	22.5	17.7	17.9	17.0	18.8	19.5	19.9	17.4	19.2	18.1	18.0
		MCWBR	16.0	14.6	13.2	12.6	9.5	8.9	7.8	7.0	7.3	11.1	13.4	15.2
Clear-Sky Solar Irradiance	taub	0.316	0.330	0.360	0.398	0.429	0.441	0.443	0.444	0.403	0.361	0.340	0.321	
	taud	2.498	2.467	2.401	2.316	2.292	2.291	2.323	2.303	2.367	2.470	2.469	2.486	
	Ebn at Noon	287	294	291	283	274	269	268	266	273	279	275	278	
	Edh at Noon	27	31	36	41	42	42	41	41	37	31	28	26	
All-Sky Solar Radiation	RadAvg	914	1068	1413	1717	1851	2082	2125	1951	1638	1287	969	805	
	RadStd	90	169	111	133	169	196	144	127	140	191	123	104	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page