

DALLAS FORT WORTH, TX, USA

WMO: 722590

Lat: 32.898N

Lon: 97.019W

Elev: 560

StdP: 14.40

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 03927

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	27.4	8.9	8.9	30.8	13.0	10.9	35.9	29.6	49.7	27.3	52.1	11.4	340	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.1	101.4	74.2	99.1	74.6	96.9	74.7	78.6	91.6	77.8	90.9	77.1	90.0	10.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.4	135.7	83.8	74.3	131.0	83.1	73.5	127.1	82.5	42.5	91.7	41.5	90.8	40.7	90.0	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	23.9	20.8	17.5	104.6	3.4	3.2	15.0	106.9	13.0	108.8	11.1	110.6	8.6	112.9
			15.4	80.2	3.0	1.5	13.2	81.3	11.4	82.1	9.7	82.9	7.5	84.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	47.1	51.0	58.6	66.2	74.6	82.5	86.2	86.4	79.4	68.5	57.5	48.6
	DBStd	16.06	10.10	10.71	9.57	7.38	6.43	4.39	3.95	4.54	6.34	8.12	9.28	9.53
	HDD50	499	175	107	35	3	0	0	0	0	0	2	35	142
	HDD65	2113	559	402	240	72	10	0	0	0	2	58	255	515
	CDD50	6814	85	135	300	490	763	974	1122	1129	883	577	259	97
	CDD65	2956	4	11	40	109	308	524	657	664	435	168	30	6
	CDH74	35106	27	86	286	828	2884	6312	9001	9130	4850	1473	194	35
	CDH80	17711	1	15	49	181	1085	3153	5110	5268	2317	496	32	4
Wind	WSAvg	10.6	10.9	11.3	12.1	12.5	11.6	10.7	9.7	8.8	8.5	9.7	10.5	10.4
Precipitation	PrecAvg	34.6	2.1	2.3	2.9	3.3	4.7	3.3	2.2	2.2	3.0	3.8	2.4	2.4
	PrecMax	62.6	6.2	7.4	7.4	10.7	17.0	11.1	11.1	6.9	12.7	15.7	9.8	8.7
	PrecMin	20.5	0.0	0.2	0.1	0.1	0.4	0.4	0.0	0.0	0.1	0.0	0.0	0.2
	PrecStd	8.9	1.5	1.6	1.9	2.0	3.1	2.5	1.9	1.7	2.5	3.1	2.0	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.7	81.6	85.0	88.5	95.4	100.0	103.8	105.1	101.3	92.4	84.1	78.7
		MCWB	60.3	60.9	65.6	69.3	74.1	74.9	74.2	73.7	72.4	71.4	66.9	63.7
	2%	DB	72.4	76.3	80.5	84.5	92.0	97.2	101.0	102.1	96.6	89.1	79.3	72.7
		MCWB	58.8	61.6	65.1	68.3	73.3	75.2	74.5	74.0	73.2	70.7	65.2	60.9
	5%	DB	68.1	72.0	77.1	81.7	89.0	94.9	98.7	99.6	93.8	85.5	75.4	68.9
		MCWB	58.2	60.1	63.3	67.2	72.4	74.8	74.9	74.6	73.0	68.5	64.2	59.5
	10%	DB	64.1	68.2	73.5	79.0	86.1	92.7	96.4	97.2	91.2	82.2	72.0	64.6
		MCWB	55.4	58.9	62.0	66.0	71.6	74.6	75.1	74.6	72.4	67.4	62.7	56.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.4	68.0	70.3	74.2	78.3	80.4	80.1	79.2	77.7	75.8	71.7	67.8
		MCDB	71.3	75.1	79.3	83.2	88.9	92.5	92.7	92.4	90.3	84.0	78.5	73.7
	2%	WB	64.0	65.8	68.2	71.9	76.2	78.5	78.5	78.0	76.4	73.9	68.8	64.9
		MCDB	68.5	71.4	76.0	80.5	86.4	90.7	92.1	91.7	88.4	82.8	74.9	70.7
	5%	WB	60.5	63.6	66.4	70.3	74.9	77.4	77.7	77.2	75.5	72.6	66.7	61.7
		MCDB	66.0	69.4	73.8	77.9	84.7	89.2	91.5	91.1	86.8	81.3	73.1	66.6
	10%	WB	55.9	60.2	64.4	68.8	73.5	76.3	76.9	76.5	74.7	70.9	64.2	57.8
		MCDB	62.1	66.9	71.6	75.9	83.2	87.8	90.5	90.2	85.7	78.9	70.9	63.6
Mean Daily Temperature Range	5% DB	MDBR	19.8	19.8	19.9	19.7	18.2	18.2	18.9	19.1	18.9	20.0	19.3	18.7
		MCDBR	26.5	25.1	23.2	21.8	20.8	20.2	21.0	21.5	21.1	22.7	22.4	24.2
		MCWBR	16.3	15.0	12.5	11.3	7.9	5.8	5.3	5.2	6.3	9.4	12.3	15.1
	5% WB	MCDBR	20.9	20.7	19.3	17.8	18.0	18.3	18.6	18.8	17.4	18.1	18.7	19.7
		MCWBR	15.9	15.2	12.9	11.4	8.9	6.7	6.1	5.5	6.2	9.1	13.6	15.8
Clear-Sky Solar Irradiance	taub	0.315	0.328	0.359	0.395	0.427	0.439	0.441	0.442	0.401	0.360	0.338	0.319	
	taud	2.499	2.470	2.402	2.322	2.294	2.294	2.294	2.326	2.307	2.370	2.472	2.473	2.487
	Ebn at Noon	287	294	292	284	274	269	268	267	274	279	276	279	
	Edh at Noon	27	31	36	41	42	42	41	41	37	31	28	26	
All-Sky Solar Radiation	RadAvg	912	1071	1414	1717	1852	2085	2125	1951	1636	1283	968	802	
	RadStd	91	168	109	134	174	199	143	125	142	191	124	102	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.65	N/A	N/A	N/A	-0.81	-0.95	N/A	N/A	+245	+169
	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page