

FORT WORTH NAS, TX, USA

WMO: 722595

Lat: 32.767N

Lon: 97.450W

Elev: 608

StdP: 14.38

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13911

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.6	28.4	7.1	8.1	31.7	11.6	10.1	36.7	28.0	49.7	25.6	51.4	10.3	0	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	102.7	73.1	100.4	73.7	98.3	73.8	78.2	92.4	77.3	91.3	76.5	90.1	9.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.7	132.7	83.4	73.5	127.4	82.6	72.8	124.4	82.4	42.1	92.3	41.1	91.3	40.2	90.3	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.9	22.2	19.9	18.4	105.2	4.2	2.8	15.4	107.2	12.9	108.9	10.6	110.4	7.5	112.4		
			DB	WB	15.8	80.8	3.6	2.3	13.2	82.5	11.1	83.8	9.1	85.1	6.5	86.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.0	47.5	51.9	59.4	66.4	75.3	83.4	87.0	86.9	80.6	68.8	58.1	49.5
	DBStd	16.13	9.96	10.59	9.89	7.74	6.44	4.77	4.10	4.64	6.34	8.58	9.18	9.46
	HDD50	459	164	95	36	3	0	0	0	0	0	2	33	126
	HDD65	2019	545	381	223	74	8	0	0	0	2	59	239	488
	CDD50	7022	87	147	326	496	783	1001	1148	1144	918	586	276	110
	CDD65	3109	3	13	49	117	326	551	683	679	470	178	33	7
	CDH74	38305	43	131	388	997	3198	7023	9667	9434	5508	1650	213	53
	CDH80	20100	3	32	83	268	1283	3732	5701	5548	2807	595	40	8
(14) Wind	WSAvg	9.6	9.6	10.0	11.3	11.6	10.9	10.4	9.0	8.0	7.5	8.9	9.3	8.9
(15) Precipitation	PrecAvg	35.3	2.1	2.1	2.9	3.7	4.4	3.3	2.2	2.3	2.9	4.0	2.9	2.4
	PrecMax	56.8	5.7	7.0	6.2	7.8	13.5	12.4	5.0	7.2	10.5	10.8	9.5	9.9
	PrecMin	14.5	0.2	0.0	0.0	0.6	0.5	0.4	0.0	0.6	0.5	0.1	0.4	0.4
	PrecStd	9.6	1.3	1.8	1.7	1.8	2.7	2.8	1.5	1.8	2.2	2.8	2.4	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.8	84.3	86.6	90.3	96.8	101.8	105.6	106.2	101.6	94.3	84.4	80.4
		MCWB	59.3	60.6	63.5	69.6	72.4	73.4	72.5	72.4	72.9	70.5	65.9	62.6
	2%	DB	73.3	77.6	82.0	86.0	93.0	99.1	102.5	103.1	98.5	89.8	79.5	73.8
		MCWB	58.1	61.0	64.5	68.2	72.9	73.9	73.0	73.1	73.0	70.6	64.5	60.3
	5%	DB	68.5	73.0	78.4	83.0	90.1	96.7	100.3	100.8	95.5	86.4	75.7	69.8
		MCWB	56.1	58.9	62.8	66.8	71.4	73.9	73.7	72.0	68.9	63.9	58.8	55.6
	10%	DB	64.0	68.9	74.6	79.9	87.3	94.2	98.0	98.1	92.8	83.1	72.4	65.4
		MCWB	54.2	57.3	61.3	65.6	70.7	74.0	74.1	73.8	72.0	67.0	61.5	55.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.3	67.8	69.6	73.6	78.3	79.4	79.4	79.4	78.0	75.2	71.6	67.3
		MCDB	72.3	77.0	80.3	83.8	88.9	94.0	94.2	93.2	93.1	85.1	78.7	74.2
	2%	WB	62.3	65.1	67.5	71.5	75.8	77.8	78.0	77.9	76.3	73.7	68.2	64.6
		MCDB	68.1	72.3	77.0	82.2	86.5	91.4	93.0	91.8	89.6	83.2	74.8	71.2
	5%	WB	59.0	62.4	65.8	69.7	74.3	76.8	77.1	77.0	75.2	72.3	66.0	60.4
		MCDB	66.2	70.0	74.2	79.0	85.2	89.9	91.8	90.8	87.5	81.5	72.9	67.0
	10%	WB	54.8	58.9	64.0	68.2	73.0	75.6	76.2	76.1	74.3	70.8	64.0	57.0
		MCDB	62.7	67.0	71.9	76.9	83.7	88.5	90.4	89.6	86.1	80.0	70.9	64.2
(35) Mean Daily Temperature Range	5% DB	MDBR	21.2	20.5	20.8	20.3	18.8	18.9	19.6	19.3	19.2	20.4	19.7	19.2
		MCDBR	28.3	26.9	25.0	23.4	21.5	21.4	22.3	22.2	22.3	22.3	23.4	25.5
		MCWBR	16.4	15.3	12.7	12.3	8.5	5.6	5.6	5.5	6.4	9.3	12.9	15.0
	5% WB	MCDBR	23.2	23.5	20.0	19.1	18.6	18.9	19.1	19.0	18.2	18.3	19.0	21.2
		MCWBR	16.4	16.0	12.8	11.9	9.3	6.6	6.0	6.1	6.4	9.3	13.8	15.8
(40) Clear-Sky Solar Irradiance	taub		0.312	0.324	0.356	0.394	0.426	0.436	0.439	0.436	0.401	0.359	0.336	0.318
	taud		2.499	2.473	2.404	2.323	2.296	2.302	2.331	2.323	2.367	2.469	2.471	2.485
	Ebn at Noon		289	296	292	284	275	270	269	269	274	279	277	279
	Edh at Noon		27	31	36	41	42	42	40	40	37	31	28	26
(44) All-Sky Solar Radiation	RadAvg		933	1102	1442	1743	1877	2109	2147	1964	1647	1293	985	819
	RadStd		93	174	109	145	187	199	146	124	139	193	126	105

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page