

DALLAS EXECUTIVE, TX, USA

WMO: 722599

Lat: 32.681N

Lon: 96.868W

Elev: 201

StdP: 98.94

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 03971

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.0	-2.2	-12.6	1.3	0.3	-10.3	1.6	3.3	11.7	7.6	10.8	8.2	4.1	350	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	38.6	23.4	37.3	23.7	36.1	23.6	25.7	33.0	25.2	32.7	24.9	32.1	3.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.2	28.1	23.3	18.5	27.7	22.9	18.1	27.5	80.0	33.4	77.9	32.6	76.4	32.2	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.1	8.7	7.8	DB	-8.0	40.3	1.8	1.8	-9.3	41.6	-10.4	42.6	-11.4	43.6	-12.7	44.9	
			WB	-9.1	26.6	1.6	0.8	-10.3	27.1	-11.2	27.6	-12.2	28.0	-13.3	28.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	8.8	10.6	14.7	19.0	23.3	27.6	29.7	30.0	26.2	20.1	14.1	9.4
	DBStd	8.73	5.58	5.91	5.18	3.98	3.43	2.43	2.33	2.59	3.39	4.54	5.17	5.32
	HDD10.0	264	90	59	18	1	0	0	0	0	1	19	76	
	HDD18.3	1157	298	222	133	39	6	0	0	0	1	35	142	281
	CDD10.0	3741	53	76	165	270	413	529	612	622	486	314	144	58
	CDD18.3	1590	2	6	21	58	161	279	353	363	236	90	17	3
	CDH23.3	18302	13	34	131	407	1449	3226	4668	4898	2596	764	98	17
Wind	WSAvg	9149	1	3	17	83	512	1579	2610	2821	1258	249	14	2
	WSAvg	3.8	4.1	4.3	4.5	4.5	4.1	3.8	3.3	3.1	3.1	3.5	3.8	4.0
	PrecAvg	939	67	64	87	97	121	96	56	58	68	106	77	72
	PrecMax	1374	158	181	166	193	400	286	125	136	243	303	261	226
	PrecMin	557	0	1	0	35	4	14	0	0	7	1	8	3
Precipitation	PrecStd	217	40	44	47	44	73	69	37	35	59	78	59	52
	DB	25.2	26.9	28.6	30.8	34.8	37.8	40.2	40.7	38.6	33.1	28.6	25.6	
	MCWB	15.8	16.6	18.9	21.3	23.4	24.1	23.7	23.4	22.5	22.0	19.7	18.1	
	DB	22.4	24.0	26.6	28.7	32.6	36.2	38.4	38.8	36.0	31.3	26.1	22.5	
	MCWB	14.9	16.0	18.3	19.9	22.5	23.8	23.7	23.3	22.8	21.5	18.4	16.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	20.2	22.1	24.7	27.4	31.1	34.7	37.1	37.5	34.1	29.3	24.0	20.6	
	MCWB	14.4	16.1	17.3	19.7	22.3	23.5	24.0	23.6	22.7	20.6	17.7	15.8	
	DB	17.9	20.0	22.8	25.9	29.5	33.2	35.6	36.3	32.8	27.6	22.3	18.2	
	MCWB	13.4	15.2	16.6	18.9	21.7	23.6	23.9	23.5	22.5	19.9	17.0	14.0	
	WB	19.1	20.0	20.9	23.3	25.2	26.6	26.2	26.0	25.5	24.4	21.8	20.1	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	21.8	23.6	25.5	27.9	31.3	33.9	33.8	32.9	32.1	29.1	25.3	22.9	
	WB	17.8	18.9	19.9	22.0	24.3	25.6	25.4	24.8	23.4	20.4	18.7		
	MCDB	19.9	21.9	24.1	26.7	29.7	32.4	33.3	33.3	31.2	28.0	23.5	21.4	
	WB	16.2	17.7	19.1	21.2	23.6	25.0	25.2	25.0	24.2	22.7	19.3	16.9	
	MCDB	19.0	20.3	23.0	25.1	28.8	31.5	32.9	33.0	30.3	27.0	22.6	19.3	
Mean Daily Temperature Range	WB	13.8	16.0	18.0	20.4	22.9	24.5	24.8	24.6	23.8	21.8	18.0	14.6	
	MCDB	16.9	19.5	21.7	24.1	27.9	30.7	32.3	32.4	29.7	25.8	21.3	17.8	
	MDBR	10.5	10.5	10.7	10.7	10.1	10.1	10.7	11.1	11.1	11.1	10.5	10.2	
	5% DB	13.5	12.7	12.1	11.5	11.3	11.5	11.9	12.2	12.3	12.3	11.9	12.7	
	MCWBR	8.3	8.0	6.6	6.0	4.5	3.3	3.0	3.2	3.7	5.3	6.7	8.2	
Clear-Sky Solar Irradiance	5% WB	10.9	10.8	10.2	9.3	9.6	9.9	10.6	10.9	10.4	10.0	10.0	10.7	
	MCWBR	8.6	8.5	6.8	6.0	4.7	3.6	3.3	3.1	3.6	5.1	7.4	8.9	
	taub	0.314	0.328	0.357	0.395	0.425	0.437	0.440	0.441	0.399	0.358	0.338	0.319	
	taud	2.504	2.471	2.408	2.322	2.299	2.296	2.329	2.307	2.373	2.477	2.474	2.492	
	Ebn at Noon	908	928	922	895	867	852	847	842	866	883	871	880	
All-Sky Solar Radiation	Edh at Noon	86	98	113	128	132	132	128	128	115	96	88	83	
	RadAvg	2.87	3.35	4.44	5.40	5.82	6.55	6.69	6.14	5.16	4.05	3.05	2.53	
	RadStd	0.28	0.53	0.35	0.41	0.52	0.61	0.46	0.40	0.44	0.60	0.39	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page