

TERRELL COUNTY AP, TX, USA

WMO: 722616

Lat: 30.048N

Lon: 102.213W

Elev: 2322

StdP: 13.50

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 03032

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.4	31.9	2.1	6.7	50.5	6.5	8.4	52.6	26.3	57.9	24.1	61.2	6.7	30	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.2	102.2	69.8	100.0	69.6	97.8	69.6	75.3	90.2	74.4	89.1	73.6	87.9	12.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	129.3	78.9	70.9	124.1	78.7	70.1	120.7	78.6	40.4	89.9	39.5	89.1	38.7	88.0	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.2	20.7	18.7	DB	22.0	107.4	5.3	4.5	18.1	110.7	15.0	113.3	12.0	115.8	8.1	119.1	
			WB	18.6	77.0	4.5	1.9	15.4	78.3	12.8	79.5	10.3	80.5	7.1	81.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	50.2	54.9	63.0	70.7	77.5	83.6	84.0	84.6	78.9	69.8	58.9	50.9
	DBStd	14.23	8.02	9.17	7.94	7.03	6.43	4.32	4.07	4.21	5.24	7.07	7.82	7.91
	HDD50	260	96	49	10	1	0	0	0	0	0	1	18	85
	HDD65	1602	459	295	130	27	4	0	0	0	1	37	208	441
	CDD50	7189	102	186	414	623	851	1007	1055	1073	866	614	286	112
	CDD65	3057	1	12	69	199	390	557	590	608	417	184	27	3
	CDH74	36325	67	281	826	2196	4386	7060	7424	7744	4339	1637	283	82
	CDH80	18945	10	80	283	964	2264	3963	4157	4410	2130	609	61	14
Wind	WSAvg	9.1	8.2	8.9	9.6	10.3	10.6	10.5	9.8	8.6	8.4	8.3	7.9	8.0
Precipitation	PrecAvg	14.5	0.6	0.7	0.8	0.7	1.5	1.8	2.0	1.9	1.9	1.5	0.8	0.4
	PrecMax	19.6	1.8	2.4	3.4	1.9	5.7	4.2	9.4	5.2	5.2	4.5	3.7	2.1
	PrecMin	9.4	0.0	0.1	0.0	0.0	0.2	0.0	0.2	0.1	0.1	0.0	0.0	0.0
	PrecStd	3.0	0.6	0.6	0.9	0.6	1.4	1.3	2.2	1.4	1.7	1.4	0.9	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.6	88.1	92.0	98.2	103.0	106.4	103.2	104.2	100.9	94.0	86.1	81.9
		MCWB	52.9	55.5	57.5	62.0	65.0	70.5	71.4	70.9	67.3	66.1	60.4	54.0
	2%	DB	74.9	81.7	87.0	93.6	99.0	102.0	100.5	101.4	97.0	89.8	81.1	75.3
		MCWB	52.2	54.5	57.6	61.1	66.2	70.1	70.9	70.9	68.8	66.6	59.7	53.0
	5%	DB	69.7	76.9	82.7	89.9	95.3	98.6	98.5	99.1	93.4	86.7	76.9	70.0
		MCWB	50.8	53.8	58.3	61.2	65.2	70.5	70.6	70.6	68.4	65.3	58.5	52.1
	10%	DB	64.5	71.1	78.3	85.6	91.6	95.4	96.0	96.6	90.8	83.0	72.8	64.3
		MCWB	49.7	53.2	57.4	61.4	66.7	70.7	70.6	70.5	68.5	65.1	57.2	50.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.9	63.3	67.2	70.8	75.3	76.6	76.4	75.6	75.2	73.6	68.5	61.8
		MCDB	66.0	72.1	78.0	84.0	88.1	94.0	90.0	91.2	88.4	83.4	75.5	67.8
	2%	WB	57.7	60.9	65.5	69.1	73.4	75.3	75.1	74.4	73.8	71.6	66.3	58.8
		MCDB	66.3	68.5	75.3	82.0	85.6	90.6	90.1	90.3	86.6	81.2	72.4	64.5
	5%	WB	54.4	58.5	63.9	67.9	72.3	74.4	74.0	73.5	72.7	70.2	63.3	56.1
		MCDB	63.2	68.5	73.0	79.2	84.1	89.2	88.6	89.8	85.0	79.3	69.9	64.2
	10%	WB	51.4	55.4	62.1	66.5	71.0	73.3	73.1	72.7	71.6	68.6	60.6	52.9
		MCDB	62.4	68.5	71.5	77.1	82.8	87.6	87.3	88.7	83.1	77.5	69.5	62.7
Mean Daily Temperature Range	5% DB	MDBR	23.4	25.4	25.9	25.8	24.1	22.9	21.5	22.2	21.3	22.7	23.3	23.2
		MCDBR	31.7	33.5	32.2	31.4	29.9	27.3	25.2	25.2	25.2	26.5	28.3	31.0
		MCWBR	15.8	15.2	12.8	12.6	11.4	8.1	7.8	7.5	8.5	10.0	12.9	15.2
	5% WB	MCDBR	25.0	25.1	21.7	23.4	22.4	21.9	20.9	21.7	19.9	19.8	20.3	22.0
	MCWBR	14.5	14.1	10.7	10.7	9.5	7.7	6.9	7.1	6.9	8.3	11.1	13.1	
Clear-Sky Solar Irradiance	taub	0.271	0.279	0.297	0.333	0.359	0.377	0.392	0.368	0.359	0.315	0.291	0.272	
	taud	2.616	2.587	2.534	2.428	2.396	2.411	2.406	2.494	2.448	2.581	2.571	2.603	
	Ebn at Noon	311	317	315	304	294	287	283	290	290	299	300	305	
	Edh at Noon	25	28	32	37	38	37	38	34	34	28	26	24	
All-Sky Solar Radiation	RadAvg	1136	1416	1793	2110	2224	2324	2218	2085	1760	1477	1201	1038	
	RadStd	115	151	109	145	139	117	145	116	121	162	127	96	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page