

CLINES CORNERS, NM, USA

WMO: 722677

Lat: 35.003N

Lon: 105.663W

Elev: 7086

StdP: 11.30

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 03027

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 9.3	(c) 13.5	(d) -6.4	(e) 5.1	(f) 33.3	(g) -2.4	(h) 6.3	(i) 36.3	(j) 39.0	(k) 41.0	(l) 35.6	(m) 38.9	(n) 13.0	(o) 300	(p) 0.711

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 25.5	(c) 88.5	(d) 56.3	(e) 86.3	(f) 56.1	(g) 84.0	(h) 56.0	(i) 61.8	(j) 77.0	(k) 60.8	(l) 76.1	(m) 59.9	(n) 75.2	(o) 12.6	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.3	91.7	63.7	56.4	88.6	63.7	55.1	84.5	63.7	31.0	77.4	30.3	75.8	29.6	75.2	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 34.8	(b) 31.3	(c) 27.2	(e) 1.1	(f) 92.7	(g) 5.5	(h) 2.4	(i) -2.9	(j) 94.4	(k) -6.1	(l) 95.8	(m) -9.2	(n) 97.1	(o) -13.2	(p) 98.9		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
					0.1	64.0	5.3	1.8	-3.7	65.4	-6.8	66.4	-9.8	67.5	-13.7	68.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.9	31.9	35.7	42.4	49.0	57.7	67.8	70.3	68.5	62.7	51.5	40.7	31.9
	DBStd	15.51	7.90	8.86	8.06	7.55	7.30	5.02	3.76	3.88	5.45	7.32	8.56	8.22
	HDD50	2274	561	403	254	107	22	0	0	0	2	71	292	562
	HDD65	5597	1025	822	702	482	241	29	6	14	102	418	730	1026
	CDD50	2604	0	2	17	76	260	533	630	574	382	118	12	0
	CDD65	451	0	0	0	0	14	112	171	123	31	0	0	0
	CDH74	5468	0	0	0	18	366	1640	1727	1221	473	23	0	0
	CDH80	1615	0	0	0	0	62	572	573	334	74	0	0	0
Wind	WSAvg	13.5	15.6	15.8	15.0	15.6	13.8	12.2	10.1	9.9	11.0	13.1	14.7	15.6
Precipitation	PrecAvg	17.0	0.7	0.7	0.9	0.8	1.4	1.4	2.8	3.0	1.8	1.4	0.8	1.0
	PrecMax	24.1	1.9	1.6	2.0	4.1	4.4	3.7	4.8	5.1	4.0	3.7	1.7	2.5
	PrecMin	13.3	0.1	0.2	0.2	0.0	0.3	0.3	0.7	1.3	0.2	0.2	0.0	0.1
	PrecStd	2.7	0.5	0.4	0.6	0.9	1.0	0.8	1.1	1.1	1.0	1.0	0.5	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.1	63.4	71.0	76.7	84.9	92.3	90.9	89.3	85.3	76.9	67.7	58.4
		MCWB	39.0	41.8	44.7	47.6	52.7	55.5	57.7	57.4	56.5	50.6	44.2	40.0
	2%	DB	53.1	59.3	66.4	72.4	81.5	89.1	88.3	86.4	82.1	73.2	63.8	53.7
		MCWB	37.6	40.1	43.0	45.9	51.1	54.4	57.5	57.7	55.2	49.8	43.1	37.9
	5%	DB	49.5	55.4	63.0	69.3	78.5	86.2	86.0	83.8	79.4	70.1	60.5	49.2
		MCWB	35.6	38.4	41.7	44.9	49.8	53.8	57.5	58.0	54.4	48.6	42.1	36.1
	10%	DB	45.4	51.0	59.1	66.0	74.8	83.4	83.4	81.2	76.6	66.4	55.4	45.1
		MCWB	33.6	36.4	39.9	43.7	48.4	53.3	58.0	58.3	54.1	47.3	39.6	34.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.4	43.8	46.6	50.8	56.4	61.1	63.2	63.0	60.3	57.1	47.1	42.2
		MCDB	53.4	59.6	64.5	66.3	73.3	77.9	78.2	77.7	72.9	66.9	60.9	53.0
	2%	WB	38.6	41.3	44.3	48.5	54.2	59.3	61.9	61.9	58.9	53.9	44.9	39.4
		MCDB	50.1	56.4	62.2	66.0	72.8	76.3	77.4	76.7	72.5	64.9	58.3	50.0
	5%	WB	36.4	39.2	42.6	46.4	52.4	58.0	61.0	60.9	57.5	51.4	43.0	37.1
		MCDB	46.9	52.8	59.8	64.4	71.1	75.3	76.7	75.8	71.4	63.4	57.1	47.7
	10%	WB	34.4	37.2	40.9	44.6	50.6	56.7	60.1	60.0	56.4	49.2	41.1	34.9
		MCDB	44.1	49.3	57.4	63.0	68.8	74.2	75.8	74.8	70.2	61.6	54.0	44.4
Mean Daily Temperature Range	5% DB	MDBR	20.7	22.7	26.0	27.5	27.4	28.7	25.5	24.3	24.8	24.7	23.5	20.0
		MCDBR	25.7	28.5	30.7	31.4	31.2	31.6	29.5	28.0	28.5	28.6	27.9	24.6
	5% WB	MCWBR	14.6	15.2	14.7	14.8	13.4	11.7	9.3	9.0	10.4	13.1	13.9	14.0
		MCWBR	23.3	26.0	28.5	29.4	27.9	27.1	24.3	23.6	23.9	23.7	25.0	22.2
Clear-Sky Solar Irradiance	taub		0.224	0.233	0.255	0.270	0.288	0.313	0.344	0.325	0.292	0.267	0.240	0.229
	taud		2.675	2.653	2.578	2.529	2.524	2.440	2.438	2.466	2.553	2.599	2.622	2.647
	Ebn at Noon		324	329	326	323	315	305	295	300	308	311	313	315
	Edh at Noon		22	25	30	33	33	36	36	34	30	26	23	21
All-Sky Solar Radiation	RadAvg		1046	1348	1769	2158	2396	2472	2196	2048	1810	1464	1130	916
	RadStd		76	107	121	120	124	127	112	93	90	124	73	54

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	+83

Nomenclature: See separate page