

CANNON AFB, NM, USA

WMO: 722686

Lat: 34.383N

Lon: 103.317W

Elev: 1309

StdP: 86.56

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23008

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.0	-7.6	-18.4	0.9	3.7	-16.5	1.0	4.2	14.9	8.4	13.5	10.8	4.4	20	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	37.1	17.3	35.4	17.4	34.0	17.7	21.7	26.6	20.9	26.7	20.3	26.8	6.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	18.3	22.4	19.8	17.1	21.6	18.9	16.1	21.4	69.9	26.8	66.7	26.1	64.2	26.4	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.6	11.8	10.5	DB	-14.0	39.4	3.3	1.7	-16.3	40.6	-18.2	41.6	-20.1	42.5	-22.4	43.7	
			WB	-14.3	23.2	3.2	1.6	-16.6	24.4	-18.5	25.3	-20.3	26.2	-22.7	27.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.0	4.0	6.5	10.2	14.2	19.1	24.4	25.8	25.1	21.7	15.1	9.2	4.6
	DBStd	8.89	5.12	5.37	4.97	4.66	4.21	2.89	2.29	2.24	3.48	4.60	4.91	5.13
	HDD10.0	648	193	119	58	17	1	0	0	0	0	13	71	176
	HDD18.3	2032	444	331	252	134	42	1	0	0	12	117	274	426
	CDD10.0	2488	7	21	66	143	283	431	491	468	351	172	47	8
	CDD18.3	829	0	0	1	10	64	182	232	211	113	17	0	0
	CDH23.3	9941	1	12	83	334	1007	2244	2582	2177	1183	291	27	1
	CDH26.7	4886	0	1	11	86	450	1222	1393	1119	525	77	1	0
Wind	WSAvg	5.1	5.3	5.6	5.7	6.0	5.5	5.1	4.3	4.1	4.3	4.8	5.0	5.2
Precipitation	PrecAvg	414	12	8	20	26	49	47	61	61	53	43	13	17
	PrecMax	705	35	32	73	115	265	112	216	158	140	175	38	84
	PrecMin	155	0	0	0	3	2	0	0	0	1	5	0	0
	PrecStd	127	13	9	17	26	53	33	44	35	33	47	12	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.9	25.0	28.2	31.4	36.0	39.7	38.5	37.2	35.9	31.2	26.1	21.9
		MCWB	8.2	9.9	11.0	12.4	14.8	16.5	17.6	18.0	17.1	15.0	11.0	8.5
	2%	DB	18.8	22.3	25.8	29.0	33.6	37.4	36.7	35.4	33.7	28.8	23.7	18.9
		MCWB	7.3	8.6	9.9	11.4	14.0	16.3	18.3	18.6	17.0	14.2	10.5	7.9
	5%	DB	16.2	19.8	23.6	27.3	31.6	35.4	35.1	34.0	32.0	27.0	21.1	16.5
		MCWB	6.0	7.7	9.4	11.1	13.5	16.1	18.7	18.7	17.0	13.7	9.7	6.6
	10%	DB	13.5	17.0	21.0	25.1	29.1	33.4	33.5	32.6	29.9	24.4	18.1	13.6
		MCWB	4.9	6.7	8.6	10.8	13.7	16.9	18.8	18.7	17.0	13.1	8.7	5.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	11.5	13.6	17.2	20.0	21.8	23.0	23.1	21.2	20.2	14.2	10.6
		MCDB	18.9	19.7	19.4	19.5	23.9	26.6	26.9	25.9	25.8	21.7	17.7	17.4
	2%	WB	7.9	9.8	11.7	14.9	18.3	20.6	21.6	21.8	20.1	17.8	12.6	8.9
		MCDB	17.1	19.4	20.4	19.5	24.4	26.8	27.4	26.2	25.3	21.7	17.9	16.6
	5%	WB	6.6	8.4	10.6	13.2	17.2	19.9	20.8	20.9	19.3	16.2	11.1	7.4
		MCDB	15.3	18.5	19.7	21.2	23.6	26.8	27.2	26.5	25.2	21.3	18.0	15.3
	10%	WB	5.2	7.1	9.5	12.0	16.1	19.1	20.2	20.2	18.6	14.8	9.8	6.0
		MCDB	12.8	16.0	19.4	22.0	23.4	26.7	27.4	26.9	24.9	21.0	17.1	12.9
Mean Daily Temperature Range	5% DB	MDBR	14.7	15.8	16.4	16.6	15.8	15.9	14.3	14.0	14.3	14.8	15.0	14.4
		MCDBR	18.7	19.8	20.2	19.7	19.2	19.1	16.7	16.2	16.9	18.1	18.7	18.2
		MCWBR	9.8	9.8	8.9	8.2	7.6	5.7	4.6	4.4	5.2	7.0	8.6	9.5
	5% WB	MCDBR	17.6	18.5	17.8	16.9	16.2	15.0	13.5	13.3	13.4	13.2	15.4	16.6
		MCWBR	9.7	9.5	8.7	8.6	7.5	5.5	4.6	4.7	4.9	6.8	8.0	9.2
Clear-Sky Solar Irradiance	taub	0.247	0.256	0.283	0.308	0.322	0.361	0.373	0.359	0.329	0.297	0.270	0.254	
	taud	2.604	2.594	2.513	2.437	2.456	2.382	2.396	2.416	2.472	2.540	2.549	2.579	
	Ebn at Noon	988	1010	997	978	960	918	904	914	933	944	947	957	
	Edh at Noon	74	84	99	113	113	121	119	114	103	88	78	72	
All-Sky Solar Radiation	RadAvg	3.35	4.23	5.49	6.80	7.46	7.81	7.36	6.70	5.72	4.50	3.52	2.90	
	RadStd	0.26	0.34	0.39	0.40	0.45	0.37	0.34	0.32	0.34	0.44	0.30	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	+63

Nomenclature: See separate page