

WHITE SANDS, NM, USA

WMO: 722690

Lat: 32.383N

Lon: 106.483W

Elev: 4081

StdP: 12.65

Time Zone: -7.00 (NAM)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	18.5	22.5	1.7	7.0	42.7	5.5	8.5	43.5	23.3	55.0	19.0	54.2	1.8	180	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.5	99.0	63.7	96.5	63.9	94.2	63.8	69.8	87.4	68.9	86.1	68.1	84.8	6.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	111.3	72.1	64.6	106.4	72.3	63.5	102.1	72.7	36.3	87.5	35.4	86.0	34.6	84.2	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	16.2	13.3	10.4	103.1	5.6	2.5	6.3	104.8	3.1	106.3	-0.1	107.7	-4.1	109.5
			8.9	73.1	5.1	1.6	5.2	74.2	2.2	75.1	-0.6	76.0	-4.4	77.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	41.9	47.7	54.5	62.7	70.7	78.3	80.3	78.4	72.6	62.7	50.1	42.0	
	DBStd	15.06	6.52	6.92	6.87	7.38	5.77	4.96	3.40	3.70	5.24	5.95	7.59	7.41	
	HDD50	773	259	112	34	9	0	0	0	0	0	4	93	262	
	HDD65	2948	717	486	329	121	16	0	0	0	7	110	448	714	
	CDD50	5111	8	46	174	389	643	849	938	880	678	397	96	13	
	CDD65	1811	0	0	4	52	194	399	473	415	236	37	1	0	
	CDH74	23032	0	19	171	939	2766	5625	5655	4441	2605	775	36	0	
	CDH80	11273	0	1	21	250	1185	3205	3071	2219	1120	198	3	0	
Wind	WSAvg	4.6	3.7	4.7	6.5	6.7	6.1	4.9	4.4	3.7	3.4	3.3	4.1	3.5	
Precipitation	PrecAvg	10.5	0.5	0.5	0.2	0.4	0.5	0.7	2.1	1.9	1.5	0.9	0.4	0.7	
	PrecMax	16.8	1.7	2.4	0.9	1.9	2.8	3.7	6.2	6.7	3.8	3.3	1.8	4.1	
	PrecMin	5.1	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.9	0.0	0.0	0.0	0.0	
	PrecStd	2.8	0.5	0.6	0.2	0.4	0.6	0.8	1.2	1.3	0.9	0.8	0.4	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.8	77.5	82.5	89.9	96.8	103.3	101.7	97.3	96.7	88.4	78.2	68.1	
		MCWB	46.7	51.7	53.3	57.1	59.4	65.0	65.3	67.1	65.7	57.6	53.9	47.8	
	2%	DB	64.1	70.9	78.7	85.9	92.9	100.1	98.4	95.1	92.4	85.2	73.9	63.9	
		MCWB	45.9	49.3	51.9	55.3	59.0	63.2	64.4	67.0	64.0	57.9	52.3	47.0	
	5%	DB	60.0	67.3	75.1	82.8	89.9	97.1	96.1	93.2	89.7	81.9	70.5	60.4	
		MCWB	44.2	47.1	50.4	54.4	57.9	62.1	64.8	66.6	63.7	57.4	50.9	45.4	
	10%	DB	56.7	63.8	71.6	79.7	86.8	94.1	93.5	91.0	86.7	78.6	66.8	57.1	
		MCWB	43.0	46.0	48.9	53.1	57.1	61.6	65.1	66.8	63.0	56.8	49.1	43.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	53.1	55.6	59.8	65.9	69.4	71.4	71.4	69.4	64.3	58.6	53.1
			MCDB	58.9	71.1	76.8	83.1	84.9	90.4	88.7	88.5	86.1	75.1	66.8	61.1
2%		WB	48.2	50.9	53.3	57.4	62.2	67.6	69.3	70.3	68.0	61.9	55.3	49.6	
		MCDB	58.4	67.6	75.2	80.6	83.9	87.3	87.1	87.4	83.7	74.2	66.7	56.9	
5%		WB	46.3	48.9	51.4	55.6	60.5	66.2	68.3	69.3	66.7	60.0	53.2	47.7	
		MCDB	56.9	64.1	73.0	77.6	82.1	86.1	86.2	86.3	81.6	74.2	66.5	57.0	
10%		WB	44.2	46.9	49.6	54.1	59.2	64.8	67.5	68.4	65.6	58.5	50.9	45.3	
		MCDB	55.3	61.8	69.5	76.5	80.2	85.0	85.4	84.4	80.0	73.6	64.8	55.5	
Mean Daily Temperature Range		5% DB	MDBR	26.9	28.1	29.4	29.6	29.3	30.4	26.5	24.6	26.6	28.9	27.8	25.7
			MCDBR	32.9	34.6	35.5	34.4	32.9	34.4	30.3	28.0	30.3	35.4	32.6	32.1
	MCWBR		19.2	18.4	17.5	15.5	13.9	13.2	10.7	8.7	10.9	15.2	16.5	18.7	
	5% WB	MCDBR	28.0	29.8	32.7	32.2	29.7	28.3	26.0	24.2	24.2	27.8	27.3	25.5	
		MCWBR	17.3	16.2	16.7	14.9	12.3	10.4	8.7	7.6	8.9	12.4	14.5	16.1	
Clear-Sky Solar Irradiance	taub		0.244	0.250	0.267	0.296	0.315	0.333	0.369	0.348	0.322	0.278	0.258	0.247	
	taud		2.651	2.633	2.550	2.436	2.433	2.416	2.396	2.436	2.477	2.609	2.607	2.635	
	Ebn at Noon		319	325	324	315	307	300	289	294	300	310	310	312	
	Edh at Noon		23	26	31	36	37	37	38	36	33	27	24	23	
All-Sky Solar Radiation	RadAvg		1133	1449	1874	2293	2516	2523	2264	2095	1864	1548	1216	1023	
	RadStd		76	109	98	93	81	104	107	76	82	114	74	55	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+223	N/A

Nomenclature: See separate page