

LAS CRUCES, NM, USA

WMO: 722695

Lat: 32.283N

Lon: 106.917W

Elev: 4454

StdP: 12.48

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 93041

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.0	26.8	-8.5	4.1	51.0	-3.6	5.3	48.6	30.4	50.9	26.3	51.5	3.8	320	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	29.0	99.7	61.6	97.8	61.5	95.4	61.5	71.0	80.8	69.5	80.5	68.2	79.9	8.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	128.8	74.3	66.2	114.1	72.8	64.3	106.8	72.9	38.0	81.4	36.7	82.3	35.2	79.5	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.6	18.8	DB	15.3	104.2	4.6	1.9	12.0	105.5	9.3	106.7	6.7	107.7	3.4	109.1
			WB	12.5	70.8	4.7	2.5	9.1	72.6	6.4	74.1	3.7	75.5	0.3	77.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	44.2	48.3	55.6	62.6	70.3	80.8	81.6	79.6	73.9	63.8	52.0	43.9
	DBStd	14.85	6.16	7.26	6.82	6.09	6.17	4.27	3.94	3.72	4.48	6.59	7.07	6.69
	HDD50	600	194	105	27	2	0	0	0	0	0	4	58	210
	HDD65	2692	644	468	297	113	23	0	0	0	2	100	390	655
	CDD50	5389	15	57	200	378	630	923	980	919	718	431	118	20
	CDD65	2009	0	0	5	40	188	473	515	454	270	63	1	0
	CDH74	25921	0	20	231	895	2872	6690	6316	5179	2833	833	52	0
	CDH80	12990	0	0	26	204	1290	3920	3475	2649	1205	219	2	0
(14) Wind	WSAvg	7.6	6.8	8.2	9.0	10.4	9.3	8.5	6.8	6.1	6.1	6.5	6.5	6.7
(15) Precipitation	PrecAvg	9.2	0.4	0.4	0.2	0.3	0.4	0.7	1.9	1.7	1.3	0.8	0.4	0.6
	PrecMax	15.2	1.7	2.3	0.9	1.9	2.2	4.1	5.3	5.7	3.9	3.0	1.6	2.9
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.6	0.0	0.0	0.0	0.0
	PrecStd	2.6	0.5	0.6	0.2	0.4	0.6	0.9	1.1	1.3	1.0	0.7	0.4	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.8	77.1	82.8	88.3	97.6	102.7	102.0	99.4	95.0	88.3	79.2	70.3
		MCWB	46.1	48.7	51.8	53.4	58.1	60.8	62.9	64.1	61.8	60.3	51.7	48.0
	2%	DB	65.5	72.3	79.7	84.3	93.3	100.2	99.4	97.1	92.2	85.1	74.9	65.6
		MCWB	45.3	47.3	50.0	52.4	56.3	60.3	63.8	63.5	61.7	57.6	51.3	47.0
	5%	DB	62.6	68.3	76.6	82.0	90.5	98.7	97.3	94.7	90.1	82.1	71.9	62.5
		MCWB	43.6	46.0	48.8	51.2	55.3	59.9	63.4	63.9	61.2	56.4	50.3	45.2
	10%	DB	58.6	63.9	72.8	80.1	87.7	96.3	94.6	91.5	87.7	79.2	67.1	57.3
		MCWB	41.9	44.0	47.6	50.6	54.5	59.4	63.5	64.4	61.0	55.5	48.5	43.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	53.2	55.3	59.0	64.4	67.6	72.4	73.2	70.1	67.3	57.1	52.4
		MCDB	60.5	65.9	72.6	72.9	77.5	86.7	80.7	80.5	79.3	76.1	66.2	61.3
	2%	WB	47.9	50.3	52.6	55.3	61.0	65.7	70.4	71.8	68.0	64.3	54.5	49.2
		MCDB	59.2	66.6	73.0	76.6	76.6	84.5	80.1	81.5	77.0	75.1	65.9	60.8
	5%	WB	45.5	48.0	50.5	53.4	58.9	64.3	69.2	70.2	66.7	61.6	52.4	47.1
		MCDB	58.5	65.4	72.0	76.2	79.6	84.8	80.6	81.1	76.0	71.8	66.0	58.9
	10%	WB	43.2	45.9	48.8	51.7	56.8	63.1	68.0	68.7	65.5	59.1	50.3	44.9
		MCDB	56.1	63.5	70.7	76.6	79.9	85.5	80.5	80.2	75.5	71.9	65.8	55.9
(35) Mean Daily Temperature Range	5% DB	MDBR	25.4	27.1	28.7	29.8	30.0	29.0	24.3	23.7	24.3	26.5	26.8	24.4
		MCDBR	30.6	32.9	33.9	32.8	33.0	31.8	27.6	27.2	28.4	29.8	31.3	29.0
		MCWBR	16.3	16.2	16.0	14.7	13.9	11.5	7.5	6.8	8.7	12.6	14.6	14.7
	5% WB	MCDBR	25.5	29.5	30.5	30.7	28.1	26.0	21.0	20.1	20.4	22.5	26.5	23.9
		MCWBR	14.4	14.7	14.4	13.4	11.4	8.7	6.2	6.2	7.1	10.6	13.4	12.6
(40) Clear-Sky Solar Irradiance	taub		0.240	0.245	0.261	0.284	0.304	0.325	0.362	0.342	0.314	0.272	0.252	0.242
	taud		2.676	2.663	2.578	2.474	2.466	2.432	2.415	2.453	2.511	2.637	2.643	2.663
	Ebn at Noon		321	328	326	319	311	303	291	297	303	312	313	315
	Edh at Noon		23	25	30	35	36	36	37	35	32	26	23	22
(44) All-Sky Solar Radiation	RadAvg		1143	1464	1896	2316	2538	2538	2271	2103	1871	1561	1233	1039
	RadStd		81	113	102	94	84	108	104	73	84	115	72	55

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-164	+259	+148

Nomenclature: See separate page