

EL PASO, TX, USA

WMO: 722700

Lat: 31.811N

Lon: 106.376W

Elev: 1194

StdP: 87.78

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23044

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.5	-1.8	-19.2	0.8	11.2	-17.1	1.0	11.7	14.7	13.4	12.6	11.5	2.2	10	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.8	38.5	17.6	37.3	17.4	36.1	17.4	21.0	29.8	20.5	29.4	20.1	29.2	4.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.0	23.1	18.3	15.2	23.3	17.5	14.5	23.8	66.5	29.7	64.7	29.2	62.9	28.9	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	10.8	9.0	DB	-7.4	40.9	2.9	1.4	-9.5	41.9	-11.2	42.7	-12.9	43.4	-15.0	44.4	(4)
(5)			WB	-9.3	21.9	2.7	0.7	-11.3	22.3	-12.9	22.7	-14.4	23.1	-16.4	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	8.1	10.8	14.9	19.1	24.1	28.8	28.9	28.0	24.9	19.3	12.6	7.9
	DBStd	8.42	3.63	4.21	4.11	3.93	3.33	2.74	2.37	2.31	2.75	3.88	3.96	3.92
	HDD10.0	234	81	35	8	1	0	0	0	0	0	2	20	88
	HDD18.3	1224	318	211	119	38	3	0	0	0	1	36	174	323
	CDD10.0	3514	21	59	161	273	438	566	585	557	447	288	98	23
	CDD18.3	1462	0	1	12	61	183	316	327	299	197	64	2	0
	CDH23.3	18571	1	21	201	762	2352	4551	4222	3646	2101	672	43	0
	CDH26.7	9566	0	1	29	228	1128	2729	2376	1931	943	200	2	0
Wind	WSAvg	3.8	3.4	4.0	4.4	5.0	4.6	4.1	3.6	3.3	3.2	3.3	3.3	3.4
Precipitation	PrecAvg	222	10	11	7	5	8	19	37	40	37	17	11	17
	PrecMax	411	34	49	25	36	107	81	140	142	170	79	51	84
	PrecMin	107	0	0	0	0	0	0	1	0	0	0	0	0
	PrecStd	75	9	11	7	8	17	23	29	32	36	18	12	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.6	25.8	29.3	32.9	37.1	40.9	39.8	38.4	35.9	32.3	26.6	21.9
		MCWB	9.1	10.1	11.4	13.7	16.2	17.2	18.3	18.9	17.7	16.1	12.3	9.7
	2%	DB	19.7	23.4	27.3	30.7	35.2	39.0	38.0	36.9	34.3	30.5	24.7	19.7
		MCWB	8.2	9.5	10.8	12.5	15.0	16.8	18.2	18.6	17.7	15.2	11.8	9.0
	5%	DB	17.8	21.5	25.7	29.3	33.8	37.7	36.8	35.6	33.0	29.0	22.8	17.8
		MCWB	7.5	8.7	10.3	12.0	14.6	16.6	18.3	18.8	17.3	14.6	11.2	8.0
	10%	DB	16.0	19.5	23.9	27.8	32.2	36.4	35.4	34.3	31.7	27.3	20.8	15.7
		MCWB	6.6	8.0	9.7	11.5	13.8	16.3	18.4	18.7	17.3	14.1	10.2	7.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.8	12.0	13.4	15.8	18.6	21.0	21.9	21.7	20.9	19.6	14.6	11.4
		MCDB	17.4	20.5	24.4	27.7	31.8	33.4	30.4	30.4	28.8	25.7	21.5	17.6
	2%	WB	9.5	10.7	12.1	14.2	17.2	20.0	21.1	20.8	20.2	17.9	13.3	10.1
		MCDB	16.9	19.6	23.5	26.7	30.6	31.6	29.6	29.6	28.1	25.2	20.7	17.2
	5%	WB	8.3	9.8	11.2	13.2	16.2	19.1	20.6	20.5	19.6	16.7	12.2	8.8
		MCDB	16.1	19.2	22.7	25.8	28.9	30.7	29.2	29.4	27.5	25.0	20.3	16.4
	10%	WB	7.2	8.7	10.3	12.2	15.4	18.4	20.2	20.1	19.0	15.6	11.1	7.7
		MCDB	15.1	18.1	21.9	25.2	27.8	30.4	29.0	29.3	27.0	24.1	19.4	14.8
Mean Daily Temperature Range	5% DB	MDBR	13.2	13.7	14.3	14.3	14.1	13.8	12.1	11.8	12.1	13.3	13.5	12.6
		MCDBR	15.9	16.6	16.4	15.8	15.5	15.0	13.4	13.1	13.7	14.9	15.9	15.1
		MCWBR	8.3	8.0	7.2	6.8	6.4	5.1	3.8	3.4	4.5	5.9	7.6	7.9
	5% WB	MCDBR	13.8	14.3	14.9	15.1	14.8	13.6	11.7	11.5	11.2	12.2	13.4	12.7
		MCWBR	7.7	7.2	6.9	7.1	6.3	4.7	3.2	3.2	3.7	5.1	6.8	6.9
Clear-Sky Solar Irradiance	taub	0.245	0.250	0.264	0.296	0.317	0.335	0.371	0.348	0.325	0.278	0.259	0.247	
	taud	2.656	2.637	2.566	2.432	2.423	2.412	2.382	2.440	2.468	2.621	2.608	2.638	
	Ebn at Noon	1008	1028	1026	994	968	945	909	930	944	979	978	987	
	Edh at Noon	73	83	96	115	117	118	121	113	105	83	76	71	
All-Sky Solar Radiation	RadAvg	3.67	4.68	6.03	7.30	8.00	7.99	7.17	6.66	5.93	4.98	3.94	3.34	
	RadStd	0.26	0.33	0.33	0.33	0.28	0.32	0.32	0.25	0.25	0.35	0.24	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.57	+0.56	N/A	+0.61	N/A	N/A	N/A	-98	+195	+109
(47) Regional (9 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-91	+144	+82

Nomenclature: See separate page