

TRUTH OR CONSEQUENCES, NM, USA

WMO: 722710

Lat: 33.237N

Lon: 107.268W

Elev: 1478

StdP: 84.78

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 93045

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.5	-3.6	-21.4	0.7	9.4	-19.4	0.8	8.9	12.6	9.1	11.1	8.4	2.9	310	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	37.0	16.3	35.7	16.0	34.3	15.9	19.5	28.3	19.0	27.9	18.5	27.6	4.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	15.0	20.8	16.9	14.5	21.2	16.0	13.7	21.8	61.7	28.0	60.0	27.4	58.4	27.2	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.5	9.9	8.5	DB	-8.9	39.3	2.8	1.2	-11.0	40.2	-12.6	40.8	-14.2	41.5	-16.3	42.4	
			WB	-10.7	20.4	2.6	0.9	-12.6	21.1	-14.1	21.6	-15.6	22.1	-17.5	22.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	6.0	8.6	12.5	16.2	21.2	26.4	26.9	25.8	22.6	16.9	10.3	5.6
	DBStd	8.39	3.56	4.15	3.99	3.78	3.49	2.73	2.29	2.17	2.71	3.87	4.04	3.86
	HDD10.0	417	131	68	22	3	0	0	0	0	0	4	44	144
	HDD18.3	1649	382	273	184	83	14	0	0	0	3	72	241	396
	CDD10.0	2830	6	28	99	188	348	492	525	488	378	217	53	7
	CDD18.3	1022	0	0	2	18	103	242	267	230	132	27	0	0
	CDH23.3	12132	0	4	66	333	1346	3208	3091	2432	1321	323	8	0
	CDH26.7	5795	0	0	6	67	554	1791	1626	1163	518	71	0	0
(14) Wind	WSAvg	3.7	3.2	3.8	4.2	4.6	4.5	4.1	3.4	3.2	3.2	3.4	3.3	3.1
(15) Precipitation	PrecAvg	238	8	6	5	4	6	18	40	41	53	28	9	15
	PrecMax	372	22	26	20	26	26	73	87	119	130	143	49	42
	PrecMin	130	0	0	0	0	0	0	8	2	6	0	0	0
	PrecStd	80	7	8	5	6	7	21	23	31	32	38	13	13
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.2	23.8	27.5	30.7	35.5	39.0	38.0	36.7	34.1	30.7	24.5	19.9
		MCWB	7.5	8.6	10.5	12.0	14.6	16.4	17.2	17.2	16.4	14.0	10.3	8.1
	2%	DB	17.5	21.2	25.2	28.6	33.2	37.3	36.7	35.2	32.6	28.6	22.5	17.3
		MCWB	6.5	7.9	9.3	10.8	13.4	15.8	16.9	17.2	15.9	13.4	9.9	7.2
	5%	DB	15.5	19.0	23.2	27.1	31.7	36.0	35.3	33.8	31.4	27.0	20.5	14.9
		MCWB	5.7	7.0	8.6	10.5	12.9	15.1	16.7	17.2	15.7	12.8	8.9	5.9
	10%	DB	13.3	16.9	21.3	25.3	29.9	34.5	33.8	32.4	29.9	25.0	18.2	12.7
		MCWB	4.7	6.1	8.0	9.5	12.1	14.6	17.0	17.2	15.5	12.1	8.0	4.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.3	10.1	11.5	13.4	16.5	19.7	20.4	20.1	18.9	17.6	12.2	9.3
		MCDB	17.0	19.4	23.4	26.9	31.9	33.9	30.0	27.5	26.2	22.5	19.8	16.7
	2%	WB	7.5	8.8	10.2	12.2	15.1	18.1	19.6	19.3	18.1	15.6	10.9	8.0
		MCDB	15.6	18.8	22.5	25.2	29.3	30.5	28.3	27.8	25.6	23.9	18.5	15.4
	5%	WB	6.3	7.8	9.3	11.1	14.1	17.3	19.1	18.9	17.6	14.4	9.9	6.7
		MCDB	14.1	17.0	21.2	24.2	27.5	29.7	27.8	27.7	25.5	23.0	18.2	13.6
	10%	WB	5.2	6.7	8.4	10.2	13.2	16.5	18.6	18.5	17.0	13.4	8.8	5.5
		MCDB	12.4	15.9	20.0	23.5	26.4	29.5	27.5	27.6	25.3	21.8	17.4	11.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	14.1	14.9	15.4	15.2	15.2	13.1	12.8	13.2	13.8	13.6	12.7
		MCDBR	16.2	16.6	17.0	17.0	16.6	16.3	14.8	14.3	15.0	15.6	16.1	14.8
		MCWBR	8.7	8.4	8.0	7.8	7.3	6.6	4.6	4.3	5.3	6.8	8.1	8.0
	5% WB	MCDBR	14.7	14.9	15.8	16.1	15.6	14.6	12.4	12.4	12.0	13.2	14.0	13.4
		MCWBR	8.3	7.6	7.7	7.8	7.2	5.9	3.7	3.7	4.4	6.1	7.5	7.6
(40) Clear-Sky Solar Irradiance	taub		0.238	0.242	0.261	0.282	0.300	0.323	0.365	0.342	0.312	0.272	0.249	0.239
	taud		2.701	2.696	2.602	2.517	2.516	2.456	2.441	2.477	2.553	2.654	2.674	2.690
	Ebn at Noon		1012	1034	1026	1007	984	955	914	933	955	982	988	992
	Edh at Noon		69	77	92	105	106	113	114	108	95	79	70	66
(44) All-Sky Solar Radiation	RadAvg		3.52	4.54	5.89	7.20	7.85	7.79	6.82	6.36	5.76	4.84	3.82	3.19
	RadStd		0.27	0.38	0.33	0.33	0.39	0.47	0.38	0.23	0.27	0.39	0.22	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-112	+168	+96
Regional (11 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-89	+146	+83

Nomenclature: See separate page