

DEMING, NM, USA

WMO: 722725

Lat: 32.262N

Lon: 107.721W

Elev: 1311

StdP: 86.54

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 23078

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -6.9	(c) -4.9	(d) -20.8	(e) 0.7	(f) 8.2	(g) -18.5	(h) 0.9	(i) 8.3	(j) 12.9	(k) 9.4	(l) 11.7	(m) 10.2	(n) 1.8	(o) 310	(p) 0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	37.8	16.9	36.9	16.8	35.6	16.6	20.2	28.5	19.8	28.3	19.3	28.1	4.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	15.6	21.5	17.8	15.0	21.5	17.2	14.4	21.8	63.8	27.9	62.2	27.9	60.6	28.0	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.8	(b) 10.4	(c) 8.8	(e) -10.8	(f) 40.2	(g) 2.4	(h) 0.8	(i) -12.5	(j) 40.7	(k) -13.9	(l) 41.2	(m) -15.2	(n) 41.6	(o) -17.0	(p) 42.2		
(4) 11.8	(5) 10.4	(6) 8.8	(7) -12.2	(8) 21.2	(9) 2.3	(10) 0.5	(11) -13.9	(12) 21.6	(13) -15.2	(14) 21.9	(15) -16.5	(16) 22.2	(17) -18.2	(18) 22.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	5.8	8.2	12.2	16.1	20.6	26.4	27.3	26.1	22.8	17.0	10.4	5.9		
	DBStd	8.34	3.20	3.78	3.57	3.22	3.23	2.37	2.12	2.04	2.49	3.48	3.83	3.54		
	HDD10.0	402	133	71	20	1	0	0	0	0	2	41	134			
	HDD18.3	1651	388	284	191	79	16	0	0	0	2	65	239	387		
	CDD10.0	2811	3	19	88	184	328	491	537	499	385	219	52	6		
	CDD18.3	1017	0	0	1	12	84	241	278	241	136	24	0	0		
	CDH23.3	14201	0	11	123	493	1607	3664	3421	2759	1618	476	30	0		
	CDH26.7	7354	0	0	13	116	738	2216	1948	1459	733	130	1	0		
(14) Wind	WSAvg	3.8	3.6	4.1	4.4	4.9	4.5	4.1	3.6	3.2	3.3	3.4	3.4	3.5		
(15) Precipitation	PrecAvg	225	15	10	8	3	4	7	49	41	34	21	11	20		
	PrecMax	352	32	37	51	16	17	26	160	98	88	74	56	49		
	PrecMin	125	0	0	0	0	0	0	9	4	0	0	0	0		
	PrecStd	74	11	10	12	5	6	8	36	25	26	22	15	16		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.7	25.1	28.2	31.3	36.2	39.7	38.9	37.7	35.6	31.6	26.2	21.3		
		MCWB	8.1	9.7	11.0	12.2	15.4	15.8	17.7	17.9	16.7	15.1	11.3	8.8		
	2%	DB	18.4	22.5	26.3	29.3	34.1	38.3	37.6	36.4	33.8	29.8	24.0	18.8		
		MCWB	7.2	8.5	10.0	11.3	13.8	15.9	17.7	18.0	16.5	14.3	10.9	8.1		
	5%	DB	16.6	20.2	24.6	27.9	32.5	37.2	36.4	35.0	32.6	28.0	22.2	16.7		
		MCWB	6.6	7.7	9.4	11.0	13.3	15.9	17.7	17.9	16.3	13.7	10.2	7.1		
	10%	DB	14.5	17.8	22.6	26.5	31.0	35.9	35.0	33.4	31.2	26.2	19.7	14.1		
		MCWB	5.7	6.9	8.7	10.4	12.7	15.4	17.6	18.0	16.1	13.1	9.2	6.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	11.2	12.3	14.1	16.7	19.3	20.8	20.8	19.9	18.3	13.7	10.7		
		MCDB	15.5	19.2	23.8	26.6	31.4	31.9	28.5	29.2	26.5	23.8	20.4	17.6		
	2%	WB	8.7	9.9	10.9	12.8	15.6	18.5	20.3	20.2	19.2	16.8	12.3	9.2		
		MCDB	15.1	18.8	23.2	26.0	29.2	31.4	28.4	28.8	26.1	24.5	20.0	16.3		
	5%	WB	7.5	8.9	10.0	11.8	14.8	17.8	19.9	19.8	18.6	15.6	11.2	7.9		
		MCDB	15.0	17.7	22.5	25.3	28.2	30.9	28.3	28.5	25.7	24.0	19.8	14.9		
	10%	WB	6.3	7.6	9.1	10.8	13.7	17.0	19.4	19.4	18.0	14.6	10.0	6.7		
		MCDB	13.7	16.9	21.3	24.7	27.6	30.7	28.2	28.1	25.6	22.7	18.9	13.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.8	16.8	17.8	18.3	18.5	18.2	14.4	14.2	15.1	16.2	16.4	15.4		
		MCDBR	19.6	21.1	21.1	20.5	20.3	19.7	16.7	16.4	17.6	18.7	19.6	18.8		
	5% WB	MCWBR	11.0	10.8	9.9	9.4	8.9	7.6	4.9	4.5	6.2	8.0	9.9	10.2		
		MCWBR	16.3	17.6	19.0	18.5	17.8	16.5	13.5	13.4	12.9	14.4	16.5	15.9		
(40) Clear-Sky Solar Irradiance	taub		0.242	0.246	0.262	0.287	0.306	0.330	0.374	0.353	0.321	0.275	0.252	0.243		
		taud	2.681	2.670	2.583	2.475	2.467	2.412	2.396	2.427	2.511	2.633	2.653	2.663		
	Ebn at Noon		1010	1031	1027	1003	978	949	906	924	947	982	987	990		
		Edh at Noon	71	80	94	110	112	118	119	114	100	82	73	69		
(44) All-Sky Solar Radiation	RadAvg		3.62	4.64	6.05	7.39	8.09	8.05	7.14	6.63	5.91	4.97	3.94	3.32		
	RadStd		0.28	0.38	0.34	0.29	0.28	0.38	0.32	0.21	0.28	0.37	0.22	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47) Regional (10 neighbors)		+0.30	N/A	N/A	N/A	N/A	N/A	N/A	-75	+90	N/A

Nomenclature: See separate page