

SAFFORD, AZ, USA

WMO: 722747

Lat: 32.855N

Lon: 109.635W

Elev: 3176

StdP: 13.09

Time Zone: -7.00 (W07)

Period: 94-19

WBAN: 93084

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	26.5	29.3	-3.4	5.1	57.3	0.4	6.3	51.3	26.5	50.2	23.7	51.6	3.7	110	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.6	105.5	64.8	102.6	64.4	100.2	64.3	70.9	87.7	70.0	87.1	69.2	86.6	13.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	113.7	73.5	66.1	108.2	74.0	64.4	102.0	75.6	36.6	86.9	35.9	86.5	35.1	86.0	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.9	18.5	19.7	109.0	4.3	1.4	16.6	110.0	14.1	110.9	11.7	111.7	8.6	112.7
			16.3	72.8	4.4	1.8	13.1	74.0	10.5	75.1	8.0	76.1	4.8	77.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.7	47.5	51.4	58.0	64.9	73.7	84.2	86.1	84.2	79.1	67.8	56.1	47.1	(6)
	DBStd	15.23	5.82	6.86	6.17	6.58	6.29	5.12	4.37	4.12	4.52	6.34	7.06	5.79	(7)
	HDD50	336	115	56	11	1	0	0	0	0	0	1	26	126	(8)
	HDD65	2114	542	381	226	81	9	0	0	0	0	43	276	556	(9)
	CDD50	6448	37	95	258	449	734	1025	1120	1060	873	554	208	35	(10)
	CDD65	2751	0	0	8	78	278	575	655	595	423	131	8	0	(11)
	CDH74	39154	0	44	424	1560	4420	8979	9033	7723	5075	1721	175	0	(12)
	CDH80	22198	0	3	76	578	2376	5769	5541	4504	2676	653	22	0	(13)
(14) Wind	WSAvg	7.8	6.8	7.3	8.0	9.0	8.8	8.9	9.0	7.8	7.0	7.0	6.8	6.7	(14)
(15) Precipitation	PrecAvg	9.4	0.7	0.7	0.6	0.2	0.2	0.3	1.5	1.7	1.1	0.9	0.6	0.9	(15)
	PrecMax	17.4	3.1	2.6	1.7	1.4	2.3	1.4	3.6	4.4	4.2	4.4	2.4	4.7	(16)
	PrecMin	4.7	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0	(17)
	PrecStd	2.8	0.7	0.7	0.5	0.3	0.4	0.4	0.8	1.1	1.1	1.0	0.6	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	79.2	86.0	93.1	102.1	108.6	108.1	105.2	100.2	93.3	82.5	71.5	(19)
		MCWB	48.8	51.4	54.3	57.0	61.9	64.9	66.2	66.5	64.6	61.1	54.5	49.7	(20)
	2%	DB	67.9	74.5	81.8	89.6	98.2	105.7	105.5	102.2	98.3	90.1	79.1	67.7	(21)
		MCWB	47.1	49.7	52.8	55.5	60.1	63.5	65.9	66.5	63.9	59.7	53.8	48.3	(22)
	5%	DB	64.4	71.1	79.1	86.5	94.9	103.0	102.2	99.6	95.4	87.1	75.2	63.7	(23)
		MCWB	46.0	48.3	51.6	54.4	58.5	62.5	65.9	66.6	63.6	58.5	52.2	46.5	(24)
	10%	DB	61.4	66.7	75.3	83.1	91.9	100.4	99.5	97.2	92.8	83.6	71.7	60.4	(25)
		MCWB	44.7	47.0	50.1	53.6	57.5	62.2	65.8	66.5	63.4	57.6	50.9	45.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.9	54.5	57.1	60.4	65.1	69.6	72.2	72.4	70.3	66.4	58.8	53.8	(27)
		MCDB	61.2	69.3	77.4	86.9	96.2	95.4	88.1	88.5	84.7	79.8	72.0	62.9	(28)
	2%	WB	50.2	52.3	54.7	57.9	62.3	67.8	70.9	71.0	68.9	63.6	56.3	50.9	(29)
		MCDB	62.0	67.0	76.3	84.2	92.6	93.1	87.3	88.1	83.8	79.9	72.3	62.0	(30)
	5%	WB	48.2	50.6	52.9	55.8	60.4	66.3	70.1	70.1	67.8	61.6	54.1	48.7	(31)
		MCDB	60.6	65.7	74.5	82.1	90.1	92.4	86.5	87.5	83.1	79.3	70.9	60.1	(32)
	10%	WB	46.2	48.6	51.2	54.0	58.7	64.8	69.3	69.3	66.6	59.8	52.1	46.6	(33)
		MCDB	58.5	63.8	72.3	80.3	88.0	92.5	86.0	87.0	82.9	77.1	68.8	58.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	25.9	27.8	30.7	32.3	32.8	31.9	25.6	25.1	26.3	28.8	27.6	25.0	(35)
		MCDBR	30.7	34.5	35.9	36.7	35.9	34.1	29.6	27.9	29.5	32.6	32.1	29.7	(36)
	5% WB	MCWBR	16.6	17.4	16.8	17.2	16.0	13.4	9.1	7.6	10.0	13.8	15.9	16.0	(37)
		MCWBR	25.3	28.8	32.2	33.6	33.9	29.1	23.9	23.9	22.3	25.0	27.3	25.3	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.256	0.260	0.282	0.299	0.318	0.336	0.389	0.372	0.333	0.290	0.265	0.255	(40)
		taud	2.668	2.667	2.571	2.500	2.484	2.440	2.417	2.432	2.533	2.618	2.646	2.665	(41)
	Ebn at Noon	Ebn at Noon	313	321	318	314	306	299	283	287	296	305	307	308	(42)
		Edh at Noon	23	25	30	34	35	36	37	36	31	26	23	22	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1100	1395	1872	2304	2559	2568	2157	2023	1846	1564	1228	1008	(44)
	RadStd	RadStd	91	128	105	94	121	146	115	67	94	118	67	52	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page