

EL CENTRO NAF, CA, USA

WMO: 722810

Lat: 32.817N

Lon: 115.683W

Elev: -42

StdP: 14.72

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 23199

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	35.5	38.5	3.6	6.6	57.7	7.8	8.2	61.0	31.5	62.4	27.2	64.4	5.0	260	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	27.1	111.9	70.7	109.6	70.5	107.6	70.3	78.9	95.1	77.8	94.9	76.8	94.8	7.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	131.7	86.4	73.3	123.7	86.7	71.2	114.9	88.0	42.3	94.6	41.2	94.4	40.0	94.9	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.3	25.9	22.3	DB	30.1	117.0	3.6	1.8	27.5	118.3	25.4	119.3	23.4	120.3	20.8	121.6	(4)
(5)			WB	24.6	81.1	2.9	1.2	22.5	81.9	20.8	82.6	19.2	83.3	17.1	84.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	74.5	56.7	60.5	67.2	72.5	78.1	87.5	93.2	93.4	87.5	75.8	65.2	55.4	(6)
(7)		DBStd	14.28	5.47	5.70	6.19	6.06	6.26	5.20	3.48	3.64	5.76	5.72	6.11	5.08	(7)
(8)		HDD50	29	14	3	0	0	0	0	0	0	0	0	1	11	(8)
(9)		HDD65	842	260	143	50	10	1	0	0	0	0	4	74	300	(9)
(10)		CDD50	8962	221	297	533	675	870	1124	1340	1345	1125	798	456	178	(10)
(11)		CDD65	4302	2	17	119	235	406	674	875	880	675	338	79	2	(11)
(12)		CDH74	66996	136	473	1770	3190	5695	10746	14658	14686	10258	4211	1106	67	(12)
(13)		CDH80	43102	8	101	712	1563	3328	7302	10350	10387	6725	2226	398	2	(13)
(14)	Wind	WSAvg	7.9	5.9	7.6	8.9	10.8	11.0	9.1	7.7	6.9	7.1	7.4	6.4	6.3	(14)
(15)	Precipitation	PrecAvg	2.5	0.5	0.5	0.3	0.1	0.0	0.0	0.1	0.2	0.2	0.2	0.2	0.4	(15)
(16)		PrecMax	5.9	3.5	2.5	1.9	0.6	0.6	0.2	0.9	0.9	1.4	1.1	1.0	1.3	(16)
(17)		PrecMin	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.7	0.8	0.6	0.4	0.1	0.1	0.0	0.2	0.3	0.3	0.4	0.3	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.8	86.6	94.5	100.4	106.8	115.3	114.3	114.1	110.6	101.6	91.4	79.4	(19)
(20)			MCWB	54.4	57.5	60.4	62.9	64.7	68.3	70.8	71.0	69.9	65.0	60.7	57.2	(20)
(21)		2%	DB	77.8	83.1	90.7	96.1	102.4	110.7	111.3	111.6	107.6	97.4	88.4	75.8	(21)
(22)			MCWB	53.7	56.6	59.4	61.7	64.0	68.0	71.6	71.3	69.5	63.6	59.2	54.4	(22)
(23)		5%	DB	74.8	80.0	87.5	92.5	99.2	107.6	109.1	109.3	105.5	94.7	85.0	72.3	(23)
(24)			MCWB	52.4	56.1	57.9	60.2	63.6	67.6	71.5	71.4	69.4	62.8	58.4	52.7	(24)
(25)		10%	DB	71.5	76.3	84.0	89.0	95.6	104.4	106.9	106.9	102.7	91.7	80.9	68.7	(25)
(26)			MCWB	52.3	54.5	57.2	59.4	62.6	67.3	71.4	71.6	69.4	62.4	57.2	51.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.9	62.0	62.8	66.4	69.2	76.4	79.6	79.7	72.8	63.9	61.3	(27)	
(28)			MCDWB	70.8	79.9	88.4	92.1	95.8	97.8	97.1	95.0	93.8	85.9	82.3	73.9	(28)
(29)		2%	WB	57.3	59.0	61.1	63.9	67.2	74.5	78.5	79.4	77.5	69.9	61.4	58.4	(29)
(30)			MCDWB	68.6	77.3	86.1	89.7	94.7	97.5	96.4	94.5	93.2	86.6	82.4	69.0	(30)
(31)		5%	WB	55.4	57.0	59.6	62.1	65.4	72.3	77.5	78.1	75.7	66.9	59.8	55.9	(31)
(32)			MCDWB	67.8	75.8	83.7	88.6	93.4	97.3	95.7	94.4	92.9	88.1	81.1	66.5	(32)
(33)		10%	WB	53.5	55.4	58.2	60.4	63.9	69.9	76.6	77.0	73.9	64.2	58.3	53.4	(33)
(34)			MCDWB	67.9	73.8	81.2	86.2	92.4	96.5	95.4	94.5	93.0	87.9	78.7	65.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	27.7	27.8	29.0	29.3	29.9	32.5	27.1	27.1	27.7	28.9	28.5	25.8	(35)
(36)			MCDBR	32.7	33.4	33.7	33.6	35.1	35.6	29.9	29.5	30.2	32.3	33.1	30.4	(36)
(37)			MCWBR	16.8	16.2	14.7	13.7	12.9	13.4	11.4	11.6	11.7	13.1	15.9	16.1	(37)
(38)		5% WB	MCDBR	24.8	29.3	31.2	31.9	33.2	33.1	24.3	23.9	24.5	26.3	28.8	24.1	(38)
(39)			MCWBR	13.9	15.1	14.1	13.4	12.4	13.5	10.6	10.5	11.7	11.5	14.6	13.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.291	0.296	0.314	0.331	0.349	0.350	0.394	0.389	0.351	0.321	0.295	0.291	(40)
(41)		taud		2.514	2.519	2.456	2.411	2.379	2.380	2.365	2.371	2.437	2.491	2.533	2.542	(41)
(42)		Ebn at Noon		297	306	307	304	297	295	281	282	290	292	293	291	(42)
(43)		Edh at Noon		27	30	34	37	39	39	39	38	34	30	26	25	(43)
(44)	All-Sky Solar Radiation	RadAvg		1108	1411	1875	2291	2551	2671	2427	2260	1990	1597	1211	1001	(44)
(45)		RadStd		58	101	70	61	77	94	100	91	72	68	53	55	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (23 neighbors)	+0.86	N/A	-2.32	+1.06	N/A	N/A	N/A	-137	+313	+164	

Nomenclature: See separate page