

EL CENTRO NAF, CA, USA

WMO: 722810

Lat: 32.817N

Lon: 115.683W

Elev: -13

StdP: 101.48

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 23199

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	1.9	3.6	-15.8	0.9	14.3	-13.4	1.2	16.1	14.1	16.9	12.2	18.0	2.2	260	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.1	44.4	21.5	43.1	21.4	42.0	21.3	26.1	35.1	25.5	34.9	24.9	34.9	3.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	18.8	30.2	23.0	17.7	30.4	21.8	16.4	31.1	80.4	34.8	77.8	34.6	75.2	35.0	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	11.6	10.0	DB	-1.1	47.2	2.0	1.0	-2.5	47.9	-3.6	48.5	-4.8	49.0	-6.2	49.8	(4)
(5)			WB	-4.1	27.3	1.6	0.7	-5.3	27.7	-6.2	28.1	-7.1	28.5	-8.3	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.6	13.7	15.8	19.6	22.5	25.6	30.8	34.0	34.1	30.8	24.3	18.4	13.0	
	DBStd	7.93	3.04	3.17	3.44	3.37	3.48	2.89	1.93	2.02	3.20	3.18	3.39	2.82	
	HDD10.0	16	8	2	0	0	0	0	0	0	0	0	1	6	
	HDD18.3	468	144	79	28	6	1	0	0	0	0	2	41	167	
	CDD10.0	4979	123	165	296	375	483	624	744	747	625	443	253	99	
	CDD18.3	2390	1	9	66	131	226	374	486	489	375	188	44	1	
	CDH23.3	37220	76	263	983	1772	3164	5970	8143	8159	5699	2339	614	37	
	CDH26.7	23946	4	56	396	868	1849	4057	5750	5771	3736	1237	221	1	
Wind	WSAvg	3.5	2.6	3.4	4.0	4.8	4.9	4.1	3.5	3.1	3.2	3.3	2.9	2.8	
Precipitation	PrecAvg	64	12	13	7	2	1	0	3	5	4	4	4	9	
	PrecMax	151	90	64	48	15	16	4	24	24	35	27	26	32	
	PrecMin	10	0	0	0	0	0	0	0	0	0	0	0	0	
	PrecStd	42	20	15	10	3	3	1	5	7	7	9	8	10	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.1	30.3	34.7	38.0	41.6	46.3	45.7	45.6	43.7	38.7	33.0	26.3	
		MCWB	12.4	14.2	15.8	17.2	18.2	20.2	21.6	21.7	21.0	18.3	15.9	14.0	
	2%	DB	25.4	28.4	32.6	35.6	39.1	43.7	44.1	44.2	42.0	36.3	31.4	24.3	
		MCWB	12.1	13.7	15.2	16.5	17.8	20.0	22.0	21.8	20.8	17.6	15.1	12.5	
	5%	DB	23.8	26.7	30.8	33.6	37.3	42.0	42.8	42.9	40.8	34.8	29.4	22.4	
		MCWB	11.3	13.4	14.4	15.7	17.6	19.8	22.0	21.9	20.8	17.1	14.6	11.5	
	10%	DB	22.0	24.6	28.9	31.7	35.3	40.2	41.6	41.6	39.3	33.2	27.2	20.4	
		MCWB	11.3	12.5	14.0	15.2	17.0	19.6	21.9	22.0	20.8	16.9	14.0	10.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	16.7	17.1	19.1	20.7	24.7	26.4	27.0	26.5	22.7	17.7	16.3
			MCDB	21.6	26.6	31.3	33.4	35.5	36.5	36.2	35.0	34.3	30.0	27.9	23.3
2%		WB	14.1	15.0	16.2	17.7	19.6	23.6	25.8	26.3	25.3	21.1	16.3	14.6	
		MCDB	20.3	25.2	30.0	32.1	34.8	36.4	35.8	34.7	34.0	30.3	28.0	20.6	
5%		WB	13.0	13.9	15.4	16.7	18.6	22.4	25.3	25.6	24.3	19.4	15.5	13.3	
		MCDB	19.9	24.3	28.7	31.4	34.1	36.3	35.4	34.7	33.9	31.2	27.3	19.2	
10%		WB	12.0	13.0	14.5	15.8	17.7	21.1	24.8	25.0	23.3	17.9	14.6	11.9	
		MCDB	20.0	23.2	27.3	30.1	33.5	35.8	35.2	34.7	33.9	31.1	26.0	18.6	
Mean Daily Temperature Range		5% DB	MDBR	15.4	15.5	16.1	16.3	16.6	18.0	15.0	15.1	15.4	16.1	15.8	14.3
			MCDBR	18.2	18.6	18.7	18.7	19.5	19.8	16.6	16.4	16.8	18.0	18.4	16.9
	MCWBR		9.4	9.0	8.2	7.6	7.2	7.4	6.3	6.4	6.5	7.3	8.8	9.0	
	5% WB	MCDBR	13.8	16.3	17.3	17.7	18.5	18.4	13.5	13.3	13.6	14.6	16.0	13.4	
		MCWBR	7.7	8.4	7.8	7.4	6.9	7.5	5.9	5.8	6.5	6.4	8.1	7.6	
Clear-Sky Solar Irradiance	taub	0.291	0.296	0.314	0.331	0.349	0.350	0.394	0.389	0.351	0.321	0.295	0.291		
	taud	2.514	2.519	2.456	2.411	2.379	2.380	2.365	2.371	2.437	2.491	2.533	2.542		
	Ebn at Noon	936	966	967	957	936	929	887	889	914	922	924	917		
	Edh at Noon	84	93	107	117	122	122	123	120	108	94	82	78		
All-Sky Solar Radiation	RadAvg	3.49	4.45	5.91	7.22	8.04	8.42	7.65	7.13	6.27	5.04	3.82	3.16		
	RadStd	0.18	0.32	0.22	0.19	0.24	0.30	0.32	0.29	0.23	0.21	0.17	0.17		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (23 neighbors)		+0.48	N/A	-1.29	+0.59	N/A	N/A	N/A	-76	+174	+91	(47)

Nomenclature: See separate page