

PEASON RIDGE, LA, USA

WMO: 722820

Lat: 31.400N

Lon: 93.283W

Elev: 365

StdP: 14.50

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 03949

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 26.8	(c) 29.6	(d) 14.6	(e) 11.7	(f) 35.4	(g) 18.9	(h) 14.4	(i) 39.7	(j) 13.5	(k) 54.2	(l) 12.4	(m) 53.1	(n) 2.2	(o) 0	(p) 0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 19.7	(c) 98.0	(d) 75.6	(e) 95.5	(f) 75.8	(g) 93.4	(h) 75.7	(i) 79.2	(j) 88.7	(k) 78.4	(l) 87.8	(m) 78.0	(n) 87.3	(o) 4.5	(p) 30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	143.2	82.0	76.3	139.4	81.5	75.7	136.1	81.0	42.8	88.6	42.1	88.2	41.5	87.2	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.2	(b) 10.7	(c) 9.7	(e) 21.3	(f) 100.6	(g) 3.6	(h) 3.2	(i) 18.7	(j) 102.8	(k) 16.6	(l) 104.7	(m) 14.6	(n) 106.4	(o) 11.9	(p) 108.7		
(a) 12.2	(b) 10.7	(c) 9.7	(e) 19.6	(f) 81.0	(g) 3.2	(h) 1.0	(i) 17.3	(j) 81.7	(k) 15.4	(l) 82.3	(m) 13.6	(n) 82.8	(o) 11.2	(p) 83.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.0	49.3	52.5	60.0	66.7	73.9	80.7	82.5	83.2	77.9	67.4	57.8	51.5
	DBStd	14.23	9.68	10.55	9.09	7.12	5.97	3.62	3.21	3.65	4.87	7.99	9.32	9.76
	HDD50	377	134	87	21	2	0	0	0	0	0	1	31	101
	HDD65	1895	495	366	205	63	11	0	0	0	0	69	252	434
	CDD50	6596	111	158	333	504	741	922	1006	1028	838	542	266	147
	CDD65	2637	6	17	51	115	287	472	541	563	388	145	37	15
	CDH74	25421	9	69	310	902	2518	4779	5660	6020	3553	1332	228	41
	CDH80	11458	0	6	38	174	940	2297	2775	3086	1658	443	40	1
Wind	WSAvg	3.4	3.8	4.2	4.3	4.4	3.5	2.7	2.5	2.5	2.5	2.9	3.3	3.8
Precipitation	PrecAvg	54.4	5.6	4.8	4.8	5.0	4.3	3.9	4.4	3.4	4.1	3.9	5.1	5.1
	PrecMax	76.4	14.6	11.1	12.0	10.6	12.2	12.0	8.7	6.5	10.6	14.8	13.4	9.9
	PrecMin	29.9	1.0	1.0	0.7	1.1	0.0	0.3	1.0	0.4	1.0	0.0	0.4	1.5
	PrecStd	11.1	3.3	2.9	2.5	2.4	3.0	2.6	2.1	1.5	2.0	4.0	3.3	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.3	80.5	83.6	87.3	92.7	99.2	99.3	101.9	97.7	91.2	84.1	78.3
		MCWB	63.8	66.1	66.8	70.6	72.6	74.8	75.7	76.0	74.1	71.3	70.3	69.2
	2%	DB	72.5	75.8	80.7	84.2	90.0	95.9	96.5	98.9	94.4	88.1	79.9	74.4
		MCWB	63.0	64.1	66.5	68.9	72.3	75.0	76.1	75.9	73.7	71.8	68.8	67.8
	5%	DB	69.2	72.2	77.8	81.9	87.9	93.0	94.4	95.7	91.7	85.2	76.1	71.5
		MCWB	62.5	64.0	64.8	67.8	72.2	75.7	76.2	76.6	73.9	70.1	65.5	66.0
	10%	DB	65.9	69.1	74.5	79.6	85.6	90.8	92.2	93.1	89.2	82.0	72.9	68.5
		MCWB	59.3	62.9	63.9	66.2	71.6	75.4	76.4	76.3	73.2	68.5	65.3	64.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.2	69.1	70.7	73.9	76.8	79.5	80.1	80.4	78.5	77.6	73.2	71.9
		MCDB	71.8	74.9	76.9	80.4	84.7	88.6	89.5	89.7	86.3	84.1	80.4	74.9
	2%	WB	66.3	67.7	69.1	72.4	75.3	78.3	79.0	79.4	77.6	76.0	71.1	69.3
		MCDB	70.2	72.9	76.2	79.4	83.7	87.6	88.6	89.1	86.0	82.5	76.3	73.3
	5%	WB	64.2	66.1	68.0	71.1	74.4	77.6	78.3	78.6	76.7	74.5	69.2	67.8
		MCDB	68.0	71.0	74.2	78.1	82.8	86.9	87.9	88.1	85.1	80.4	74.6	71.2
	10%	WB	61.3	63.7	66.5	69.8	73.4	76.9	77.7	78.1	75.7	72.4	66.8	65.0
		MCDB	64.8	68.0	72.6	76.3	81.7	86.0	87.4	87.5	84.0	77.9	71.6	68.1
Mean Daily Temperature Range	5% DB	MDBR	20.9	20.4	21.8	21.7	20.8	19.8	18.9	19.7	21.2	24.0	22.7	19.5
		MCDBR	22.5	21.5	22.5	22.0	22.1	22.6	21.8	23.1	23.6	25.3	22.8	20.3
		MCWBR	14.6	12.4	10.6	9.3	7.7	6.4	5.7	5.4	8.2	10.6	12.9	13.4
	5% WB	MCDWR	18.4	18.2	18.6	18.2	18.4	19.0	18.7	19.6	19.7	19.0	19.7	17.4
	MCWBR	14.6	13.6	11.5	10.2	7.7	6.6	6.0	6.0	7.5	10.2	12.9	12.9	
Clear-Sky Solar Irradiance	taub	0.327	0.345	0.367	0.403	0.436	0.474	0.483	0.481	0.434	0.365	0.353	0.337	
	taud	2.527	2.481	2.417	2.324	2.276	2.207	2.221	2.220	2.320	2.488	2.473	2.499	
	Ebn at Noon	286	290	290	282	272	260	258	257	266	279	273	275	
	Edh at Noon	27	31	36	41	43	46	45	45	39	31	29	27	
All-Sky Solar Radiation	RadAvg	875	987	1381	1695	1880	1929	1926	1825	1590	1334	992	763	
	RadStd	82	170	115	121	131	145	152	159	148	184	103	90	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207	+142

Nomenclature: See separate page