

FULLERTON LANDING, LA, USA

WMO: 722821

Lat: 31.022N

Lon: 92.911W

Elev: 310

StdP: 14.53

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 53988

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.2	30.0	15.2	12.0	35.9	19.4	14.8	42.1	11.3	55.7	10.5	54.6	1.8	N/A	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.9	97.9	76.2	95.6	76.4	93.7	76.5	80.1	89.1	79.3	88.6	78.6	87.7	3.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.0	146.9	83.0	77.1	142.9	82.5	76.4	139.3	82.0	43.6	89.0	42.9	88.6	42.2	88.4	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.2	8.5	6.9	21.3	100.9	4.3	3.4	18.2	103.3	15.6	105.3	13.2	107.2	10.1	109.6
			19.4	81.8	3.7	1.2	16.7	82.6	14.5	83.3	12.4	83.9	9.7	84.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.9	50.2	53.5	61.3	67.9	74.9	81.4	82.7	83.3	78.7	68.8	59.1	52.6
	DBStd	13.95	9.67	10.47	9.07	7.17	5.79	3.62	3.19	3.36	4.58	7.99	9.04	9.45
	HDD50	317	117	77	18	2	0	0	0	0	0	1	19	83
	HDD65	1725	464	344	178	52	7	0	0	0	0	55	223	402
	CDD50	6861	125	174	369	539	770	941	1014	1032	860	583	292	162
	CDD65	2795	7	21	63	140	313	491	549	567	410	172	46	16
	CDH74	27090	18	79	359	1078	2775	5181	5793	6159	3763	1576	265	44
	CDH80	12108	1	6	47	225	1039	2519	2804	3133	1745	549	40	0
Wind	WSAvg	2.4	2.8	3.1	3.1	3.4	2.6	2.0	1.6	1.6	1.6	2.1	2.3	2.5
Precipitation	PrecAvg	58.2	5.8	4.7	5.0	5.2	4.7	4.3	4.6	3.5	4.4	4.3	5.4	5.9
	PrecMax	79.5	15.7	11.5	10.0	12.2	15.5	12.3	8.2	6.5	11.4	14.8	11.5	9.2
	PrecMin	36.9	1.0	0.7	1.5	1.1	0.2	1.1	0.7	0.7	1.0	0.0	0.6	1.9
	PrecStd	10.4	3.3	2.7	2.2	2.7	3.4	2.8	1.7	1.3	2.6	4.2	3.0	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.5	80.5	84.2	87.8	93.0	100.2	99.1	101.4	96.9	92.0	84.6	78.5
		MCWB	63.9	66.6	67.6	71.7	73.1	74.8	77.2	76.1	74.8	71.9	71.7	68.6
	2%	DB	72.8	76.5	81.1	84.9	90.3	96.7	96.5	98.4	94.1	88.7	80.4	74.6
		MCWB	63.6	64.6	67.5	69.4	73.4	75.5	76.8	76.7	75.1	73.0	69.9	67.3
	5%	DB	70.0	72.8	78.2	82.6	88.2	93.9	94.5	95.5	91.9	86.0	76.8	71.7
		MCWB	63.1	64.8	65.9	68.4	73.3	76.3	77.1	77.0	75.3	70.9	67.9	66.9
	10%	DB	66.7	69.7	75.1	80.4	86.1	91.4	92.4	93.2	89.5	82.9	73.9	68.3
		MCWB	60.2	63.9	64.6	67.5	72.5	76.2	77.3	77.0	74.8	69.9	66.9	63.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	70.3	71.4	74.9	78.0	80.3	80.5	81.3	79.9	78.3	74.6	71.3
		MCDB	72.5	75.0	77.4	80.6	86.1	89.6	89.2	89.6	88.3	84.8	80.2	74.5
	2%	WB	67.1	68.6	70.2	73.2	76.3	79.1	79.8	80.2	78.5	76.9	72.7	69.6
		MCDB	70.6	73.5	76.0	79.9	84.7	88.4	89.0	89.2	87.1	83.4	77.1	73.0
	5%	WB	64.7	66.8	68.9	71.9	75.3	78.3	79.1	79.5	77.7	75.5	70.8	67.8
		MCDB	68.1	70.9	74.6	78.9	83.4	87.5	88.5	88.9	86.2	81.7	75.1	71.5
	10%	WB	61.8	64.3	67.5	70.7	74.3	77.6	78.3	78.8	76.7	73.5	68.2	64.6
		MCDB	65.7	68.7	73.1	77.5	82.3	86.7	87.7	87.9	84.8	79.2	73.1	67.5
Mean Daily Temperature Range	5% DB	MDBR	21.2	20.5	21.3	21.6	20.4	19.6	18.5	19.9	20.8	23.6	22.8	18.9
		MCDBR	22.7	20.9	21.3	21.7	21.5	23.1	21.6	22.8	23.1	24.2	22.5	20.6
		MCWBR	15.1	11.9	10.0	9.3	7.8	6.6	6.1	6.0	7.7	10.3	13.0	13.9
	5% WB	MCDBR	18.0	18.0	17.8	17.3	18.2	18.4	18.7	19.4	19.2	19.0	18.8	18.5
		MCWBR	14.8	13.8	10.9	9.5	7.7	6.7	6.5	6.5	7.2	10.0	12.4	14.6
Clear-Sky Solar Irradiance	taub	0.329	0.348	0.369	0.409	0.439	0.480	0.492	0.487	0.442	0.369	0.354	0.342	
	taud	2.526	2.476	2.413	2.306	2.262	2.187	2.190	2.204	2.298	2.476	2.470	2.489	
	Ebn at Noon	286	290	290	280	271	259	255	256	263	279	274	274	
	Edh at Noon	28	31	36	42	44	47	47	45	40	31	29	27	
All-Sky Solar Radiation	RadAvg	884	1004	1396	1711	1896	1905	1888	1787	1584	1354	1015	779	
	RadStd	83	170	118	128	129	155	147	165	147	182	102	89	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (28 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207	+144	

Nomenclature: See separate page