

FULLERTON LANDING, LA, USA

WMO: 722821

Lat: 31.022N

Lon: 92.911W

Elev: 95

StdP: 100.19

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 53988

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.7	(c) -1.1	(d) -9.3	(e) 1.7	(f) 2.2	(g) -7.0	(h) 2.1	(i) 5.6	(j) 5.0	(k) 13.2	(l) 4.7	(m) 12.6	(n) 0.8	(o) N/A	(p) 0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 11.1	(c) 36.6	(d) 24.6	(e) 35.3	(f) 24.7	(g) 34.3	(h) 24.7	(i) 26.7	(j) 31.7	(k) 26.3	(l) 31.5	(m) 25.9	(n) 31.0	(o) 1.5	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	21.0	28.3	25.1	20.4	28.1	24.7	19.9	27.8	83.5	31.7	81.8	31.4	80.3	31.3	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.6	(b) 3.8	(c) 3.1	(e) -6.0	(f) 38.3	(g) 2.4	(h) 1.9	(i) -7.7	(j) 39.6	(k) -9.1	(l) 40.7	(m) -10.4	(n) 41.8	(o) -12.2	(p) 43.1		
(4) 4.6	(5) 3.8	(6) 3.1	(7) -6.0	(8) 38.3	(9) 2.4	(10) 1.9	(11) -7.7	(12) 39.6	(13) -9.1	(14) 40.7	(15) -10.4	(16) 41.8	(17) -12.2	(18) 43.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	10.1	11.9	16.3	20.0	23.8	27.4	28.2	28.5	25.9	20.4	15.0	11.4		
	DBStd	7.75	5.37	5.81	5.04	3.98	3.22	2.01	1.77	1.87	2.54	4.44	5.02	5.25		
	HDD10.0	176	65	43	10	1	0	0	0	0	0	1	11	46		
	HDD18.3	958	258	191	99	29	4	0	0	0	0	31	124	223		
	CDD10.0	3812	69	97	205	299	428	523	563	573	478	324	162	90		
	CDD18.3	1553	4	12	35	78	174	273	305	315	228	96	26	9		
	CDH23.3	15050	10	44	199	599	1542	2878	3218	3422	2091	876	147	24		
	CDH26.7	6727	1	3	26	125	577	1399	1558	1741	969	305	22	0		
(14) Wind	WSAvg	1.1	1.2	1.4	1.4	1.5	1.1	0.9	0.7	0.7	0.7	0.9	1.0	1.1		
(15) Precipitation	PrecAvg	1478	147	120	127	131	120	109	118	90	112	110	138	149		
	PrecMax	2019	399	293	255	311	394	312	208	166	290	377	292	233		
	PrecMin	936	26	17	39	28	4	28	18	19	26	0	16	48		
	PrecStd	264	85	68	55	68	86	71	42	34	66	106	77	50		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.7	26.9	29.0	31.0	33.9	37.9	37.3	38.5	36.1	33.3	29.2	25.8		
		MCWB	17.7	19.2	19.8	22.0	22.8	23.8	25.1	24.5	23.8	22.2	22.1	20.4		
	2%	DB	22.7	24.7	27.3	29.4	32.4	36.0	35.8	36.9	34.5	31.5	26.9	23.7		
		MCWB	17.6	18.1	19.7	20.8	23.0	24.1	24.9	24.8	24.0	22.8	21.0	19.6		
	5%	DB	21.1	22.6	25.7	28.1	31.2	34.4	34.7	35.3	33.3	30.0	24.9	22.1		
		MCWB	17.3	18.2	18.8	20.2	22.9	24.6	25.1	25.0	24.0	21.6	19.9	19.4		
	10%	DB	19.3	20.9	24.0	26.9	30.0	33.0	33.6	34.0	31.9	28.3	23.3	20.2		
		MCWB	15.6	17.7	18.1	19.7	22.5	24.5	25.1	25.0	23.8	21.1	19.4	17.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	21.3	21.9	23.9	25.6	26.8	26.9	27.4	26.6	25.7	23.7	21.8		
		MCDB	22.5	23.9	25.2	27.0	30.0	32.0	31.8	32.0	31.3	29.3	26.8	23.6		
	2%	WB	19.5	20.3	21.2	22.9	24.6	26.2	26.6	26.8	25.8	24.9	22.6	20.9		
		MCDB	21.5	23.0	24.5	26.6	29.3	31.3	31.7	31.8	30.6	28.6	25.1	22.8		
	5%	WB	18.2	19.3	20.5	22.2	24.1	25.7	26.1	26.4	25.4	24.1	21.5	19.9		
		MCDB	20.1	21.6	23.7	26.1	28.6	30.8	31.4	31.6	30.1	27.6	24.0	22.0		
	10%	WB	16.6	18.0	19.7	21.5	23.5	25.3	25.7	26.0	24.8	23.1	20.1	18.1		
		MCDB	18.7	20.4	22.8	25.3	28.0	30.4	30.9	31.1	29.3	26.2	22.9	19.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	11.4	11.9	12.0	11.3	10.9	10.3	11.1	11.6	13.1	12.7	10.5		
		MCDBR	12.6	11.6	11.8	12.0	11.9	12.8	12.0	12.7	12.8	13.5	12.5	11.4		
		MCWBR	8.4	6.6	5.6	5.2	4.3	3.7	3.4	3.3	4.3	5.7	7.2	7.7		
	5% WB	MCDBR	10.0	10.0	9.9	9.6	10.1	10.2	10.4	10.8	10.6	10.5	10.5	10.3		
		MCWBR	8.2	7.6	6.0	5.3	4.3	3.7	3.6	3.6	4.0	5.6	6.9	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.329	0.348	0.369	0.409	0.439	0.480	0.492	0.487	0.442	0.369	0.354	0.342		
	taud		2.526	2.476	2.413	2.306	2.262	2.187	2.190	2.204	2.298	2.476	2.470	2.489		
	Ebn at Noon		901	913	914	884	855	816	804	806	830	878	863	864		
	Edh at Noon		87	99	113	131	138	148	147	143	126	98	91	86		
(44) All-Sky Solar Radiation	RadAvg		2.79	3.17	4.40	5.39	5.98	6.01	5.95	5.63	4.99	4.27	3.20	2.46		
	RadStd		0.26	0.54	0.37	0.40	0.41	0.49	0.46	0.52	0.46	0.57	0.32	0.28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+115	+80

Nomenclature: See separate page