

PALM SPRINGS, CA, USA

WMO: 722868

Lat: 33.822N

Lon: 116.504W

Elev: 409

StdP: 14.48

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 93138

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	41.2	43.9	-0.1	5.5	64.6	4.3	6.9	66.2	23.3	61.4	18.9	61.8	4.0	330	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.8	112.4	70.2	109.7	70.2	107.8	69.8	78.3	97.9	76.9	97.2	75.3	97.6	10.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.8	123.6	90.4	70.3	113.4	90.9	67.1	101.1	91.8	42.1	96.9	40.4	96.9	38.9	97.5	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.9	19.9	17.8	DB	35.6	117.5	3.1	2.7	33.3	119.4	31.5	121.0	29.7	122.5	27.4	124.5
			WB	29.0	81.3	2.6	3.7	27.1	84.0	25.6	86.2	24.2	88.3	22.3	91.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.4	59.2	61.2	67.4	72.3	79.5	88.1	93.9	93.2	87.7	77.2	66.3	57.6	(6)
	DBStd	14.15	6.12	6.57	7.11	7.18	7.23	6.27	4.27	4.34	6.05	6.54	6.79	5.52	(7)
	HDD50	12	6	1	0	0	0	0	0	0	0	0	0	5	(8)
	HDD65	723	197	142	58	19	2	0	0	0	0	3	64	238	(9)
	CDD50	9275	290	314	540	670	914	1142	1362	1340	1131	843	488	241	(10)
	CDD65	4510	16	35	133	239	450	692	897	875	681	381	102	9	(11)
	CDH74	67829	181	405	1576	2955	6127	10909	15128	14611	10351	4478	1014	94	(12)
	CDH80	43740	23	93	622	1438	3604	7386	10812	10343	6731	2330	349	9	(13)
(14) Wind	WSAvg	6.5	5.0	5.3	6.5	8.0	8.9	8.1	7.2	6.5	6.5	6.1	5.2	4.8	(14)
(15) Precipitation	PrecAvg	4.9	1.0	0.8	0.5	0.1	0.1	0.0	0.2	0.4	0.4	0.2	0.7	0.7	(15)
	PrecMax	13.7	4.3	5.4	2.1	1.0	1.1	0.8	2.6	4.3	4.2	1.9	6.3	2.9	(16)
	PrecMin	1.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	3.3	1.3	1.1	0.6	0.2	0.2	0.2	0.5	0.9	0.9	0.4	1.2	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.4	86.9	95.2	100.6	108.4	115.0	116.9	115.1	110.5	101.9	92.1	81.2	(19)
		MCWB	54.5	56.5	61.0	63.8	69.3	68.0	74.0	71.4	68.7	65.2	59.4	55.1	(20)
	2%	DB	79.0	82.8	90.5	96.5	103.6	110.5	112.7	111.4	107.7	98.8	88.1	76.6	(21)
		MCWB	53.7	55.3	59.8	61.6	65.2	68.0	70.8	71.0	68.8	64.0	58.4	53.7	(22)
	5%	DB	75.2	79.4	87.1	92.5	100.0	107.7	109.7	108.9	105.1	94.9	84.0	72.8	(23)
		MCWB	52.3	54.6	58.3	60.5	65.8	67.4	71.2	70.8	67.9	62.4	57.3	52.0	(24)
	10%	DB	72.1	75.0	82.9	88.5	96.7	104.5	107.6	106.4	102.0	91.4	80.4	69.9	(25)
		MCWB	51.4	53.0	57.2	59.1	63.5	66.8	70.9	70.7	67.6	61.6	56.0	50.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.3	60.4	64.8	67.8	73.5	78.4	80.5	81.0	77.6	70.8	62.6	59.3	(27)
		MCDB	73.4	75.4	84.8	91.9	97.9	98.3	100.2	100.3	94.1	86.8	82.3	72.2	(28)
	2%	WB	57.1	57.9	62.1	64.1	70.2	74.0	78.2	78.6	75.7	68.3	60.3	56.8	(29)
		MCDB	68.6	73.7	83.3	90.6	96.9	98.8	97.6	98.7	94.6	89.9	81.5	68.9	(30)
	5%	WB	55.2	56.2	60.2	62.1	67.3	71.5	76.8	77.0	74.0	65.9	58.8	54.7	(31)
		MCDB	68.2	73.0	81.8	87.4	94.2	99.7	97.4	97.9	94.9	89.1	79.8	67.2	(32)
	10%	WB	53.4	54.8	58.7	60.4	65.4	69.5	75.3	75.3	72.1	63.9	57.2	52.8	(33)
		MCDB	68.4	71.3	79.6	84.2	91.6	98.3	98.2	98.0	94.1	86.7	76.8	66.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.3	21.7	24.0	25.0	26.3	29.0	25.8	25.7	25.3	24.0	22.5	20.8	(35)
		MCDBR	25.4	27.1	28.6	29.9	30.3	31.9	28.8	28.1	28.1	27.4	26.5	24.8	(36)
	5% WB	MCWBR	11.3	11.3	10.0	9.9	9.3	8.3	8.1	8.6	8.2	10.0	11.3	11.4	(37)
		MCWBR	20.7	23.2	26.8	27.8	28.6	29.0	22.1	20.8	20.9	24.0	23.8	20.9	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.307	0.312	0.331	0.350	0.365	0.368	0.401	0.391	0.359	0.349	0.313	0.315	(40)
		taud	2.490	2.488	2.422	2.381	2.369	2.376	2.372	2.385	2.447	2.423	2.512	2.496	(41)
	Ebn at Noon	Ebn at Noon	288	298	300	297	292	289	279	281	287	280	284	278	(42)
		Edh at Noon	27	30	35	38	39	39	39	37	34	32	26	26	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1054	1349	1823	2234	2509	2684	2438	2279	1988	1559	1171	954	(44)
	RadStd	RadStd	71	118	85	72	100	101	116	98	74	78	49	58	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.08	N/A	-3.69	+1.51	-1.48	N/A	N/A	-176	+482	+310	(46)
(47)	Regional (47 neighbors)	+1.04	N/A	-2.92	+1.12	N/A	N/A	N/A	-167	+367	+193	(47)

Nomenclature: See separate page