

LOS ANGELES USC, CA, USA

WMO: 722874

Lat: 34.024N

Lon: 118.291W

Elev: 55

StdP: 100.67

Time Zone: -8.00 (NAP)

Period: 99-19

WBAN: 93134

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.1	7.3	-11.1	1.5	18.1	-8.3	1.9	16.8	4.7	13.8	4.0	14.3	0.2	20	0.293

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	33.3	19.0	31.4	19.0	29.7	18.9	22.0	29.5	21.4	28.3	20.7	27.2	1.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.4	25.3	18.9	13.8	24.8	18.3	13.2	24.1	64.9	29.5	62.4	28.3	60.0	27.3	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.2	3.3	2.9	3.7	37.7	1.1	2.5	2.9	39.5	2.3	40.9	1.6	42.3	0.9	44.1		
			0.5	23.5	1.1	0.8	-0.2	24.1	-0.9	24.6	-1.5	25.0	-2.3	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	14.9	14.8	16.3	17.4	18.8	20.7	23.0	23.3	22.8	20.7	17.3	14.4
	DBStd	4.12	2.92	2.98	2.79	2.72	2.34	1.88	2.17	2.01	2.69	2.93	2.99	2.48
	HDD10.0	2	1	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	547	113	104	75	48	18	1	0	0	0	9	52	126
	CDD10.0	3188	152	136	197	222	274	321	403	413	385	331	220	136
	CDD18.3	692	6	6	13	21	34	72	144	155	135	81	22	2
	CDH23.3	4318	79	77	127	181	208	303	816	907	844	545	197	33
(14) Wind	WSAvg	0.8	0.6	0.8	0.9	1.1	1.0	1.0	1.0	0.9	0.8	0.7	0.6	0.6
	PrecAvg	403	91	107	55	23	10	2	1	0	5	17	28	61
	PrecMax	750	406	371	178	61	102	21	8	2	59	138	67	246
	PrecMin	166	6	3	0	1	0	0	0	0	0	0	0	1
	PrecStd	186	100	95	54	17	20	5	2	1	12	28	21	59
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.4	29.3	30.4	32.5	32.9	32.3	33.8	33.7	36.3	35.2	31.9	26.5
		MCWB	13.0	13.6	15.5	16.4	16.4	20.7	22.1	21.2	20.1	16.8	15.4	12.4
	2%	DB	25.6	25.8	26.8	27.9	28.2	28.3	30.8	31.4	32.9	31.9	28.5	24.0
		MCWB	12.5	12.8	14.1	14.6	17.0	19.6	21.3	20.7	20.4	16.5	14.3	12.0
	5%	DB	23.3	22.8	23.9	24.9	25.2	26.4	29.0	29.5	30.2	29.0	25.3	21.6
		MCWB	11.8	12.6	13.7	14.3	17.1	19.2	20.8	20.5	19.7	16.3	13.4	11.6
	10%	DB	20.6	20.1	21.5	22.4	23.0	24.8	27.4	27.8	27.9	26.2	22.8	19.3
		MCWB	11.6	12.3	13.5	14.3	16.4	18.4	20.3	20.2	19.4	16.8	13.2	11.4
	0.4%	WB	15.8	16.6	17.6	18.3	20.2	21.2	23.4	22.8	22.9	21.0	17.5	15.9
		MCDB	20.6	21.2	25.1	26.1	27.5	29.3	30.8	30.9	32.9	27.9	23.3	19.3
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	14.8	15.2	16.3	16.8	18.8	20.2	22.1	21.8	21.6	19.6	16.6	15.0
		MCDB	19.0	20.3	22.8	23.7	25.2	27.2	28.9	29.0	29.7	26.4	22.0	18.5
	5%	WB	14.1	14.3	15.4	15.8	17.7	19.4	21.4	21.1	20.7	18.7	15.8	14.1
		MCDB	18.0	18.9	20.8	21.9	23.4	25.7	27.7	27.9	27.8	24.7	20.8	17.7
	10%	WB	13.4	13.5	14.6	15.0	16.8	18.7	20.7	20.5	20.0	17.9	15.2	13.3
		MCDB	17.5	18.0	19.0	20.4	21.8	24.3	26.5	26.8	26.4	22.9	20.0	16.8
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	9.7	9.5	9.1	8.2	8.2	9.2	9.6	9.8	9.9	10.4	10.1
		MCDBR	14.8	14.4	14.1	13.8	12.3	11.0	10.9	11.5	13.1	15.1	14.9	14.0
		MCWBR	6.6	6.2	5.8	5.7	5.1	4.6	4.3	4.3	4.7	5.7	6.4	6.9
	5% WB	MCDBR	10.2	10.7	10.6	10.7	10.1	10.0	10.1	10.4	11.0	10.7	10.5	9.6
		MCWBR	5.2	5.4	4.9	4.9	4.5	4.3	4.2	4.2	4.2	4.4	5.0	5.4
(40) Clear-Sky Solar Irradiance	taub		0.343	0.356	0.382	0.384	0.385	0.405	0.402	0.383	0.369	0.380	0.325	0.326
	taud		2.463	2.437	2.340	2.347	2.376	2.324	2.401	2.433	2.465	2.397	2.558	2.551
	Ebn at Noon		863	890	891	903	901	878	879	893	893	851	882	865
	Edh at Noon		88	100	120	124	122	128	118	113	104	103	80	77
(44) All-Sky Solar Radiation	RadAvg		3.15	4.04	5.42	6.63	7.20	7.57	7.51	7.13	6.03	4.57	3.52	2.86
	RadStd		0.23	0.41	0.31	0.34	0.47	0.45	0.39	0.23	0.23	0.33	0.20	0.21

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.80	N/A	N/A	+1.53	N/A	N/A	N/A	-135	+309	+184
(47)	Regional (52 neighbors)	+0.64	N/A	-1.65	+0.73	N/A	N/A	N/A	-118	+225	+108

Nomenclature: See separate page