

**HOLLYWOOD BURBANK, CA, USA**WMO: **722880**Lat: **34.201N**Lon: **118.358W**Elev: **775**StdP: **14.29**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **23152****Annual Heating, Humidification, and Ventilation Design Conditions**

| Coldest Month | Heating DB |      | Humidification DP/MCDB and HR |     |      |      |      |      | Coldest Month WS/MCDB |      |      |      | MCWS/PCWD to 99.6% DB |      | WSF   |
|---------------|------------|------|-------------------------------|-----|------|------|------|------|-----------------------|------|------|------|-----------------------|------|-------|
|               |            |      | 99.6%                         |     |      | 99%  |      |      | 0.4%                  |      | 1%   |      |                       |      |       |
|               | 99.6%      | 99%  | DP                            | HR  | MCDB | DP   | HR   | MCDB | WS                    | MCDB | WS   | MCDB | MCWS                  | PCWD |       |
| (a)           | (b)        | (c)  | (d)                           | (e) | (f)  | (g)  | (h)  | (i)  | (j)                   | (k)  | (l)  | (m)  | (n)                   | (o)  | (p)   |
| 12            | 38.9       | 41.3 | 5.3                           | 7.4 | 63.2 | 11.3 | 10.1 | 62.8 | 25.0                  | 59.0 | 20.8 | 58.5 | 1.7                   | 350  | 0.387 |

**Annual Cooling, Dehumidification, and Enthalpy Design Conditions**

| Hottest Month | Hottest Month DB Range | Cooling DB/MCWB |      |      |      |      |      | Evaporation WB/MCDB |      |      |      |      |      | MCWS/PCWD to 0.4% DB |      |
|---------------|------------------------|-----------------|------|------|------|------|------|---------------------|------|------|------|------|------|----------------------|------|
|               |                        | 0.4%            |      | 1%   |      | 2%   |      | 0.4%                |      | 1%   |      | 2%   |      |                      |      |
|               |                        | DB              | MCWB | DB   | MCWB | DB   | MCWB | WB                  | MCDB | WB   | MCDB | WB   | MCDB | MCWS                 | PCWD |
| (a)           | (b)                    | (c)             | (d)  | (e)  | (f)  | (g)  | (h)  | (i)                 | (j)  | (k)  | (l)  | (m)  | (n)  | (o)                  | (p)  |
| 8             | 23.2                   | 97.9            | 67.8 | 94.3 | 66.8 | 91.2 | 66.1 | 72.4                | 89.8 | 70.9 | 87.6 | 69.3 | 85.5 | 8.4                  | 180  |

| Dehumidification DP/MCDB and HR |       |      |      |      |      |      |      |      | Enthalpy/MCDB |      |      |      |      |      | Extreme<br>Max WB |
|---------------------------------|-------|------|------|------|------|------|------|------|---------------|------|------|------|------|------|-------------------|
| 0.4%                            |       |      | 1%   |      |      | 2%   |      |      | 0.4%          |      | 1%   |      | 2%   |      |                   |
| DP                              | HR    | MCDB | DP   | HR   | MCDB | DP   | HR   | MCDB | Enth          | MCDB | Enth | MCDB | Enth | MCDB |                   |
| (a)                             | (b)   | (c)  | (d)  | (e)  | (f)  | (g)  | (h)  | (i)  | (j)           | (k)  | (l)  | (m)  | (n)  | (o)  |                   |
| 66.4                            | 100.2 | 78.0 | 65.1 | 95.7 | 77.0 | 63.8 | 91.1 | 75.3 | 36.4          | 89.7 | 35.0 | 87.6 | 33.8 | 85.9 | 82.9              |

**Extreme Annual Design Conditions**

| Extreme Annual WS |      |      | Extreme Annual Temperature |       |                    |     | n-Year Return Period Values of Extreme Temperature |       |            |       |            |       |            |       |    |    |
|-------------------|------|------|----------------------------|-------|--------------------|-----|----------------------------------------------------|-------|------------|-------|------------|-------|------------|-------|----|----|
|                   |      |      | Mean                       |       | Standard Deviation |     | n=5 years                                          |       | n=10 years |       | n=20 years |       | n=50 years |       |    |    |
| 1%                | 2.5% | 5%   | Min                        | Max   | Min                | Max | Min                                                | Max   | Min        | Max   | Min        | Max   | Min        | Max   | DB | WB |
| (a)               | (b)  | (c)  | (e)                        | (f)   | (g)                | (h) | (i)                                                | (j)   | (k)        | (l)   | (m)        | (n)   | (o)        | (p)   |    |    |
| (4) 18.1          | 14.8 | 12.6 | 34.2                       | 105.4 | 2.3                | 3.8 | 32.5                                               | 108.1 | 31.1       | 110.4 | 29.8       | 112.5 | 28.1       | 115.2 |    |    |
| (5)               |      |      | 28.9                       | 75.0  | 2.3                | 3.2 | 27.2                                               | 77.3  | 25.8       | 79.2  | 24.6       | 81.0  | 22.9       | 83.3  |    |    |

**Monthly Climatic Design Conditions**

|                                                                        |             | Annual | Jan   | Feb   | Mar   | Apr   | May   | Jun   | Jul   | Aug   | Sep   | Oct   | Nov   | Dec   |  |  |
|------------------------------------------------------------------------|-------------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|--|--|
|                                                                        |             | (d)    | (e)   | (f)   | (g)   | (h)   | (i)   | (j)   | (k)   | (l)   | (m)   | (n)   | (o)   | (p)   |  |  |
| (6) Temperatures, Degree-Days and Degree-Hours                         | DBAvg       | 65.4   | 56.6  | 56.7  | 60.0  | 62.5  | 65.7  | 70.4  | 75.8  | 77.1  | 74.8  | 68.2  | 61.2  | 55.6  |  |  |
|                                                                        | DBStd       | 9.39   | 5.79  | 5.95  | 5.91  | 6.31  | 5.70  | 5.26  | 4.78  | 4.98  | 6.11  | 6.02  | 5.93  | 5.18  |  |  |
|                                                                        | HDD50       | 31     | 9     | 8     | 2     | 1     | 0     | 0     | 0     | 0     | 0     | 0     | 1     | 10    |  |  |
|                                                                        | HDD65       | 1345   | 267   | 241   | 176   | 122   | 57    | 8     | 0     | 0     | 2     | 32    | 145   | 295   |  |  |
|                                                                        | CDD50       | 5662   | 213   | 195   | 313   | 374   | 488   | 612   | 801   | 840   | 743   | 564   | 336   | 183   |  |  |
|                                                                        | CDD65       | 1502   | 7     | 8     | 22    | 46    | 80    | 170   | 336   | 375   | 294   | 131   | 30    | 3     |  |  |
|                                                                        | CDH74       | 14776  | 140   | 170   | 345   | 587   | 779   | 1419  | 2981  | 3605  | 2879  | 1372  | 423   | 76    |  |  |
| (13)                                                                   | CDH80       | 6519   | 20    | 40    | 98    | 207   | 307   | 557   | 1328  | 1786  | 1427  | 602   | 138   | 9     |  |  |
| (14)                                                                   | Wind        | WSAvg  | 5.3   | 4.5   | 5.0   | 5.3   | 6.2   | 6.2   | 6.3   | 5.7   | 5.1   | 4.5   | 3.9   | 4.4   |  |  |
| (15) Precipitation                                                     | PrecAvg     | 15.9   | 3.6   | 4.2   | 2.2   | 0.9   | 0.4   | 0.1   | 0.0   | 0.0   | 0.2   | 0.7   | 1.1   | 2.4   |  |  |
|                                                                        | PrecMax     | 29.5   | 16.0  | 14.6  | 7.0   | 2.4   | 4.0   | 0.8   | 0.3   | 0.1   | 2.3   | 5.4   | 2.6   | 9.7   |  |  |
|                                                                        | PrecMin     | 6.5    | 0.2   | 0.1   | 0.0   | 0.0   | 0.0   | 0.0   | 0.0   | 0.0   | 0.0   | 0.0   | 0.0   | 0.0   |  |  |
|                                                                        | PrecStd     | 7.3    | 3.9   | 3.7   | 2.1   | 0.7   | 0.8   | 0.2   | 0.1   | 0.0   | 0.5   | 1.1   | 0.8   | 2.3   |  |  |
| (19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures | 0.4%        | DB     | 82.7  | 84.9  | 88.4  | 91.7  | 94.6  | 98.4  | 99.3  | 101.1 | 101.9 | 96.9  | 89.8  | 81.0  |  |  |
|                                                                        |             | MCWB   | 54.7  | 57.0  | 58.7  | 59.5  | 63.2  | 67.0  | 70.8  | 68.7  | 69.3  | 63.1  | 58.8  | 54.7  |  |  |
|                                                                        | 2%          | DB     | 78.3  | 79.7  | 82.2  | 86.0  | 88.3  | 91.0  | 93.5  | 97.1  | 97.1  | 91.4  | 83.9  | 75.4  |  |  |
|                                                                        |             | MCWB   | 53.4  | 54.6  | 57.3  | 58.6  | 62.9  | 66.9  | 68.7  | 68.6  | 67.6  | 60.8  | 57.2  | 52.8  |  |  |
|                                                                        | 5%          | DB     | 73.5  | 73.8  | 77.4  | 81.0  | 82.3  | 86.1  | 90.5  | 93.1  | 92.8  | 87.2  | 78.9  | 71.6  |  |  |
|                                                                        |             | MCWB   | 52.1  | 53.7  | 55.9  | 57.6  | 62.1  | 65.4  | 68.3  | 68.0  | 66.7  | 60.3  | 55.4  | 51.5  |  |  |
|                                                                        | 10%         | DB     | 69.5  | 69.0  | 72.8  | 75.7  | 77.3  | 81.9  | 87.7  | 90.0  | 88.5  | 81.9  | 73.6  | 66.6  |  |  |
|                                                                        |             | MCWB   | 51.4  | 52.4  | 55.0  | 56.5  | 61.5  | 65.2  | 68.0  | 67.7  | 65.7  | 59.9  | 54.3  | 50.7  |  |  |
| (27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures | 0.4%        | WB     | 60.2  | 60.8  | 62.7  | 65.3  | 69.3  | 71.2  | 75.4  | 74.4  | 73.4  | 69.7  | 62.4  | 59.4  |  |  |
|                                                                        |             | MCDB   | 67.4  | 75.4  | 78.7  | 83.2  | 85.7  | 88.3  | 91.7  | 92.2  | 93.6  | 84.4  | 74.7  | 67.2  |  |  |
|                                                                        | 2%          | WB     | 57.5  | 58.2  | 60.4  | 62.3  | 66.4  | 68.8  | 72.3  | 72.2  | 71.1  | 66.8  | 60.6  | 57.4  |  |  |
|                                                                        |             | MCDB   | 65.8  | 69.4  | 74.2  | 78.0  | 81.3  | 85.8  | 88.2  | 90.0  | 89.1  | 80.0  | 72.2  | 65.7  |  |  |
|                                                                        | 5%          | WB     | 55.9  | 56.3  | 58.9  | 60.1  | 64.4  | 67.2  | 70.5  | 70.6  | 69.3  | 64.7  | 59.2  | 55.7  |  |  |
|                                                                        |             | MCDB   | 64.2  | 66.4  | 71.6  | 73.8  | 77.9  | 82.8  | 85.7  | 88.0  | 85.9  | 77.7  | 70.4  | 63.3  |  |  |
|                                                                        | 10%         | WB     | 54.3  | 54.8  | 57.3  | 58.4  | 62.4  | 65.7  | 68.9  | 69.0  | 67.9  | 62.9  | 57.6  | 54.0  |  |  |
|                                                                        |             | MCDB   | 63.3  | 64.4  | 68.2  | 71.0  | 74.0  | 80.3  | 83.6  | 85.5  | 83.3  | 74.4  | 68.1  | 61.7  |  |  |
| (35) Mean Daily Temperature Range                                      | 5% DB       | MDBR   | 20.8  | 19.9  | 20.1  | 20.0  | 18.3  | 19.7  | 21.9  | 23.2  | 22.5  | 22.0  | 22.5  | 20.8  |  |  |
|                                                                        |             | MCDBR  | 29.1  | 29.8  | 29.3  | 29.6  | 27.3  | 27.5  | 25.7  | 27.8  | 28.6  | 31.2  | 30.9  | 29.1  |  |  |
|                                                                        |             | MCWBR  | 13.3  | 13.5  | 12.5  | 11.9  | 11.4  | 10.7  | 9.6   | 10.9  | 11.1  | 12.5  | 13.6  | 14.0  |  |  |
|                                                                        | 5% WB       | MCDBR  | 20.0  | 22.1  | 23.4  | 23.6  | 23.2  | 24.2  | 23.2  | 24.6  | 24.3  | 23.7  | 23.2  | 19.7  |  |  |
|                                                                        |             | MCWBR  | 10.9  | 11.5  | 11.5  | 10.8  | 10.5  | 9.9   | 9.2   | 10.3  | 10.1  | 11.2  | 12.1  | 11.2  |  |  |
| (40) Clear-Sky Solar Irradiance                                        | taub        |        | 0.332 | 0.344 | 0.369 | 0.379 | 0.381 | 0.401 | 0.400 | 0.378 | 0.367 | 0.374 | 0.319 | 0.319 |  |  |
|                                                                        | taud        |        | 2.465 | 2.445 | 2.357 | 2.334 | 2.361 | 2.311 | 2.378 | 2.416 | 2.443 | 2.382 | 2.546 | 2.534 |  |  |
|                                                                        | Ebn at Noon |        | 277   | 286   | 287   | 288   | 287   | 280   | 279   | 285   | 284   | 271   | 281   | 276   |  |  |
|                                                                        | Edh at Noon |        | 28    | 31    | 37    | 40    | 39    | 41    | 38    | 36    | 34    | 33    | 25    | 25    |  |  |
| (44) All-Sky Solar Radiation                                           | RadAvg      |        | 994   | 1275  | 1718  | 2107  | 2315  | 2464  | 2423  | 2294  | 1938  | 1466  | 1119  | 905   |  |  |
|                                                                        | RadStd      |        | 75    | 135   | 99    | 107   | 142   | 136   | 115   | 67    | 63    | 98    | 60    | 68    |  |  |

**Historical Trends**

|      |                         | Heating |        | Cooling |       |       | Degree-Days |       |       |       |
|------|-------------------------|---------|--------|---------|-------|-------|-------------|-------|-------|-------|
|      |                         | 99% DB  | 99% DP | 1% DB   | 1% WB | 1% DP | HDD50       | HDD65 | CDD50 | CDD65 |
| (46) | Station Only            | N/A     | N/A    | N/A     | N/A   | N/A   | N/A         | N/A   | N/A   | N/A   |
| (47) | Regional (52 neighbors) | +1.15   | N/A    | -2.88   | +1.31 | N/A   | N/A         | -212  | +405  | +194  |

Nomenclature: See separate page