

HOLLYWOOD BURBANK, CA, USAWMO: **722880**Lat: **34.201N**Lon: **118.358W**Elev: **236**StdP: **98.52**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **23152****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.8	5.2	-14.8	1.1	17.3	-11.5	1.4	17.1	11.2	15.0	9.3	14.7	0.8	350	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	36.6	19.9	34.6	19.3	32.9	19.0	22.4	32.1	21.6	30.9	20.7	29.7	3.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.3	25.6	18.4	13.7	25.0	17.6	13.0	24.0	66.7	32.0	63.6	30.9	60.9	30.0	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.1	6.6	5.6	1.2	40.8	1.3	2.1	0.3	42.3	-0.5	43.5	-1.2	44.7	-2.2	46.2
			-1.7	23.9	1.3	1.8	-2.7	25.2	-3.4	26.2	-4.1	27.2	-5.1	28.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	13.7	13.7	15.6	16.9	18.7	21.3	24.4	25.0	23.8	20.1	16.2	13.1
	DBStd	5.22	3.22	3.30	3.28	3.51	3.17	2.92	2.66	2.77	3.39	3.34	3.29	2.88
	HDD10.0	17	5	4	1	1	0	0	0	0	0	0	1	6
	HDD18.3	747	148	134	98	68	32	4	0	0	1	18	81	164
	CDD10.0	3146	118	108	174	208	271	340	445	467	413	313	187	102
	CDD18.3	834	4	4	12	26	44	94	187	208	163	73	17	2
	CDH23.3	8209	78	94	192	326	433	788	1656	2003	1599	762	235	42
(14) Wind	WSAvg	2.4	2.0	2.2	2.4	2.8	2.8	2.8	2.8	2.5	2.3	2.0	1.8	2.0
	PrecAvg	403	91	107	55	23	10	2	1	0	5	17	28	61
	PrecMax	750	406	371	178	61	102	21	8	2	59	138	67	246
	PrecMin	166	6	3	0	1	0	0	0	0	0	0	0	1
	PrecStd	186	100	95	54	17	20	5	2	1	12	28	21	59
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.2	29.4	31.3	33.2	34.8	36.9	37.4	38.4	38.8	36.1	32.1	27.2
		MCWB	12.6	13.9	14.8	15.3	17.3	19.5	21.6	20.4	20.7	17.3	14.9	12.6
	2%	DB	25.7	26.5	27.9	30.0	31.3	32.8	34.1	36.2	36.2	33.0	28.9	24.1
		MCWB	11.9	12.5	14.1	14.8	17.2	19.4	20.4	20.3	19.8	16.0	14.0	11.6
	5%	DB	23.1	23.2	25.2	27.2	27.9	30.0	32.5	34.0	33.8	30.7	26.1	22.0
		MCWB	11.2	12.0	13.3	14.2	16.7	18.6	20.2	20.0	19.3	15.7	13.0	10.9
	10%	DB	20.8	20.5	22.6	24.3	25.2	27.7	30.9	32.2	31.4	27.7	23.1	19.2
		MCWB	10.8	11.4	12.8	13.6	16.4	18.5	20.0	19.8	18.7	15.5	12.4	10.4
	0.4%	WB	15.6	16.0	17.1	18.5	20.7	21.8	24.1	23.5	23.0	21.0	16.9	15.2
		MCDB	19.7	24.1	26.0	28.4	29.8	31.3	33.2	33.5	34.2	29.1	23.7	19.5
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	14.2	14.6	15.8	16.8	19.1	20.4	22.4	22.3	21.7	19.3	15.9	14.1
		MCDB	18.8	20.8	23.4	25.6	27.4	29.9	31.2	32.2	31.7	26.7	22.3	18.7
	5%	WB	13.3	13.5	15.0	15.6	18.0	19.5	21.4	21.4	20.7	18.2	15.1	13.2
		MCDB	17.9	19.1	22.0	23.2	25.5	28.2	29.8	31.1	30.0	25.4	21.4	17.4
	10%	WB	12.4	12.7	14.0	14.7	16.9	18.7	20.5	20.5	19.9	17.2	14.2	12.2
		MCDB	17.4	18.0	20.1	21.7	23.4	26.8	28.7	29.7	28.5	23.5	20.1	16.5
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	11.1	11.2	11.1	10.2	10.9	12.1	12.9	12.5	12.2	12.5	11.5
		MCDBR	16.2	16.6	16.3	16.5	15.2	15.3	14.3	15.4	15.9	17.3	17.2	16.2
		MCWBR	7.4	7.5	6.9	6.6	6.3	5.9	5.3	6.0	6.2	6.9	7.5	7.8
	5% WB	MCDBR	11.1	12.3	13.0	13.1	12.9	13.4	12.9	13.7	13.5	13.2	12.9	11.0
		MCWBR	6.1	6.4	6.4	6.0	5.8	5.5	5.1	5.7	5.6	6.2	6.7	6.2
(40) Clear-Sky Solar Irradiance	taub		0.332	0.344	0.369	0.379	0.381	0.401	0.400	0.378	0.367	0.374	0.319	0.319
	taud		2.465	2.445	2.357	2.334	2.361	2.311	2.378	2.416	2.443	2.382	2.546	2.534
	Ebn at Noon		874	902	904	907	904	882	881	897	895	855	887	871
	Edh at Noon		88	99	117	126	124	130	121	114	106	104	80	78
(44) All-Sky Solar Radiation	RadAvg		3.13	4.02	5.42	6.64	7.30	7.77	7.64	7.23	6.11	4.62	3.53	2.85
	RadStd		0.23	0.43	0.31	0.34	0.45	0.43	0.36	0.21	0.20	0.31	0.19	0.21

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	-1.60	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		+0.64	N/A	-1.65	+0.73	N/A	N/A	-118	+225	+108

Nomenclature: See separate page