

VAN NUYS, CA, USA

WMO: 722886

Lat: 34.210N

Lon: 118.489W

Elev: 770

StdP: 14.29

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 23130

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	38.6	41.1	0.1	5.7	60.9	5.5	7.5	63.1	25.9	58.8	24.0	59.1	1.7	0	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	26.1	100.0	67.5	97.0	66.9	93.5	65.8	72.1	91.9	70.5	89.6	69.1	87.5	8.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	97.3	79.3	63.9	91.6	76.4	63.0	88.6	74.9	36.1	92.3	34.7	89.6	33.6	87.6	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.7	18.0	15.3	DB	34.1	106.4	2.5	3.8	32.3	109.1	30.8	111.4	29.4	113.5	27.5	116.2
			WB	29.5	75.2	2.5	3.5	27.7	77.7	26.2	79.7	24.8	81.6	23.0	84.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	57.2	56.7	60.3	62.7	66.7	71.5	77.4	78.2	75.6	68.9	61.8	55.9
	DBStd	9.92	6.59	6.35	6.45	6.48	6.01	5.75	5.05	5.09	6.33	6.31	6.41	5.89
	HDD50	39	12	9	3	1	0	0	0	0	0	0	1	13
	HDD65	1307	257	244	175	119	47	8	0	0	2	31	135	289
	CDD50	5923	234	196	321	381	517	645	849	873	768	587	356	196
	CDD65	1716	14	11	28	50	99	203	384	408	320	152	40	7
	CDH74	18392	135	178	418	672	1107	1988	3913	4320	3377	1656	539	89
	CDH80	8920	17	32	116	243	481	909	2021	2353	1808	748	183	9
Wind	WSAvg	5.2	6.2	5.3	5.3	5.8	5.5	5.4	5.1	4.6	4.2	4.5	4.9	5.9
Precipitation	PrecAvg	15.9	3.6	4.2	2.2	0.9	0.4	0.1	0.0	0.0	0.2	0.7	1.1	2.4
	PrecMax	29.5	16.0	14.6	7.0	2.4	4.0	0.8	0.3	0.1	2.3	5.4	2.6	9.7
	PrecMin	6.5	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	7.3	3.9	3.7	2.1	0.7	0.8	0.2	0.1	0.0	0.5	1.1	0.8	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.2	84.0	88.9	92.7	97.4	101.8	102.2	103.6	104.1	97.7	90.3	81.1
		MCWB	54.6	56.0	59.2	60.2	65.6	66.0	69.8	68.1	69.4	62.8	58.3	54.5
	2%	DB	78.1	79.9	83.0	87.0	90.8	93.9	97.2	99.4	99.2	92.6	85.6	76.3
		MCWB	53.6	55.3	57.9	59.3	62.8	67.0	68.4	67.7	67.0	60.8	57.4	52.5
	5%	DB	74.0	74.8	78.7	81.6	85.3	89.5	93.5	95.8	95.1	88.5	80.3	72.2
		MCWB	52.2	53.7	56.5	57.6	62.1	65.8	68.1	67.0	66.3	59.9	55.2	51.4
	10%	DB	70.4	70.0	74.1	76.9	80.0	84.7	90.6	92.0	90.5	83.6	75.3	68.1
		MCWB	50.8	51.8	55.3	56.3	61.4	65.0	67.4	66.5	65.0	58.9	53.5	50.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.7	60.3	64.0	65.7	72.0	71.7	74.6	73.5	73.1	68.8	61.7	59.2
		MCDB	70.8	72.1	77.0	83.6	86.3	89.9	94.7	94.9	96.2	83.9	75.6	68.1
	2%	WB	57.3	57.6	60.8	62.1	66.5	69.2	72.0	71.3	70.8	66.1	59.8	57.3
		MCDB	67.4	70.6	76.4	78.7	83.1	88.1	91.0	91.7	91.3	82.0	74.8	65.8
	5%	WB	55.5	55.9	59.0	59.9	64.4	67.6	70.3	69.6	68.9	64.1	58.3	55.5
		MCDB	65.5	68.1	73.9	75.8	80.4	85.0	88.5	89.3	87.7	79.0	71.6	63.6
	10%	WB	53.9	54.3	57.1	58.2	62.3	66.0	68.8	68.3	67.4	62.3	56.9	53.6
		MCDB	64.0	65.1	69.5	72.7	76.3	82.1	86.2	87.2	85.0	75.6	68.8	63.0
Mean Daily Temperature Range	5% DB	MDBR	20.1	20.0	21.0	21.2	21.2	22.7	24.9	26.1	25.1	23.3	22.8	20.2
		MCDBR	26.4	29.4	29.2	30.5	30.9	30.5	28.4	30.6	31.7	32.1	31.2	27.7
		MCWBR	11.8	12.8	11.9	11.9	11.3	9.8	9.1	9.7	9.6	10.7	11.6	12.5
	5% WB	MCDBR	20.5	23.3	24.9	25.1	26.3	26.9	25.7	26.6	26.9	24.8	24.2	20.4
		MCWBR	10.7	11.4	11.6	11.4	11.2	10.0	9.3	9.4	9.3	10.2	10.6	10.8
Clear-Sky Solar Irradiance	taub	0.325	0.338	0.360	0.378	0.385	0.399	0.407	0.381	0.372	0.372	0.318	0.319	
	taud	2.491	2.471	2.391	2.339	2.350	2.318	2.357	2.406	2.426	2.392	2.549	2.536	
	Ebn at Noon	280	289	290	288	285	280	277	284	282	272	282	277	
	Edh at Noon	27	31	36	40	40	41	39	37	34	33	25	25	
All-Sky Solar Radiation	RadAvg	990	1269	1710	2099	2306	2451	2421	2293	1934	1461	1115	901	
	RadStd	75	137	101	110	146	139	115	67	63	100	61	69	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.94	N/A	-6.44	+1.26	N/A	N/A	N/A	-299	+688	+367
Regional (52 neighbors)		+1.15	N/A	-2.97	+1.30	N/A	N/A	N/A	-225	+414	+182

Nomenclature: See separate page