

VAN NUYS, CA, USA

WMO: 722886

Lat: 34.210N

Lon: 118.489W

Elev: 235

StdP: 98.54

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 23130

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.7	5.0	-17.7	0.8	16.0	-14.7	1.1	17.3	11.6	14.9	10.7	15.0	0.8	0	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.5	37.8	19.7	36.1	19.4	34.2	18.8	22.3	33.3	21.4	32.0	20.6	30.8	3.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.9	26.3	17.7	13.1	24.6	17.2	12.7	23.9	66.1	33.5	62.9	32.0	60.2	30.9	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	8.0	6.8	1.2	41.4	1.4	2.1	0.2	42.9	-0.7	44.1	-1.5	45.3	-2.5	46.8		
			-1.4	24.0	1.4	1.9	-2.4	25.4	-3.2	26.5	-4.0	27.6	-5.0	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	14.0	13.7	15.7	17.0	19.3	21.9	25.2	25.6	24.2	20.5	16.6	13.3	
	DBStd	5.51	3.66	3.53	3.58	3.60	3.34	3.19	2.80	2.83	3.52	3.50	3.56	3.27	
	HDD10.0	22	7	5	2	1	0	0	0	0	0	1	7		
	HDD18.3	726	143	136	97	66	26	4	0	0	1	17	75	161	
	CDD10.0	3291	130	109	178	212	287	358	472	485	427	326	198	109	
	CDD18.3	953	8	6	16	28	55	113	213	227	178	84	22	4	
	CDH23.3	10218	75	99	232	373	615	1104	2174	2400	1876	920	299	49	
CDH26.7	4956	9	18	64	135	267	505	1123	1307	1004	416	102	5		
Wind	WSAvg	2.3	2.8	2.4	2.4	2.6	2.5	2.4	2.3	2.1	1.9	2.0	2.2	2.6	
Precipitation	PrecAvg	403	91	107	55	23	10	2	1	0	5	17	28	61	
	PrecMax	750	406	371	178	61	102	21	8	2	59	138	67	246	
	PrecMin	166	6	3	0	1	0	0	0	0	0	0	1	1	
	PrecStd	186	100	95	54	17	20	5	2	1	12	28	21	59	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	28.9	31.6	33.7	36.3	38.8	39.0	39.8	40.0	36.5	32.4	27.3	
		MCWB	12.6	13.3	15.1	15.7	18.7	18.9	21.0	20.1	20.8	17.1	14.6	12.5	
	2%	DB	25.6	26.6	28.3	30.6	32.6	34.4	36.2	37.4	37.3	33.7	29.8	24.6	
		MCWB	12.0	12.9	14.4	15.2	17.1	19.5	20.2	19.8	19.5	16.0	14.1	11.4	
	5%	DB	23.3	23.8	26.0	27.6	29.6	32.0	34.2	35.5	35.0	31.4	26.9	22.4	
		MCWB	11.2	12.1	13.6	14.2	16.7	18.8	20.1	19.5	19.1	15.5	12.9	10.8	
	10%	DB	21.3	21.1	23.4	24.9	26.6	29.3	32.6	33.3	32.5	28.7	24.0	20.1	
		MCWB	10.4	11.0	12.9	13.5	16.3	18.3	19.7	19.2	18.3	15.0	11.9	10.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	15.7	17.8	18.7	22.2	22.0	23.7	23.0	22.8	20.5	16.5	15.1
			MCDB	21.5	22.3	25.0	28.7	30.1	32.2	34.9	34.9	35.7	28.8	24.2	20.0
2%		WB	14.0	14.2	16.0	16.7	19.2	20.7	22.2	21.8	21.6	19.0	15.4	14.0	
		MCDB	19.7	21.4	24.7	26.0	28.4	31.2	32.8	33.2	32.9	27.8	23.8	18.8	
5%		WB	13.1	13.3	15.0	15.5	18.0	19.8	21.3	20.9	20.5	17.8	14.6	13.0	
		MCDB	18.6	20.1	23.3	24.3	26.9	29.5	31.4	31.8	30.9	26.1	22.0	17.6	
10%		WB	12.2	12.4	13.9	14.6	16.8	18.9	20.4	20.2	19.6	16.8	13.9	12.0	
		MCDB	17.8	18.4	20.8	22.6	24.6	27.8	30.1	30.7	29.5	24.2	20.4	17.2	
Mean Daily Temperature Range		5% DB	MDBR	11.2	11.1	11.7	11.8	11.8	12.6	13.8	14.5	14.0	12.9	12.7	11.2
			MCDBR	14.6	16.3	16.2	16.9	17.1	16.9	15.8	17.0	17.6	17.8	17.3	15.4
	MCWBR		6.6	7.1	6.6	6.6	6.3	5.5	5.1	5.4	5.4	5.9	6.4	7.0	
	5% WB	MCDBR	11.4	13.0	13.8	14.0	14.6	15.0	14.3	14.8	14.9	13.8	13.5	11.4	
		MCWBR	5.9	6.3	6.4	6.3	6.2	5.6	5.2	5.2	5.2	5.7	5.9	6.0	
Clear-Sky Solar Irradiance	taub	0.325	0.338	0.360	0.378	0.385	0.399	0.407	0.381	0.372	0.372	0.318	0.319		
	taud	2.491	2.471	2.391	2.339	2.350	2.318	2.357	2.406	2.426	2.392	2.549	2.536		
	Ebn at Noon	884	910	913	908	900	883	874	894	889	858	888	872		
	Edh at Noon	85	97	113	125	125	129	123	116	108	103	80	78		
All-Sky Solar Radiation	RadAvg	3.12	4.00	5.39	6.62	7.27	7.73	7.63	7.23	6.10	4.61	3.52	2.84		
	RadStd	0.24	0.43	0.32	0.35	0.46	0.44	0.36	0.21	0.20	0.32	0.19	0.22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only		+1.08	N/A	-3.58	+0.70	N/A	N/A	N/A	-166	+382	+204
Regional (52 neighbors)		+0.64	N/A	-1.65	+0.72	N/A	N/A	N/A	-125	+230	+101

Nomenclature: See separate page