

SAN LUIS OBISPO, CA, USA

WMO: 722897

Lat: 35.237N

Lon: 120.641W

Elev: 61

StdP: 100.59

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93206

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	1.2	2.5	-6.7	2.1	12.0	-4.2	2.7	11.6	9.8	14.0	8.5	14.4	0.8	100	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	13.1	32.2	17.8	29.6	17.4	27.7	17.2	19.7	28.5	18.9	27.1	18.1	25.8	4.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	11.9	21.9	15.9	11.4	21.2	15.0	10.8	20.2	56.2	28.5	53.4	27.1	51.2	25.8	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	9.4	8.4	-1.2	37.7	1.6	2.6	-2.4	39.6	-3.3	41.1	-4.2	42.5	-5.4	44.4
			-2.4	21.5	1.7	1.5	-3.6	22.6	-4.6	23.5	-5.6	24.3	-6.9	25.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	12.2	12.3	13.5	14.1	15.7	17.3	19.0	19.3	19.2	17.7	14.6	11.7
	DBStd	3.88	2.79	3.12	2.98	2.94	2.61	2.21	1.87	1.82	2.67	3.25	3.25	2.65
	HDD10.0	44	11	11	4	2	0	0	0	0	0	0	3	13
	HDD18.3	1197	192	171	153	132	91	44	13	8	17	51	121	205
	CDD10.0	2076	78	74	112	125	177	219	278	289	277	241	139	66
	CDD18.3	189	1	2	3	5	9	13	33	39	44	32	8	0
	CDH23.3	2079	28	36	55	88	138	174	293	321	422	392	116	16
	CDH26.7	663	4	7	11	29	48	54	69	84	161	162	33	1
(14) Wind	WSAvg	3.1	2.4	2.7	3.2	3.7	4.0	3.7	3.3	3.3	3.1	2.9	2.4	2.3
(15) Precipitation	PrecAvg	658	135	135	101	40	11	2	1	1	9	25	70	98
	PrecMax	1267	626	385	419	175	87	20	13	36	98	132	198	276
	PrecMin	297	0	2	0	0	0	0	0	0	0	0	0	0
	PrecStd	249	131	121	86	40	20	5	3	6	19	29	56	70
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	27.9	27.8	30.9	31.8	32.2	31.9	32.4	35.5	34.9	30.5	25.7
		MCWB	12.9	15.8	16.7	16.9	18.1	18.5	19.1	18.8	19.0	17.6	16.5	12.6
	2%	DB	23.1	23.7	24.5	25.9	27.1	27.9	28.4	28.8	31.1	31.0	26.7	22.2
		MCWB	13.2	14.3	14.7	15.3	16.8	17.6	18.4	18.8	18.1	16.5	14.8	12.3
	5%	DB	20.5	20.6	21.8	22.6	23.7	25.1	26.5	26.7	27.9	27.6	23.5	19.5
		MCWB	12.6	13.2	14.1	14.6	15.7	16.7	18.0	18.1	17.6	15.4	13.8	11.9
	10%	DB	17.8	17.7	19.2	20.0	21.3	23.0	24.6	24.8	25.4	24.5	21.0	17.4
		MCWB	12.1	12.1	13.4	13.8	14.9	16.1	17.3	17.5	17.1	15.0	13.2	11.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.3	17.0	17.9	18.1	19.1	19.7	20.5	20.6	21.2	20.0	17.7	16.3
		MCDB	19.1	22.8	25.2	27.0	28.3	29.7	28.5	28.6	28.4	29.5	25.4	18.8
	2%	WB	15.0	15.5	16.1	16.4	17.4	18.2	19.1	19.1	19.3	18.1	16.3	15.1
		MCDB	18.9	20.7	22.0	24.0	25.3	26.4	27.0	27.4	27.8	26.1	22.3	17.5
	5%	WB	14.0	14.4	15.0	15.3	16.2	17.2	18.3	18.4	18.3	17.0	15.3	13.8
		MCDB	17.7	18.7	20.0	21.3	22.6	24.4	25.9	26.1	26.0	24.0	21.0	16.7
	10%	WB	13.0	13.3	14.0	14.2	15.1	16.3	17.5	17.6	17.5	16.1	14.4	12.7
		MCDB	16.7	17.0	18.4	19.2	20.8	22.7	24.4	24.8	24.8	22.5	19.3	16.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	11.3	11.7	11.8	11.7	12.2	12.2	12.4	13.1	13.7	13.3	12.4
		MCDBR	17.2	16.3	16.0	16.6	16.4	15.8	15.2	15.4	17.2	19.1	17.7	16.6
	5% WB	MCWBR	9.2	8.7	8.5	8.3	7.9	7.3	6.7	6.6	7.2	8.2	8.2	9.1
		MCDWR	11.9	12.7	13.1	14.2	14.2	13.8	14.2	14.6	15.2	15.2	14.0	11.0
(40) Clear-Sky Solar Irradiance	taub		0.308	0.324	0.329	0.334	0.343	0.353	0.351	0.343	0.341	0.344	0.308	0.313
		taud	2.563	2.523	2.515	2.499	2.491	2.453	2.514	2.503	2.514	2.505	2.577	2.561
	Ebn at Noon		902	923	945	951	940	925	925	929	918	887	895	873
		Edh at Noon	78	91	99	106	109	113	105	104	98	91	76	74
(44) All-Sky Solar Radiation	RadAvg		2.91	3.77	5.20	6.52	7.43	7.89	7.43	6.84	5.88	4.44	3.30	2.59
	RadStd		0.24	0.40	0.37	0.45	0.42	0.31	0.25	0.23	0.23	0.28	0.18	0.25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	+0.76	N/A	N/A	N/A	-242	+257
(47) Regional (28 neighbors)		+0.57	N/A	-1.23	+0.70	N/A	N/A	N/A	-158	+207

Nomenclature: See separate page