

SAN DIEGO INTL, CA, USA

WMO: 722900

Lat: 32.734N

Lon: 117.183W

Elev: 15

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23188

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	45.3	47.2	16.8	12.9	61.2	21.9	16.4	61.5	20.2	59.7	17.9	59.6	1.8	340	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.6	84.8	64.4	81.6	65.6	79.0	65.8	71.4	78.4	70.3	77.0	69.3	75.6	8.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	106.1	75.1	67.7	102.0	74.4	66.7	98.4	73.6	35.2	78.6	34.3	77.2	33.3	75.8	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.6	12.7	41.7	92.5	2.0	4.5	40.3	95.7	39.1	98.4	37.9	100.9	36.4	104.2		
(5)			34.3	73.3	2.2	1.8	32.7	74.6	31.4	75.6	30.1	76.6	28.5	77.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	58.0	58.3	60.2	61.9	64.0	66.4	70.1	71.8	71.1	67.4	62.2	57.5
	DBStd	6.22	4.08	3.91	3.72	3.94	3.43	2.92	3.21	3.27	3.97	4.06	4.29	3.62
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1101	221	192	156	108	57	15	1	0	0	16	103	232
	CDD50	5157	248	232	318	358	435	493	622	676	634	540	367	234
	CDD65	784	3	4	9	17	27	58	158	211	184	91	21	1
	CDH74	2415	37	40	72	109	105	67	271	548	614	386	154	12
	CDH80	469	2	6	15	27	36	10	21	70	126	114	42	0
Wind	WSAvg	5.9	4.7	5.7	6.1	6.9	6.9	6.8	6.5	6.4	6.2	5.2	4.5	4.5
Precipitation	PrecAvg	8.7	1.7	1.6	1.6	0.7	0.2	0.0	0.0	0.0	0.2	0.3	1.2	1.3
	PrecMax	19.9	6.1	6.9	6.3	2.9	1.3	0.7	0.1	0.3	1.4	2.0	5.7	5.6
	PrecMin	2.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	3.9	1.7	1.7	1.6	0.8	0.3	0.1	0.0	0.0	0.4	0.4	1.3	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.5	79.8	81.6	83.9	84.9	80.4	82.4	85.7	88.9	88.9	85.7	75.6
		MCWB	54.4	55.3	58.0	57.2	58.6	66.8	69.7	69.6	69.0	62.2	59.2	52.9
	2%	DB	73.6	73.2	74.6	76.4	75.2	75.3	79.3	81.8	83.3	83.0	78.1	70.9
		MCWB	53.2	54.3	55.7	57.4	61.9	65.8	68.8	69.7	68.7	61.3	56.5	53.7
	5%	DB	69.5	68.6	69.8	71.5	70.9	72.5	76.9	79.0	80.0	77.8	73.2	67.3
		MCWB	53.6	54.3	56.3	58.0	61.7	64.4	68.1	69.1	69.1	62.5	56.3	54.2
	10%	DB	65.5	65.0	66.4	68.0	68.4	70.9	74.9	76.9	77.3	74.0	69.5	64.7
		MCWB	53.8	54.7	56.4	58.3	60.6	63.3	67.2	68.3	68.3	63.2	57.7	54.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.9	61.2	62.2	63.4	66.1	68.4	71.9	72.8	73.3	70.3	64.9	62.2
		MCDB	64.6	66.4	70.1	70.3	73.1	76.0	79.3	81.2	81.6	77.6	69.8	65.6
	2%	WB	59.3	59.5	60.2	61.7	64.2	66.8	69.9	71.2	71.7	67.9	63.1	60.2
		MCDB	63.6	64.6	67.1	68.9	70.7	73.6	76.6	78.2	78.7	74.6	68.1	64.2
	5%	WB	58.2	58.3	59.1	60.3	62.8	65.5	68.9	70.1	70.5	66.3	61.8	58.9
		MCDB	62.6	63.4	65.3	67.2	68.8	71.6	75.1	76.7	77.1	72.6	67.0	63.0
	10%	WB	57.1	57.2	58.1	59.3	61.7	64.2	67.9	69.2	69.3	64.9	60.4	57.5
		MCDB	61.9	62.3	63.9	65.8	67.4	70.0	73.9	75.4	75.6	71.0	65.9	61.8
Mean Daily Temperature Range	5% DB	MDBR	14.5	12.8	11.3	10.4	8.0	7.6	8.0	8.6	9.5	11.5	13.9	14.5
		MCDBR	22.1	20.7	19.3	18.7	12.8	10.7	10.3	11.4	14.2	20.4	22.2	20.1
		MCWBR	11.1	10.4	9.5	9.0	6.0	4.6	4.2	4.7	6.2	11.6	12.4	11.9
	5% WB	MCDBR	13.5	13.1	12.4	13.3	10.7	11.2	9.8	10.9	12.3	14.1	14.5	13.1
		MCWBR	8.7	7.9	7.0	6.9	5.2	4.8	4.2	4.6	5.6	8.6	9.4	8.7
Clear-Sky Solar Irradiance	taub	0.317	0.328	0.341	0.352	0.372	0.371	0.400	0.399	0.365	0.372	0.325	0.328	
	taud	2.550	2.532	2.479	2.453	2.418	2.424	2.426	2.408	2.479	2.432	2.555	2.545	
	Ebn at Noon	288	295	298	297	290	289	280	279	286	275	282	277	
	Edh at Noon	26	29	33	36	37	37	37	37	33	32	26	25	
All-Sky Solar Radiation	RadAvg	1048	1324	1731	2086	2179	2260	2220	2145	1857	1451	1137	949	
	RadStd	64	110	97	115	166	146	150	95	104	106	77	67	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.95	N/A	-2.65	+1.69	N/A	N/A	N/A	-185	+338	+162
(47) Regional (39 neighbors)		+1.15	N/A	-2.86	+1.37	N/A	N/A	N/A	-189	+414	+214

Nomenclature: See separate page