

LOS ANGELES INTL, CA, USA

WMO: 722950

Lat: 33.938N

Lon: 118.389W

Elev: 30

StdP: 100.97

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23174

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.2	8.3	-11.0	1.5	16.7	-8.0	1.9	16.2	11.5	14.1	10.0	13.6	1.9	80	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	29.3	17.4	27.4	17.9	25.9	18.0	21.4	25.7	20.7	24.6	20.1	23.9	3.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.5	23.7	19.1	14.0	23.1	18.5	13.4	22.5	62.3	25.7	59.9	24.8	57.8	23.8	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	7.9	7.2	DB	4.7	34.6	1.1	2.4	3.8	36.3	3.2	37.7	2.6	39.0	1.7	40.8	(4)
(5)			WB	0.9	22.3	1.4	1.1	0.0	23.1	-0.8	23.7	-1.6	24.3	-2.6	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	14.4	14.2	15.1	15.9	17.3	18.9	20.7	21.2	21.0	19.3	16.7	14.2
	DBStd	3.49	2.72	2.63	2.29	2.42	1.95	1.48	1.70	1.86	2.30	2.73	2.82	2.33
	HDD10.0	2	1	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	698	126	119	106	82	43	8	1	1	2	16	64	129
	CDD10.0	2719	138	118	157	177	227	268	333	349	329	289	202	131
	CDD18.3	373	4	4	5	8	12	27	76	91	81	48	16	2
	CDH23.3	1182	34	32	33	52	48	36	131	215	257	233	99	14
	CDH26.7	252	4	7	6	14	15	5	14	27	53	77	29	1
Wind	WSAvg	3.3	2.8	3.3	3.5	3.8	3.7	3.5	3.5	3.4	3.2	3.0	2.8	2.8
Precipitation	PrecAvg	307	66	72	46	17	3	2	1	1	5	10	34	48
	PrecMax	749	323	338	162	115	24	25	9	32	48	96	190	224
	PrecMin	95	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	141	72	75	42	23	5	5	2	4	11	16	39	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	27.4	27.2	28.5	28.8	27.0	28.5	29.3	31.1	32.8	30.3	25.3
		MCWB	12.9	13.9	13.9	14.6	15.6	19.1	21.2	21.1	19.5	16.4	15.0	12.0
	2%	DB	23.6	23.0	23.2	24.2	23.5	24.0	26.1	27.0	28.0	28.6	26.0	22.2
		MCWB	12.0	12.4	12.9	13.7	17.1	18.4	20.4	20.5	19.8	15.7	13.4	11.8
	5%	DB	21.2	20.3	20.5	21.5	21.7	22.7	24.7	25.5	26.1	25.7	23.3	20.0
		MCWB	11.6	12.2	13.1	14.0	16.8	17.9	19.8	20.0	19.6	16.2	13.2	11.5
	10%	DB	18.9	18.0	18.6	19.5	20.3	21.7	23.6	24.3	24.5	23.3	21.1	18.2
		MCWB	11.5	12.2	13.4	14.0	16.0	17.4	19.2	19.5	19.3	16.6	13.4	11.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.3	16.3	16.7	17.4	19.9	20.1	21.9	22.1	22.3	20.8	17.9	16.4
		MCDB	19.2	20.5	20.5	22.4	23.5	25.3	26.6	27.1	27.5	25.1	21.6	18.2
	2%	WB	15.2	15.2	15.6	16.1	18.2	19.0	21.0	21.3	21.2	19.5	16.8	15.4
		MCDB	17.7	17.9	19.0	20.3	21.6	23.2	25.0	25.6	25.4	23.6	20.1	17.3
	5%	WB	14.5	14.6	15.0	15.3	17.4	18.3	20.3	20.6	20.5	18.6	16.2	14.7
		MCDB	16.8	17.0	18.0	19.0	20.5	22.1	23.9	24.5	24.4	22.2	19.3	16.7
	10%	WB	13.8	13.9	14.4	14.7	16.6	17.8	19.6	20.0	19.8	17.8	15.5	14.0
		MCDB	16.2	16.3	17.0	18.1	19.5	21.2	22.9	23.6	23.5	21.2	18.6	16.1
Mean Daily Temperature Range	5% DB	MDBR	8.4	7.6	6.9	6.8	5.8	5.4	5.5	5.7	6.1	7.2	8.3	8.2
		MCDBR	12.7	12.1	11.0	10.5	7.9	6.6	6.6	7.1	8.6	12.1	12.6	11.6
		MCWBR	6.3	6.1	5.6	4.9	3.8	2.9	2.8	3.0	3.6	5.6	6.5	6.5
	5% WB	MCDBR	8.0	7.9	7.3	7.8	6.7	6.4	6.3	6.8	7.1	8.2	8.6	7.5
		MCWBR	4.8	4.7	4.2	4.1	3.5	3.0	2.8	3.0	3.2	4.2	5.0	4.9
Clear-Sky Solar Irradiance	taub	0.335	0.349	0.372	0.377	0.382	0.398	0.400	0.380	0.367	0.371	0.322	0.323	
	taud	2.501	2.476	2.385	2.378	2.393	2.352	2.412	2.447	2.478	2.439	2.577	2.573	
	Ebn at Noon	875	900	902	910	904	885	881	896	895	861	887	871	
	Edh at Noon	85	97	114	120	120	125	117	111	103	99	78	76	
All-Sky Solar Radiation	RadAvg	3.15	4.03	5.40	6.61	7.12	7.41	7.42	7.06	5.96	4.52	3.50	2.85	
	RadStd	0.23	0.40	0.31	0.35	0.50	0.46	0.41	0.24	0.25	0.34	0.22	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	-1.60	N/A	N/A	N/A	N/A	N/A	+139	N/A
(47) Regional (52 neighbors)		+0.64	N/A	-1.65	+0.73	N/A	N/A	N/A	-118	+225	+108

Nomenclature: See separate page