

LOS ALAMITOS AAF, CA, USA

WMO: 722975

Lat: 33.790N

Lon: 118.052W

Elev: 11

StdP: 101.20

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 53141

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.9	5.2	-12.5	1.3	20.9	-8.2	1.9	19.0	9.4	17.1	8.2	15.2	0.9	20	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.8	33.4	18.9	31.4	18.9	29.7	18.8	22.4	28.4	21.8	27.2	21.2	26.3	4.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	15.5	23.7	20.1	14.9	23.6	19.5	14.2	23.3	65.9	28.2	63.5	27.3	61.3	26.5	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.4	5.6	1.3	39.0	0.9	2.3	0.6	40.7	0.1	42.1	-0.5	43.4	-1.1	45.1		
(5)			-0.4	23.4	0.9	1.0	-1.1	24.2	-1.6	24.8	-2.0	25.3	-2.7	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	13.9	13.6	15.2	16.7	17.9	19.8	22.1	22.7	22.6	19.9	16.4	13.1
	DBStd	4.17	2.54	2.92	2.45	2.38	2.02	1.73	1.99	2.13	2.70	2.67	2.68	2.38
	HDD10.0	9	2	4	0	0	0	0	0	0	0	0	0	3
	HDD18.3	718	141	136	102	62	31	3	0	0	1	12	69	162
	CDD10.0	2871	122	104	161	200	244	294	374	394	377	307	193	99
	CDD18.3	539	2	3	5	12	17	47	117	136	128	61	12	1
	CDH23.3	3935	67	67	104	191	148	185	612	829	921	571	210	30
	CDH26.7	1313	12	19	33	65	66	47	149	251	366	233	68	4
Wind	WSAvg	2.2	1.8	2.1	2.3	2.6	2.8	2.6	2.5	2.3	2.1	1.9	1.7	1.8
Precipitation	PrecAvg	316	70	81	45	19	7	2	1	0	3	12	22	53
	PrecMax	632	325	330	152	51	54	22	11	2	40	113	57	249
	PrecMin	121	0	0	0	2	0	0	0	0	0	0	0	0
	PrecStd	153	82	75	44	14	12	5	2	0	8	23	18	53
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.7	29.7	30.8	32.7	33.8	31.5	32.6	33.6	36.9	36.3	32.3	26.9
		MCWB	13.2	14.2	15.3	15.4	15.9	20.1	20.3	20.1	20.1	17.5	15.8	11.5
	2%	DB	25.1	25.1	26.0	28.0	27.8	27.2	30.0	31.4	32.8	32.2	28.5	23.1
		MCWB	12.9	13.4	14.1	14.7	15.9	19.4	20.5	20.5	20.8	17.2	14.3	12.6
	5%	DB	22.9	21.9	23.1	25.2	23.7	25.2	28.1	29.5	30.7	29.0	25.5	20.5
		MCWB	12.4	14.0	14.5	14.3	16.9	18.8	20.5	20.4	20.3	17.0	13.7	11.9
	10%	DB	20.2	19.5	20.7	22.2	21.8	23.7	26.6	27.6	28.4	26.1	22.8	18.5
		MCWB	12.7	13.8	14.4	14.7	16.2	18.2	20.2	20.3	20.4	17.1	13.9	12.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.8	18.4	18.4	18.4	19.1	21.2	22.7	23.0	23.7	22.6	18.6	17.8
		MCDB	20.2	21.4	23.2	25.4	24.5	28.3	28.2	29.4	31.8	27.1	23.3	19.1
	2%	WB	15.8	16.7	16.9	17.2	18.3	20.1	21.8	22.3	22.5	20.9	17.5	16.2
		MCDB	18.3	19.7	21.7	22.9	23.6	25.9	27.6	27.9	28.9	25.8	21.8	18.3
	5%	WB	15.1	15.7	16.0	16.4	17.5	19.4	21.1	21.6	21.7	20.0	16.7	15.3
		MCDB	17.6	18.8	20.5	21.6	21.7	24.3	26.5	26.8	27.2	24.6	20.9	17.0
	10%	WB	14.3	14.8	15.3	15.6	16.7	18.6	20.5	20.9	21.0	18.9	15.9	14.4
		MCDB	17.4	17.8	19.1	20.1	20.7	23.0	25.5	25.6	26.0	23.1	19.8	16.3
Mean Daily Temperature Range	5% DB	MDBR	12.5	11.0	10.6	10.7	8.5	8.0	8.8	9.8	10.9	11.7	12.8	11.4
		MCDBR	17.6	16.2	16.3	17.5	13.1	11.5	11.7	13.3	15.2	18.0	18.2	16.2
		MCWBR	8.4	8.2	7.6	6.5	5.1	4.5	4.2	4.4	5.0	6.7	7.9	8.3
	5% WB	MCDBR	11.6	11.5	11.3	12.2	10.3	10.5	10.3	10.9	12.7	12.4	12.8	10.0
		MCWBR	7.2	7.2	6.4	5.7	4.5	4.2	3.9	4.1	4.7	5.4	7.0	6.8
Clear-Sky Solar Irradiance	taub		0.335	0.346	0.372	0.371	0.371	0.387	0.389	0.373	0.359	0.365	0.318	0.318
	taud		2.507	2.485	2.386	2.398	2.430	2.386	2.449	2.479	2.509	2.466	2.595	2.596
	Ebn at Noon		877	904	903	916	914	895	891	903	904	869	894	880
	Edh at Noon		85	96	114	118	116	121	113	108	100	97	77	74
All-Sky Solar Radiation	RadAvg		3.18	4.07	5.44	6.63	7.11	7.43	7.41	7.06	5.97	4.54	3.53	2.88
	RadStd		0.22	0.39	0.29	0.34	0.48	0.46	0.40	0.22	0.25	0.34	0.21	0.21

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		+0.62	N/A	-1.63	+0.72	N/A	N/A	-110	+216	+104

Nomenclature: See separate page