

DARE COUNTY REGIONAL, NC, USA

WMO: 723046

Lat: 35.917N

Lon: 75.700W

Elev: 4

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 13766

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.6	-2.0	-13.9	1.1	-1.5	-11.3	1.4	0.8	12.0	11.6	10.9	9.0	3.8	340	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	32.9	25.8	32.2	25.8	31.0	25.2	27.6	30.9	26.8	30.0	26.0	29.1	4.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	29.9	26.0	21.4	28.9	25.1	20.2	28.2	87.2	31.2	83.4	30.0	80.7	29.4	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.4	8.5	DB	-5.3	35.3	2.6	1.5	-7.2	36.4	-8.7	37.3	-10.2	38.2	-12.1	39.3	(4)
(5)			WB	-7.5	28.6	2.3	1.0	-9.2	29.3	-10.5	29.9	-11.8	30.4	-13.5	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	6.5	7.6	10.5	15.7	20.3	24.8	26.9	26.3	23.8	18.6	13.0	9.3	(6)	
	DBStd	8.18	5.25	4.49	4.71	4.31	3.80	2.95	2.33	2.08	2.45	3.93	4.19	4.60	(7)	
	HDD10.0	373	134	92	54	4	0	0	0	0	0	0	18	71	(8)	
	HDD18.3	1533	367	301	246	102	25	1	0	0	1	44	165	281	(9)	
	CDD10.0	2924	26	25	68	175	319	443	523	507	413	268	108	49	(10)	
	CDD18.3	1042	0	0	2	23	86	193	264	248	164	54	6	1	(11)	
	CDH23.3	8432	0	0	6	74	438	1612	2724	2353	1012	207	7	0	(12)	
	CDH26.7	2355	0	0	0	6	79	462	937	687	164	20	0	0	(13)	
(14) Wind	WSAvg	4.1	4.0	4.3	4.6	4.9	4.5	4.1	4.0	3.7	4.1	3.8	3.8	3.8	(14)	
(15) Precipitation	PrecAvg	1231	98	80	94	69	81	126	144	158	128	89	64	84	(15)	
	PrecMax	1768	189	165	197	188	180	239	263	297	259	209	175	151	(16)	
	PrecMin	683	29	24	20	14	0	25	26	77	19	9	0	19	(17)	
	PrecStd	247	48	41	49	51	54	55	60	63	64	53	46	32	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.3	21.2	23.8	27.5	31.2	34.0	35.9	34.0	32.0	28.5	24.0	21.8	(19)	
		MCWB	16.5	16.5	17.0	19.7	23.3	24.9	26.4	26.8	24.7	23.3	20.1	18.3	(20)	
	2%	DB	17.8	18.0	21.4	25.6	28.8	32.4	33.0	32.4	29.6	27.1	22.5	19.6	(21)	
		MCWB	15.3	14.6	16.4	19.3	22.5	24.7	26.1	26.0	24.6	22.8	18.9	17.7	(22)	
	5%	DB	16.2	16.4	19.2	23.7	27.2	31.0	32.3	31.3	28.1	25.9	21.0	17.8	(23)	
		MCWB	13.8	13.4	15.9	18.7	21.7	24.2	26.3	25.6	23.7	21.9	17.9	16.1	(24)	
	10%	DB	14.0	14.2	17.7	22.3	25.9	29.0	31.2	30.0	27.5	24.1	19.1	16.2	(25)	
		MCWB	12.2	11.8	14.7	18.3	21.2	24.0	25.8	25.1	23.5	20.9	16.9	14.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.6	17.6	19.1	22.5	24.8	27.1	29.0	28.6	26.8	24.9	21.7	19.5	(27)	
		MCDB	18.9	19.8	21.9	25.6	29.0	30.8	32.5	32.0	29.2	27.5	23.3	20.4	(28)	
	2%	WB	16.1	15.9	17.7	20.8	23.5	26.0	28.0	27.4	25.5	23.8	19.7	18.1	(29)	
		MCDB	17.6	17.4	19.7	23.5	27.1	29.7	31.6	30.2	27.9	26.3	21.0	19.0	(30)	
	5%	WB	14.5	14.3	16.6	19.8	22.7	25.3	27.1	26.6	24.9	22.9	18.5	16.6	(31)	
		MCDB	16.1	16.1	18.9	22.7	26.1	29.2	30.6	29.3	27.4	25.1	20.1	17.9	(32)	
	10%	WB	12.7	12.4	15.1	18.8	21.9	24.6	26.3	25.8	24.4	21.7	17.3	14.8	(33)	
		MCDB	14.0	14.0	17.6	21.6	24.8	28.4	29.7	28.7	26.9	23.7	18.7	16.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	7.9	7.9	8.0	7.3	6.6	6.4	6.0	5.6	6.8	7.4	7.1	(35)	
		MCDBR	9.4	10.2	9.8	9.4	8.5	8.3	7.9	7.3	6.9	7.0	8.6	8.2	(36)	
	5% WB	MCWBR	7.6	7.6	6.1	5.2	4.4	4.0	4.0	3.6	3.5	4.0	6.2	6.9	(37)	
		MCWBR	8.6	9.5	8.7	8.3	7.4	7.2	7.2	6.7	5.7	5.4	7.4	7.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.324	0.331	0.354	0.398	0.441	0.486	0.513	0.501	0.419	0.368	0.337	0.329	(40)	
		taud	2.535	2.510	2.468	2.355	2.274	2.198	2.130	2.155	2.386	2.512	2.545	2.548	(41)	
	Ebn at Noon		877	911	915	886	849	808	782	784	837	858	854	847	(42)	
		Edh at Noon	80	91	104	122	135	145	154	148	112	91	79	75	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.38	3.16	4.24	5.41	6.08	6.43	6.06	5.52	4.57	3.68	2.69	2.15	(44)	
	RadStd		0.16	0.32	0.32	0.39	0.43	0.34	0.31	0.37	0.29	0.36	0.19	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+164	+112

Nomenclature: See separate page