

CHERRY POINT MCAS, NC, USA

WMO: 723090

Lat: 34.900N

Lon: 76.883W

Elev: 9

StdP: 101.22

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13754

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.6	(c) -2.7	(d) -14.7	(e) 1.0	(f) -0.9	(g) -12.1	(h) 1.3	(i) 0.5	(j) 11.8	(k) 7.6	(l) 10.9	(m) 7.5	(n) 3.3	(o) 10	(p) 0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	33.1	25.5	32.1	25.1	31.1	24.6	26.9	30.8	26.3	30.0	25.7	29.3	4.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.3	29.0	25.2	20.3	28.4	24.6	19.6	27.8	84.3	30.9	81.4	30.0	78.9	29.3	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.5	(b) 8.9	(c) 8.1	(e) -8.7	(f) 35.8	(g) 2.3	(h) 1.4	(i) -10.4	(j) 36.8	(k) -11.7	(l) 37.6	(m) -13.0	(n) 38.4	(o) -14.7	(p) 39.4		
(a) 10.5	(b) 8.9	(c) 8.1	(e) -9.8	(f) 28.3	(g) 2.1	(h) 0.7	(i) -11.2	(j) 28.8	(k) -12.4	(l) 29.2	(m) -13.6	(n) 29.5	(o) -15.1	(p) 30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	7.3	8.8	12.0	16.7	21.0	25.1	26.6	26.1	23.6	18.4	12.9	9.6
	DBStd	7.92	5.69	5.10	4.80	4.09	3.49	2.57	1.87	1.87	2.49	4.14	4.61	5.23
	HDD10.0	333	122	77	35	2	0	0	0	0	0	1	23	73
	HDD18.3	1406	342	269	203	78	15	1	0	0	1	52	172	273
	CDD10.0	3029	39	42	97	204	342	452	513	501	408	262	108	61
	CDD18.3	1061	1	2	6	29	98	203	255	242	159	54	8	3
	CDH23.3	8480	2	6	30	167	701	1723	2375	2119	1017	307	29	6
	CDH26.7	2651	0	0	2	22	183	584	841	719	249	49	1	0
Wind	WSAvg	3.7	3.9	4.1	4.4	4.4	3.9	3.5	3.2	3.0	3.5	3.3	3.5	3.6
Precipitation	PrecAvg	1388	107	99	101	79	128	127	177	188	133	82	79	92
	PrecMax	1732	241	236	224	236	311	287	371	487	348	274	234	233
	PrecMin	1063	14	14	22	2	55	25	34	53	6	13	11	10
	PrecStd	184	49	52	45	50	69	61	77	106	87	60	53	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	24.0	26.3	29.0	32.9	34.6	34.7	34.2	32.1	30.0	26.2	24.1
		MCWB	18.3	19.0	18.8	20.4	23.6	24.9	26.2	26.1	24.6	23.4	21.0	19.7
	2%	DB	21.0	21.7	23.8	27.0	30.2	32.7	33.2	32.5	30.6	27.9	24.0	22.2
		MCWB	17.7	16.8	17.5	19.6	22.6	24.7	25.9	25.6	23.7	22.3	19.5	18.6
	5%	DB	19.1	19.6	22.1	25.3	28.6	31.3	32.0	31.5	29.2	26.4	22.4	20.7
		MCWB	16.1	15.7	16.4	18.8	22.0	24.2	25.6	25.2	23.3	21.5	18.8	18.2
	10%	DB	17.1	17.7	20.2	23.7	27.2	29.9	30.8	30.3	28.0	25.0	20.9	18.7
		MCWB	14.5	14.2	15.9	18.1	21.1	23.7	25.0	24.6	23.0	20.9	17.6	16.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.0	20.4	20.4	22.9	25.2	27.0	27.9	27.8	25.9	25.4	22.8	21.3
		MCDB	21.9	22.8	23.5	26.0	29.9	31.5	32.1	31.8	29.5	27.6	24.8	22.9
	2%	WB	18.4	18.6	19.1	21.5	24.0	26.0	27.0	26.9	25.2	24.1	21.1	19.7
		MCDB	20.2	20.7	22.0	24.7	28.0	30.4	31.0	30.5	28.6	26.5	22.9	21.1
	5%	WB	16.8	16.9	18.0	20.3	23.0	25.3	26.4	26.2	24.6	23.0	19.6	18.3
		MCDB	18.8	18.8	20.7	23.6	26.8	29.6	30.3	29.6	27.7	25.3	21.6	20.0
	10%	WB	14.8	14.8	16.8	19.2	22.2	24.6	25.7	25.6	24.1	21.8	18.1	16.7
		MCDB	16.8	17.4	19.6	22.6	25.9	28.4	29.4	28.9	26.8	24.1	20.2	18.7
Mean Daily Temperature Range	5% DB	MDBR	10.7	11.0	11.3	11.1	10.2	9.1	8.3	8.3	8.2	10.1	11.0	10.6
		MCDBR	13.0	13.0	13.0	12.0	11.3	10.3	9.5	9.5	9.3	10.7	11.9	11.7
		MCWBR	10.0	9.2	7.7	6.5	5.3	4.4	4.2	4.2	4.1	5.8	8.1	8.9
	5% WB	MCDBR	11.5	11.4	10.6	9.8	9.5	9.2	8.7	8.3	7.7	8.1	9.8	10.4
		MCWBR	9.9	9.4	7.9	6.5	5.0	4.4	4.4	4.2	3.9	5.3	8.0	9.2
Clear-Sky Solar Irradiance	taub		0.321	0.332	0.359	0.399	0.444	0.492	0.519	0.502	0.422	0.371	0.342	0.330
	taud		2.540	2.503	2.446	2.333	2.251	2.162	2.098	2.138	2.369	2.487	2.518	2.542
	Ebn at Noon		888	915	913	887	847	804	778	784	838	858	853	854
	Edh at Noon		81	93	107	126	138	151	160	151	115	94	82	77
All-Sky Solar Radiation	RadAvg		2.59	3.32	4.39	5.55	6.13	6.36	6.02	5.47	4.53	3.82	2.87	2.30
	RadStd		0.16	0.33	0.32	0.38	0.42	0.34	0.35	0.32	0.30	0.41	0.20	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.50	N/A	N/A	N/A	N/A	N/A	N/A	+147	+109
(47) Regional (38 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	+160	+113

Nomenclature: See separate page