

MCENTIRE JNGB, SC, USA

WMO: 723105

Lat: 33.921N

Lon: 80.801W

Elev: 254

StdP: 14.56

Time Zone: -5.00 (NAE)

Period: 08-19

WBAN: 03858

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.8	25.6	4.1	6.8	31.6	9.0	8.8	34.7	22.4	53.6	19.8	54.0	3.3	310	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	96.4	75.7	94.2	75.6	92.1	75.3	79.1	89.8	78.2	88.5	77.4	87.3	8.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	140.7	81.7	75.7	135.8	81.1	75.0	132.5	80.6	42.6	90.1	41.7	88.6	40.9	87.7	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.4	15.9	12.8	DB	16.0	99.4	4.0	3.2	13.1	101.7	10.8	103.5	8.6	105.3	5.7	107.6
			WB	14.2	80.7	3.6	1.2	11.6	81.5	9.4	82.2	7.4	82.9	4.8	83.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.0	44.8	49.7	55.2	63.7	71.6	78.8	81.1	79.9	75.5	64.6	53.1	49.5	(6)
	DBStd	14.65	10.16	9.86	9.48	6.97	5.69	3.91	3.07	3.36	5.00	7.74	7.99	9.28	(7)
	HDD50	596	227	120	58	3	0	0	0	0	0	3	56	129	(8)
	HDD65	2467	627	435	324	106	17	0	0	0	2	102	365	489	(9)
	CDD50	5714	67	111	220	413	671	863	964	927	764	455	147	112	(10)
	CDD65	2112	2	6	21	66	223	413	499	462	316	90	7	7	(11)
	CDH74	20509	16	65	276	788	2166	4169	5093	4300	2732	831	56	17	(12)
	CDH80	9076	0	4	53	194	839	2010	2531	2011	1205	225	4	0	(13)
(14) Wind	WSAvg	5.1	5.6	6.1	6.4	6.1	5.4	4.7	4.6	4.1	4.5	4.6	4.6	5.1	(14)
(15) Precipitation	PrecAvg	42.2	2.1	3.4	3.3	2.7	3.4	4.9	4.9	4.9	3.5	2.9	2.5	3.5	(15)
	PrecMax	53.5	4.0	5.4	7.0	6.3	6.4	7.9	12.5	9.0	8.8	10.9	5.2	8.5	(16)
	PrecMin	30.8	1.1	1.9	0.6	0.8	0.7	1.8	1.9	2.2	0.2	0.2	0.3	1.0	(17)
	PrecStd	7.0	0.9	1.0	1.5	1.3	1.3	1.5	2.9	1.8	2.0	2.5	1.4	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.6	80.2	85.0	87.7	96.2	99.3	99.3	97.4	95.3	89.6	79.6	76.5	(19)
		MCWB	63.9	64.8	63.9	67.4	71.5	75.3	75.7	76.9	73.0	74.9	67.5	67.1	(20)
	2%	DB	70.4	75.7	81.2	85.1	90.8	95.4	96.5	94.4	92.5	85.5	75.1	72.4	(21)
		MCWB	60.0	62.5	63.8	66.6	70.5	75.9	76.5	76.1	73.3	70.4	62.9	65.3	(22)
	5%	DB	66.4	71.6	76.9	82.2	87.9	92.7	94.2	92.2	90.2	82.1	71.4	68.9	(23)
		MCWB	58.8	59.9	61.2	65.9	70.8	75.2	76.6	76.3	73.2	68.4	60.8	62.9	(24)
	10%	DB	62.0	67.1	72.3	78.8	84.8	90.2	91.6	89.9	87.3	78.6	68.0	65.4	(25)
		MCWB	55.7	57.4	59.3	64.3	69.9	74.6	76.5	75.6	72.7	67.1	60.5	61.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.0	67.5	67.8	73.2	75.7	79.4	80.4	80.3	78.1	77.2	69.6	70.6	(27)
		MCDB	69.9	74.6	76.7	80.8	83.9	91.3	92.8	90.1	87.0	81.7	73.4	73.0	(28)
	2%	WB	64.1	65.2	66.1	71.0	74.3	78.1	79.2	79.0	76.8	75.2	67.3	67.8	(29)
		MCDB	69.1	72.9	75.2	78.6	82.9	90.0	90.4	88.8	85.6	80.6	71.3	70.7	(30)
	5%	WB	61.1	62.6	64.4	69.0	73.1	77.1	78.3	78.1	75.6	73.2	65.3	64.7	(31)
		MCDB	64.4	68.8	72.9	76.9	81.8	88.7	89.0	87.4	84.1	77.9	68.9	67.2	(32)
	10%	WB	57.1	59.7	62.1	67.0	71.9	76.0	77.4	77.3	74.7	70.4	62.2	61.7	(33)
		MCDB	60.4	65.0	69.2	74.7	80.4	86.5	87.8	86.0	82.5	76.0	67.0	64.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.1	23.3	24.0	24.8	22.8	21.5	20.8	19.4	20.5	23.9	24.2	20.9	(35)
		MCDBR	26.3	28.0	29.0	28.9	27.3	24.9	24.4	23.0	24.9	26.2	27.5	23.2	(36)
		MCWBR	16.7	16.2	13.5	12.7	10.3	8.5	7.6	7.5	8.2	12.2	16.2	15.6	(37)
	5% WB	MCDBR	20.0	24.0	24.1	22.2	21.4	22.0	21.0	20.0	20.5	20.0	20.1	18.6	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.323	0.332	0.369	0.411	0.476	0.510	0.555	0.525	0.441	0.400	0.349	0.319	(40)
		taud	2.491	2.463	2.384	2.261	2.124	2.072	1.969	2.045	2.265	2.346	2.450	2.539	(41)
	Ebn at Noon	Ebn at Noon	282	291	287	279	260	250	238	243	260	263	269	277	(42)
		Edh at Noon	27	31	36	43	50	52	58	53	41	35	28	25	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	882	1083	1426	1794	1951	2028	1932	1754	1510	1265	969	772	(44)
	RadStd	RadStd	46	113	107	129	151	141	125	87	130	152	75	70	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (62 neighbors)	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+346	+243

Nomenclature: See separate page