

GREENWOOD COUNTY AP, SC, USA

WMO: 723124

Lat: 34.249N

Lon: 82.159W

Elev: 631

StdP: 14.36

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 53874

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.9	25.8	4.7	7.2	30.7	8.8	8.8	33.9	20.3	56.8	18.3	53.3	2.5	260	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	95.4	74.3	93.1	74.0	90.9	73.7	77.6	88.6	76.8	87.4	76.0	86.0	7.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.8	133.7	81.0	73.8	128.8	80.5	73.0	125.5	79.9	41.4	88.6	40.5	87.7	39.7	86.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	15.3	12.7	14.1	98.8	3.7	4.1	11.4	101.8	9.3	104.1	7.2	106.4	4.5	109.4
			12.6	79.2	3.5	1.2	10.1	80.1	8.0	80.8	6.1	81.5	3.6	82.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.5	43.7	46.8	54.1	62.5	70.1	77.5	80.2	79.4	73.7	62.7	52.2	46.4	(6)
	DBStd	14.90	9.78	8.68	9.00	7.50	6.29	4.33	3.53	3.96	5.22	7.65	8.07	8.60	(7)
	HDD50	720	248	153	62	6	0	0	0	0	0	5	68	178	(8)
	HDD65	2797	662	512	351	134	30	0	0	0	5	133	390	580	(9)
	CDD50	5290	52	63	190	380	623	824	937	910	712	400	134	65	(10)
	CDD65	1893	1	2	15	58	188	374	472	445	268	62	6	2	(11)
	CDH74	17360	4	9	139	593	1649	3562	4625	4106	2135	497	36	5	(12)
	CDH80	7303	0	0	17	126	543	1581	2198	1898	831	108	1	0	(13)
(14) Wind	WSAvg	5.4	6.1	6.4	6.5	6.7	5.7	5.0	4.9	4.2	4.6	4.8	4.9	5.5	(14)
(15) Precipitation	PrecAvg	46.0	4.6	4.3	5.0	3.5	3.6	3.9	4.1	3.7	3.4	3.1	3.4	3.7	(15)
	PrecMax	68.2	7.8	9.1	11.1	8.5	8.8	11.0	9.1	12.5	9.4	11.5	9.4	9.6	(16)
	PrecMin	28.7	0.7	0.6	0.4	0.5	0.4	0.6	0.4	0.2	0.2	0.0	0.7	0.6	(17)
	PrecStd	7.7	1.7	1.9	2.4	2.0	1.7	2.3	1.9	2.6	2.0	2.4	2.0	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.5	75.3	82.3	87.3	91.7	96.3	97.7	99.9	93.3	87.2	79.0	73.9	(19)
		MCWB	62.0	62.2	63.0	67.5	70.5	73.7	75.4	73.7	71.7	71.5	64.3	64.1	(20)
	2%	DB	67.2	69.8	78.0	83.5	88.7	93.7	95.3	95.3	90.8	82.6	74.0	69.2	(21)
		MCWB	58.8	57.4	61.4	65.1	70.0	73.8	75.0	73.9	71.8	68.3	61.6	62.2	(22)
	5%	DB	63.7	66.1	73.9	80.9	85.9	91.2	93.0	92.0	88.2	79.6	70.8	65.4	(23)
		MCWB	57.1	56.4	59.6	64.0	69.1	73.7	74.7	74.3	71.8	66.4	60.8	60.3	(24)
	10%	DB	59.7	62.4	70.0	77.4	82.7	88.5	90.6	89.5	85.1	76.0	66.9	61.7	(25)
		MCWB	53.6	53.6	57.2	62.5	68.4	72.9	74.4	74.6	71.2	65.2	58.7	56.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.8	65.3	66.1	70.4	74.4	77.8	78.5	78.9	76.5	74.9	69.6	67.8	(27)
		MCDB	69.9	71.0	75.7	81.6	84.0	89.5	90.4	88.6	86.2	81.0	72.9	70.7	(28)
	2%	WB	61.8	62.5	64.2	68.7	72.8	76.6	77.5	77.8	75.1	72.4	66.2	64.2	(29)
		MCDB	65.8	67.3	73.4	78.3	82.6	88.1	89.4	87.7	84.4	78.4	70.3	67.5	(30)
	5%	WB	58.6	59.1	62.4	66.9	71.4	75.4	76.8	76.8	74.0	70.3	63.7	61.2	(31)
		MCDB	62.6	63.9	70.5	75.5	81.1	86.3	88.1	86.4	82.7	75.6	67.9	64.3	(32)
	10%	WB	54.5	55.6	60.2	64.9	70.3	74.5	75.9	75.8	72.9	67.9	60.7	57.4	(33)
		MCDB	58.1	59.9	66.9	73.3	79.3	84.7	86.5	84.8	80.8	73.8	65.6	60.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.4	21.1	23.0	23.6	21.7	20.3	19.7	19.3	20.1	22.2	23.4	20.2	(35)
		MCDBR	23.1	24.6	26.6	26.0	24.4	23.6	22.9	23.4	24.2	24.7	26.6	21.9	(36)
		MCWBR	15.4	15.1	13.0	11.1	9.6	7.9	6.7	7.2	8.5	11.7	15.3	15.2	(37)
	5% WB	MCDBR	19.4	19.3	21.6	21.8	20.4	19.9	19.5	18.8	19.2	18.4	19.1	18.4	(38)
		MCWBR	15.2	14.6	12.3	11.1	8.8	7.7	6.8	6.7	7.5	10.3	13.4	14.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.318	0.326	0.364	0.400	0.459	0.490	0.537	0.522	0.429	0.392	0.345	0.315	(40)
	taud		2.498	2.473	2.394	2.287	2.161	2.121	2.011	2.040	2.282	2.356	2.448	2.537	(41)
	Ebn at Noon		283	293	288	281	265	256	243	244	264	265	270	278	(42)
	Edh at Noon		27	30	36	42	48	50	56	53	40	34	28	24	(43)
(44) All-Sky Solar Radiation	RadAvg		866	1064	1408	1764	1946	2039	1925	1765	1519	1265	956	745	(44)
	RadStd		47	120	99	126	153	146	125	85	134	149	83	73	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (47 neighbors)	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+311	+211

Nomenclature: See separate page