

GREENWOOD COUNTY AP, SC, USA

WMO: 723124

Lat: 34.249N

Lon: 82.159W

Elev: 192

StdP: 99.04

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 53874

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.6	(c) -3.4	(d) -15.1	(e) 1.0	(f) -0.7	(g) -12.9	(h) 1.3	(i) 1.0	(j) 9.1	(k) 13.8	(l) 8.2	(m) 11.8	(n) 1.1	(o) 260	(p) 0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	35.2	23.5	33.9	23.3	32.7	23.2	25.3	31.5	24.9	30.8	24.4	30.0	3.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.8	19.1	27.2	23.2	18.4	26.9	22.8	17.9	26.6	78.4	31.5	76.3	30.9	74.4	30.1	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.8	6.8	5.7	-10.0	37.1	2.0	2.3	-11.4	38.8	-12.6	40.1	-13.8	41.4	-15.3	43.0
			-10.8	26.2	1.9	0.7	-12.2	26.7	-13.3	27.1	-14.4	27.5	-15.8	28.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	6.5	8.2	12.3	16.9	21.2	25.3	26.8	26.3	23.2	17.1	11.2	8.0
	DBStd	8.28	5.43	4.82	5.00	4.17	3.50	2.41	1.96	2.20	2.90	4.25	4.48	4.78
	HDD10.0	400	138	85	34	3	0	0	0	0	0	3	38	99
	HDD18.3	1554	368	284	195	74	17	0	0	0	3	74	217	322
	CDD10.0	2939	29	35	106	211	346	458	521	506	396	222	74	36
	CDD18.3	1052	1	1	8	32	104	208	262	247	149	34	3	1
	CDH23.3	9644	2	5	77	329	916	1979	2569	2281	1186	276	20	3
	CDH26.7	4057	0	0	9	70	302	878	1221	1054	462	60	1	0
Wind	WSAvg	2.4	2.7	2.8	2.9	3.0	2.5	2.2	2.2	1.9	2.1	2.1	2.2	2.4
Precipitation	PrecAvg	1169	117	108	127	89	91	100	103	94	87	80	87	93
	PrecMax	1732	197	232	281	216	224	280	231	318	240	292	240	245
	PrecMin	729	19	16	9	13	9	16	11	4	5	0	18	14
	PrecStd	196	44	47	60	52	43	58	48	66	52	62	52	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.5	24.1	27.9	30.7	33.2	35.7	36.5	37.7	34.1	30.7	26.1	23.3
		MCWB	16.7	16.8	17.2	19.7	21.4	23.2	24.1	23.2	22.0	21.9	18.0	17.9
	2%	DB	19.6	21.0	25.6	28.6	31.5	34.3	35.1	35.1	32.7	28.1	23.3	20.6
		MCWB	14.9	14.1	16.3	18.4	21.1	23.2	23.9	23.3	22.1	20.1	16.5	16.8
	5%	DB	17.6	19.0	23.3	27.1	30.0	32.9	33.9	33.3	31.2	26.5	21.6	18.6
		MCWB	13.9	13.6	15.3	17.8	20.6	23.2	23.7	23.5	22.1	19.1	16.0	15.7
	10%	DB	15.4	16.9	21.1	25.2	28.1	31.4	32.6	31.9	29.5	24.4	19.4	16.5
		MCWB	12.0	12.0	14.0	16.9	20.2	22.7	23.6	23.7	21.8	18.5	14.8	13.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.2	18.5	18.9	21.3	23.6	25.4	25.8	26.0	24.7	23.8	20.9	19.9
		MCDB	21.1	21.7	24.3	27.6	28.9	32.0	32.4	31.4	30.1	27.2	22.7	21.5
	2%	WB	16.5	16.9	17.9	20.4	22.6	24.8	25.3	25.4	23.9	22.5	19.0	17.9
		MCDB	18.8	19.6	23.0	25.7	28.1	31.2	31.9	30.9	29.1	25.8	21.3	19.7
	5%	WB	14.8	15.0	16.9	19.4	21.9	24.1	24.9	24.9	23.3	21.3	17.6	16.2
		MCDB	17.0	17.7	21.4	24.2	27.3	30.2	31.2	30.2	28.1	24.2	20.0	18.0
	10%	WB	12.5	13.1	15.7	18.3	21.3	23.6	24.4	24.4	22.7	20.0	15.9	14.1
		MCDB	14.5	15.5	19.4	22.9	26.3	29.3	30.3	29.3	27.1	23.2	18.6	16.0
Mean Daily Temperature Range	5% DB	MDBR	11.4	11.7	12.8	13.1	12.0	11.3	11.0	10.7	11.1	12.3	13.0	11.2
		MCDBR	12.8	13.7	14.8	14.4	13.6	13.1	12.7	13.0	13.4	13.7	14.8	12.1
		MCWBR	8.6	8.4	7.2	6.2	5.3	4.4	3.7	4.0	4.7	6.5	8.5	8.4
	5% WB	MCDBR	10.8	10.7	12.0	12.1	11.3	11.0	10.8	10.4	10.7	10.2	10.6	10.2
		MCWBR	8.4	8.1	6.9	6.2	4.9	4.3	3.8	3.7	4.2	5.7	7.5	8.1
Clear-Sky Solar Irradiance	taub	0.318	0.326	0.364	0.400	0.459	0.490	0.537	0.522	0.429	0.392	0.345	0.315	
	taud	2.498	2.473	2.394	2.287	2.161	2.121	2.011	2.040	2.282	2.356	2.448	2.537	
	Ebn at Noon	893	923	909	887	835	806	765	769	832	835	850	876	
	Edh at Noon	84	96	113	132	151	157	175	167	125	107	88	77	
All-Sky Solar Radiation	RadAvg	2.73	3.35	4.44	5.56	6.13	6.43	6.07	5.56	4.79	3.99	3.02	2.35	
	RadStd	0.15	0.38	0.31	0.40	0.48	0.46	0.39	0.27	0.42	0.47	0.26	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (47 neighbors)	+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+173	+117

Nomenclature: See separate page