

FRISCO MITCHELL, NC, USA

WMO: 723139

Lat: 35.233N

Lon: 75.622W

Elev: 11

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93729

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	30.8	10.5	9.4	31.7	15.1	11.8	34.6	28.0	61.0	25.0	57.3	8.6	320	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	87.9	78.2	86.5	77.7	85.3	77.1	80.5	84.8	79.8	84.0	78.9	83.1	9.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	152.0	83.2	78.3	147.2	82.6	77.4	142.8	82.1	44.1	85.4	43.1	84.1	42.3	83.2	
(p)															

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.2	20.3	18.3	DB	22.3	90.8	4.5	2.9	19.1	92.9	16.5	94.6	14.0	96.2	10.8	98.4
			WB	19.7	82.0	3.9	1.3	16.9	82.9	14.6	83.6	12.4	84.3	9.6	85.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.7	46.4	47.9	52.4	60.9	68.6	76.4	79.8	79.5	75.5	67.1	57.3	51.3
	DBStd	13.69	9.36	8.17	7.73	6.81	5.88	4.29	2.91	3.13	4.22	6.83	7.52	8.56
	HDD50	487	183	125	64	4	0	0	0	0	0	0	21	90
	HDD65	2381	578	480	394	157	33	1	0	0	1	58	249	430
	CDD50	5481	70	66	140	331	578	792	925	915	766	529	239	130
	CDD65	1899	1	1	4	34	146	344	460	450	316	121	17	5
	CDH74	14410	0	0	1	56	536	2581	4420	4234	2072	486	18	6
	CDH80	3108	0	0	0	2	46	485	1094	1090	345	43	0	3
(14) Wind	WSAvg	9.3	9.6	9.9	10.3	10.7	9.7	9.2	8.8	8.1	9.0	8.7	8.8	9.3
(15) Precipitation	PrecAvg	57.4	5.8	4.3	4.4	3.4	3.9	4.4	5.3	6.2	5.5	4.8	4.5	4.7
	PrecMax	90.8	12.4	9.7	11.2	9.9	11.7	12.6	12.0	14.0	20.0	13.1	14.3	10.8
	PrecMin	29.4	1.9	1.1	0.7	0.3	0.5	0.9	1.0	0.6	0.3	0.6	0.9	0.7
	PrecStd	10.9	2.6	1.9	2.6	2.0	2.8	2.5	2.8	3.7	3.5	3.1	2.9	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.9	70.6	72.6	78.8	83.9	88.3	89.8	89.5	87.6	84.1	76.3	72.9
		MCWB	64.9	64.5	65.2	70.2	74.1	77.3	78.7	79.2	77.1	75.9	70.4	69.0
	2%	DB	66.2	66.6	69.5	75.4	81.0	86.1	87.8	87.9	85.3	80.8	73.5	70.0
		MCWB	62.9	62.2	64.1	67.8	72.2	76.9	78.4	78.5	76.4	73.8	69.2	66.1
	5%	DB	63.9	63.8	67.1	73.1	79.0	84.3	86.4	86.5	83.5	78.7	71.2	67.6
		MCWB	60.5	60.0	62.1	66.5	71.2	76.0	77.9	77.9	75.7	72.7	66.6	64.1
	10%	DB	61.1	61.1	64.8	70.7	77.1	82.8	85.0	85.1	82.0	76.9	68.9	65.0
		MCWB	58.0	57.2	60.3	65.0	70.3	75.3	77.4	77.2	75.3	71.4	64.8	61.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.0	66.1	67.5	72.2	76.5	80.2	81.8	82.2	80.3	78.0	72.8	70.2
		MCDB	67.9	69.1	70.4	75.9	81.4	84.7	86.5	86.1	82.8	81.2	75.0	73.0
	2%	WB	63.8	63.6	65.2	69.9	74.5	78.5	80.4	80.7	78.8	76.1	70.3	66.9
		MCDB	65.8	66.0	68.3	73.6	78.8	83.4	84.9	85.1	82.5	79.4	72.7	69.0
	5%	WB	61.2	60.7	63.5	68.0	73.0	77.6	79.7	79.9	77.8	74.4	67.6	64.6
		MCDB	63.5	63.3	66.4	71.9	77.1	82.5	84.0	84.2	81.8	77.7	70.3	66.9
	10%	WB	58.3	57.6	61.0	66.0	71.6	76.7	78.8	78.9	76.7	72.3	65.3	62.0
		MCDB	60.8	60.7	64.4	69.8	75.6	81.4	83.1	83.3	80.8	75.7	68.1	64.7
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	13.2	13.0	12.4	11.6	10.6	9.9	10.2	10.0	11.6	12.2	12.0
		MCDBR	15.6	15.2	14.8	13.1	12.4	11.7	10.8	10.9	11.0	11.5	13.3	13.6
		MCWBR	14.2	13.2	11.5	8.3	7.1	6.1	5.5	5.4	5.8	7.1	10.4	12.2
	5% WB	MCDBR	14.1	14.9	13.0	11.1	10.5	10.0	9.5	9.4	9.2	9.7	12.1	13.1
		MCWBR	13.9	14.1	11.4	8.5	6.7	5.8	5.7	5.4	6.0	7.8	11.1	12.8
(40) Clear-Sky Solar Irradiance	taub		0.333	0.339	0.361	0.403	0.445	0.484	0.510	0.496	0.424	0.372	0.345	0.340
	taud		2.529	2.510	2.467	2.355	2.277	2.217	2.155	2.188	2.393	2.514	2.540	2.530
	Ebn at Noon		276	287	289	280	268	257	249	250	265	272	269	266
	Edh at Noon		26	29	33	39	43	45	48	46	36	29	25	24
(44) All-Sky Solar Radiation	RadAvg		760	1007	1346	1719	1939	2033	1896	1745	1446	1188	859	691
	RadStd		49	106	107	134	134	101	112	115	89	113	60	53

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+275	+160
(47) Regional (29 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+292	+196

Nomenclature: See separate page