

MOORE COUNTY AP, NC, USA

WMO: 723143

Lat: 35.237N

Lon: 79.391W

Elev: 141

StdP: 99.65

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03720

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.4	-5.1	-18.9	0.7	-1.3	-16.1	0.9	0.1	9.1	14.6	8.3	13.9	1.1	20	0.407

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	35.1	24.1	33.7	23.5	32.5	23.3	25.6	32.1	25.1	31.2	24.5	30.1	3.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.1	27.8	23.2	18.3	27.3	22.8	17.8	27.0	79.4	32.1	76.9	31.2	74.7	30.3	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	7.0	5.8	DB	-12.0	38.0	2.7	3.1	-13.9	40.2	-15.4	42.0	-16.9	43.7	-18.9	45.9	(4)
(5)			WB	-12.5	26.3	2.7	0.9	-14.5	26.9	-16.0	27.4	-17.6	27.9	-19.5	28.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	5.5	7.2	11.0	16.2	20.8	24.7	26.5	25.7	22.4	16.4	10.5	7.2	(6)	
	DBStd	8.67	6.01	5.44	5.27	4.64	3.98	3.07	2.22	2.61	3.26	4.58	4.98	5.33	(7)	
	HDD10.0	516	166	111	53	6	0	0	0	0	0	5	53	123	(8)	
	HDD18.3	1750	399	313	235	94	23	2	0	0	6	92	237	348	(9)	
	CDD10.0	2786	26	32	82	192	334	441	513	487	372	203	69	35	(10)	
	CDD18.3	980	1	2	6	31	99	193	254	228	129	32	3	2	(11)	
	CDH23.3	9084	1	10	61	298	917	1858	2493	2140	1022	259	21	4	(12)	
	CDH26.7	3746	0	1	7	68	321	823	1156	946	365	58	1	0	(13)	
(14) Wind	WSAvg	2.5	2.6	2.7	2.9	3.3	2.7	2.5	2.3	2.0	2.3	2.1	2.2	2.3	(14)	
(15) Precipitation	PrecAvg	1188	94	84	105	81	78	116	130	127	128	84	79	81	(15)	
	PrecMax	1582	170	163	186	155	184	317	224	253	376	232	213	172	(16)	
	PrecMin	837	22	41	31	26	32	20	48	32	33	0	19	39	(17)	
	PrecStd	164	45	36	41	34	35	72	55	49	82	60	52	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.4	24.9	27.5	30.9	34.0	36.4	37.0	37.2	33.8	30.9	26.0	23.6	(19)	
		MCWB	16.4	17.6	17.1	19.1	21.9	23.5	24.7	24.3	22.1	23.0	18.5	18.0	(20)	
	2%	DB	19.9	21.9	25.0	28.7	32.2	34.1	34.9	34.6	32.3	27.9	23.0	21.1	(21)	
		MCWB	15.4	15.0	16.1	18.5	21.3	23.0	24.6	24.0	22.3	20.2	16.6	17.0	(22)	
	5%	DB	17.6	18.9	22.6	27.1	30.1	32.7	33.5	32.8	30.9	26.2	21.4	18.7	(23)	
		MCWB	13.9	13.7	14.5	17.3	20.8	22.9	24.1	23.8	22.3	19.2	16.1	15.9	(24)	
	10%	DB	15.9	17.1	20.0	24.8	28.0	31.3	32.3	32.0	28.8	24.0	19.0	16.4	(25)	
		MCWB	12.1	12.0	13.2	16.6	19.9	22.5	23.9	23.6	21.5	18.7	15.2	12.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.3	19.0	19.0	21.9	24.0	25.5	26.7	26.2	25.2	24.3	20.8	19.7	(27)	
		MCDB	20.6	22.8	24.6	25.6	29.3	32.4	33.8	32.8	30.0	27.3	22.8	21.8	(28)	
	2%	WB	16.5	17.0	17.4	20.2	22.8	24.7	25.7	25.5	24.2	22.9	18.8	17.8	(29)	
		MCDB	19.2	20.0	22.0	25.4	28.5	31.3	32.4	31.9	29.1	26.4	21.6	19.8	(30)	
	5%	WB	14.8	14.9	16.4	19.0	22.0	24.0	25.2	25.0	23.5	21.2	17.3	15.8	(31)	
		MCDB	17.3	18.5	20.8	24.5	27.8	30.2	31.6	30.8	28.1	24.4	19.9	18.1	(32)	
	10%	WB	12.3	12.4	14.9	17.9	21.2	23.4	24.6	24.3	22.7	19.7	15.6	13.6	(33)	
		MCDB	15.0	15.7	19.1	22.9	26.3	29.2	30.5	29.4	26.8	23.3	18.9	16.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	11.9	12.7	12.8	12.1	11.3	10.7	10.6	10.8	12.3	12.8	11.3	(35)	
		MCDBR	13.4	14.4	15.0	14.5	13.6	13.1	12.1	12.2	12.9	13.7	14.1	12.6	(36)	
	5% WB	MCWBR	9.5	9.6	8.1	6.6	5.2	4.6	4.5	4.3	5.4	7.3	9.1	9.0	(37)	
		MCWBR	11.5	13.3	12.4	11.9	11.3	11.2	10.9	10.8	10.2	9.8	11.4	10.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.315	0.327	0.362	0.401	0.457	0.490	0.539	0.515	0.426	0.388	0.334	0.312	(40)	
		taud	2.500	2.458	2.395	2.283	2.169	2.113	1.998	2.054	2.297	2.371	2.485	2.541	(41)	
	Ebn at Noon	Ebn at Noon	890	917	908	884	836	805	762	773	831	835	858	872	(42)	
		Edh at Noon	83	97	112	132	150	158	177	164	122	105	84	76	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.63	3.29	4.36	5.47	6.03	6.38	6.03	5.47	4.63	3.78	2.89	2.28	(44)	
	RadStd	RadStd	0.16	0.39	0.32	0.39	0.48	0.45	0.38	0.26	0.40	0.49	0.23	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (67 neighbors)		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+154	+112	(47)	

Nomenclature: See separate page