

BACON COUNTY AP, GA, USA

WMO: 723160

Lat: 31.536N

Lon: 82.507W

Elev: 193

StdP: 14.59

Time Zone: -5.00 (NAE)

Period: 00-19

WBAN: 13870

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.1	30.2	10.7	9.6	36.8	15.8	12.3	39.1	20.5	52.7	18.5	52.4	2.8	310	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	95.9	75.9	94.0	75.6	92.3	75.2	79.2	89.9	78.3	88.7	77.6	87.7	6.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.4	138.6	83.0	75.5	134.3	82.1	74.9	131.9	81.5	42.6	90.0	41.8	89.0	41.0	87.8	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.9	14.4	12.1	DB	21.8	99.0	3.4	3.2	19.3	101.3	17.4	103.1	15.4	104.9	13.0	107.2
			WB	19.5	80.8	3.3	1.2	17.2	81.7	15.3	82.4	13.4	83.1	11.1	84.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	50.6	54.2	59.9	66.7	74.1	80.0	82.0	81.8	77.7	68.6	58.8	53.4	(6)
	DBStd	13.10	9.66	8.76	8.19	6.41	5.17	3.04	2.58	2.65	4.06	7.04	7.95	9.32	(7)
	HDD50	269	115	50	16	1	0	0	0	0	0	1	16	70	(8)
	HDD65	1667	453	317	198	56	5	0	0	0	1	46	218	373	(9)
	CDD50	6610	133	166	322	501	746	901	991	985	831	578	279	177	(10)
	CDD65	2533	6	13	38	107	286	451	526	520	382	158	31	15	(11)
	CDH74	23856	40	96	380	1148	2862	4364	5282	4998	3192	1210	219	65	(12)
	CDH80	10320	1	8	64	323	1206	2087	2577	2350	1347	330	25	2	(13)
(14) Wind	WSAvg	4.6	5.3	5.3	5.6	5.3	4.9	4.4	4.1	3.7	3.8	4.0	4.3	4.8	(14)
(15) Precipitation	PrecAvg	46.7	3.7	3.7	4.4	2.8	2.9	5.4	5.2	5.7	4.3	3.1	2.3	3.0	(15)
	PrecMax	61.2	14.1	9.4	10.4	7.8	6.8	8.8	9.3	9.7	14.7	10.0	6.5	7.6	(16)
	PrecMin	34.4	0.5	0.6	0.2	0.2	0.5	1.8	0.8	2.6	0.8	0.2	0.0	0.3	(17)
	PrecStd	8.0	2.7	2.0	2.6	1.8	1.6	2.0	2.2	1.6	2.6	2.6	1.8	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.6	81.3	84.8	89.7	95.4	97.8	97.6	98.2	94.9	90.2	82.8	79.3	(19)
		MCWB	66.4	67.1	66.4	69.5	71.7	74.2	76.7	76.8	73.4	74.7	68.9	67.6	(20)
	2%	DB	74.2	77.1	81.8	86.6	91.9	94.8	95.3	95.2	91.9	86.6	79.9	75.7	(21)
		MCWB	64.0	64.3	65.4	68.2	70.9	75.1	76.5	77.1	74.1	71.9	67.3	65.8	(22)
	5%	DB	70.1	73.2	78.5	83.8	89.6	92.6	93.5	93.0	90.0	83.8	76.3	72.1	(23)
		MCWB	61.8	62.1	64.0	66.7	70.5	74.7	76.2	76.7	74.0	69.9	65.4	65.5	(24)
	10%	DB	66.2	69.4	75.0	81.1	87.0	90.4	91.5	90.9	87.8	81.2	73.0	68.7	(25)
		MCWB	60.1	60.0	61.9	65.2	70.0	74.4	76.1	76.5	73.9	68.9	64.4	63.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.5	69.2	70.4	73.2	75.9	79.4	80.4	80.4	78.4	77.0	74.2	71.4	(27)
		MCDB	74.3	76.5	78.2	83.1	86.2	90.9	91.1	91.8	87.5	84.9	78.4	74.8	(28)
	2%	WB	66.2	67.2	68.3	71.4	74.4	78.1	79.1	79.2	77.4	75.3	71.4	68.9	(29)
		MCDB	71.0	73.8	76.5	81.0	84.4	89.1	90.3	89.5	86.4	81.7	74.7	72.1	(30)
	5%	WB	64.2	64.9	66.5	69.7	73.3	77.1	78.2	78.3	76.5	73.7	69.1	66.7	(31)
		MCDB	68.7	71.2	74.3	79.0	83.0	87.5	89.0	88.3	84.8	79.9	73.9	70.8	(32)
	10%	WB	61.7	62.4	64.6	68.1	72.2	76.2	77.4	77.7	75.6	72.2	66.2	64.2	(33)
		MCDB	66.4	67.5	71.9	76.6	81.9	85.8	87.8	87.4	83.3	77.9	71.5	68.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.9	22.3	23.7	24.6	23.5	20.2	19.7	18.9	19.2	21.9	23.7	21.3	(35)
		MCDBR	24.1	24.9	26.8	27.4	26.1	23.4	22.1	21.7	22.3	23.2	24.9	22.1	(36)
	5% WB	MCWBR	15.0	14.3	12.4	11.0	8.6	7.4	6.8	6.7	7.7	10.2	13.4	13.8	(37)
		MCWBR	20.3	20.8	21.4	22.2	20.9	19.4	19.4	19.0	17.8	17.7	18.0	18.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.327	0.333	0.371	0.389	0.431	0.478	0.511	0.504	0.425	0.380	0.348	0.332	(40)
		taud	2.509	2.491	2.405	2.350	2.269	2.199	2.110	2.131	2.346	2.440	2.478	2.522	(41)
	Edn at Noon		285	294	289	286	274	259	250	250	268	274	275	277	(42)
		Edh at Noon	28	31	36	40	43	46	50	49	38	32	28	26	(43)
(44) All-Sky Solar Radiation	RadAvg		954	1147	1505	1844	2024	1954	1937	1759	1533	1332	1059	832	(44)
	RadStd		56	128	139	137	113	130	120	113	122	127	74	75	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+391	+281	(46)
(47)	Regional (33 neighbors)	+0.95	+1.33	N/A	N/A	N/A	N/A	N/A	-142	+313	+220	(47)

Nomenclature: See separate page