

EDWARDS AFB NORTH, CA, USA

WMO: 723171

Lat: 34.988N

Lon: 117.865W

Elev: 2283

StdP: 13.52

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 53144

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	19.8	23.5	-9.8	3.5	37.0	-4.9	4.6	41.5	32.1	50.5	28.4	51.1	1.6	350	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.2	105.3	64.3	102.8	63.5	100.5	62.7	68.2	94.5	66.8	94.5	65.3	94.3	12.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.3	82.0	80.2	55.4	71.1	80.0	52.6	64.0	77.5	33.6	93.5	32.4	95.2	31.2	93.9	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.7	26.1	23.8	DB	15.1	109.6	3.7	2.5	12.4	111.4	10.2	112.8	8.2	114.2	5.5	116.0	(4)
(5)			WB	10.8	70.5	5.0	1.4	7.2	71.5	4.3	72.3	1.5	73.1	-2.2	74.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.7	44.1	48.4	53.7	60.1	67.9	78.2	84.6	82.4	74.1	62.7	51.8	43.1		
	DBStd	15.39	5.56	6.41	6.22	6.66	6.85	6.60	4.33	4.05	6.29	5.99	6.40	6.23		
	HDD50	612	192	98	34	3	0	0	0	0	0	1	55	229		
	HDD65	2887	647	464	351	175	50	4	0	0	8	115	395	678		
	CDD50	5239	10	54	149	306	555	845	1073	1003	723	395	110	16		
	CDD65	2041	0	1	2	28	140	399	608	538	281	44	0	0		
	CDH74	31554	0	26	176	789	2351	6008	8814	7821	4367	1080	122	0		
	CDH80	18634	0	2	24	271	1139	3680	5657	4938	2517	394	12	0		
(14) Wind	WSAvg	8.7	5.5	7.8	9.7	11.4	11.9	11.5	10.5	9.3	7.7	7.1	5.8	6.1		
(15) Precipitation	PrecAvg	5.7	1.1	1.4	0.6	0.3	0.1	0.0	0.2	0.1	0.2	0.3	0.3	0.8		
	PrecMax	13.0	5.9	6.0	2.3	1.0	0.9	0.5	0.9	0.4	1.3	2.0	1.1	3.6		
	PrecMin	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	3.4	1.5	1.5	0.6	0.3	0.2	0.1	0.2	0.2	0.4	0.5	0.3	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.6	77.6	83.0	91.2	98.5	107.7	109.2	106.2	102.1	92.8	81.7	70.1		
		MCWB	48.0	51.5	53.9	57.5	60.5	63.8	65.6	64.7	63.3	59.4	53.5	50.5		
	2%	DB	65.0	73.1	78.8	87.1	94.2	103.4	106.3	103.5	99.3	88.4	77.9	64.1		
		MCWB	45.8	49.7	52.5	55.4	58.7	62.3	65.2	63.6	62.1	57.5	51.6	48.5		
	5%	DB	62.0	69.1	74.9	82.7	91.1	100.3	103.7	101.5	97.0	84.4	73.3	60.5		
		MCWB	45.2	48.3	51.0	54.1	57.7	61.5	64.5	62.9	61.2	55.5	50.3	46.2		
	10%	DB	58.3	64.5	70.7	78.4	86.9	97.0	100.9	99.3	93.7	80.6	68.5	56.7		
		MCWB	44.8	47.1	49.6	52.6	56.4	60.8	63.4	62.5	59.8	54.3	48.1	44.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.8	55.3	56.1	60.2	62.7	66.9	70.2	69.2	68.1	63.6	55.6	54.2		
		MCDB	61.2	63.7	74.7	83.5	92.8	99.6	96.4	92.1	92.9	80.8	72.4	62.8		
	2%	WB	50.4	52.1	54.2	57.4	60.2	65.1	68.7	67.4	65.4	60.7	53.4	51.6		
		MCDB	58.6	65.4	73.2	80.4	89.2	97.7	94.9	95.5	91.9	80.0	72.0	60.5		
	5%	WB	48.3	50.2	52.8	55.4	59.0	63.6	67.5	65.9	63.0	58.5	51.6	49.3		
		MCDB	56.5	64.4	71.3	77.8	87.0	95.3	94.1	95.6	90.9	77.5	69.3	56.9		
	10%	WB	46.1	48.7	50.9	53.8	57.5	62.0	66.1	64.3	61.3	56.4	49.9	46.4		
		MCDB	55.4	62.0	67.5	74.9	84.0	92.5	93.5	94.5	89.6	75.1	66.0	55.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	28.5	28.9	29.3	30.8	31.1	34.0	32.2	34.3	35.6	33.5	32.7	26.8		
		MCDBR	35.7	38.6	38.3	38.8	38.0	38.2	36.2	36.9	38.8	39.8	39.6	32.1		
		MCWBR	20.5	19.7	17.7	16.5	14.3	13.2	12.1	13.0	14.9	18.1	21.2	18.9		
	5% WB	MCDBR	25.2	29.8	32.4	33.2	35.7	36.3	29.4	31.6	33.1	30.9	32.9	24.4		
		MCWBR	16.0	15.5	15.5	14.6	13.5	12.5	10.6	12.6	13.4	13.6	17.7	15.6		
(40) Clear-Sky Solar Irradiance	taub		0.273	0.283	0.296	0.319	0.334	0.330	0.352	0.340	0.324	0.302	0.277	0.275		
	taud		2.544	2.533	2.485	2.423	2.402	2.426	2.410	2.422	2.461	2.511	2.556	2.551		
	Ebn at Noon		301	308	311	306	301	300	293	296	297	297	297	292		
	Edh at Noon		25	28	32	36	38	37	37	36	33	29	24	23		
(44) All-Sky Solar Radiation	RadAvg		981	1281	1748	2167	2451	2668	2506	2350	2004	1511	1121	893		
	RadStd		73	127	87	89	105	103	107	65	49	80	46	65		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	+1.10	N/A	-3.42	+1.10	N/A	N/A	N/A	-202	+392	+187

Nomenclature: See separate page