

ANDERSON, SC, USA

WMO: 723190

Lat: 34.498N

Lon: 82.710W

Elev: 760

StdP: 14.30

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93846

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.9	25.8	4.7	7.2	31.7	9.0	9.0	34.1	23.2	45.2	20.5	46.1	4.3	270	0.407

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	94.9	74.1	92.8	73.6	90.6	73.3	77.3	88.3	76.4	86.8	75.5	85.3	8.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.4	132.1	80.7	73.3	127.5	79.8	72.7	124.7	79.3	41.1	88.5	40.2	86.6	39.4	85.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	17.2	15.3		14.5	98.3	4.0	3.4	11.6	100.7	9.2	102.7	7.0	104.6	4.0	107.1
			DB	12.8	79.1	3.6	1.6	10.2	80.2	8.1	81.2	6.1	82.1	3.5	83.2
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.1	43.0	46.7	53.5	61.7	69.7	77.0	79.9	79.1	73.3	62.6	52.1	45.7
	DBStd	14.78	9.19	8.47	8.42	6.98	5.97	4.39	3.45	3.72	5.42	7.22	7.67	8.35
	HDD50	731	257	151	62	5	0	0	0	0	0	4	65	187
	HDD65	2858	682	515	362	143	28	1	0	0	7	130	392	598
	CDD50	5149	39	58	172	354	612	809	926	903	700	395	127	54
	CDD65	1802	0	1	7	43	175	359	461	438	257	56	4	1
	CDH74	16535	1	6	95	486	1561	3353	4508	4047	2022	429	25	2
	CDH80	6789	0	0	11	95	494	1454	2080	1805	764	85	1	0
Wind	WSAvg	6.0	6.7	7.0	7.3	7.0	6.1	5.5	5.2	4.8	5.3	5.3	5.3	6.0
Precipitation	PrecAvg	48.1	4.5	3.8	5.5	3.8	4.4	3.5	4.4	3.4	4.1	3.1	3.3	4.1
	PrecMax	67.8	7.2	6.8	10.9	9.4	8.7	9.0	10.3	7.0	11.7	7.5	5.1	10.2
	PrecMin	32.3	0.6	0.7	1.9	0.4	0.9	0.6	1.1	0.7	0.4	0.1	1.3	0.6
	PrecStd	8.3	1.8	1.7	3.0	2.3	2.1	2.0	2.6	2.0	3.0	2.0	1.1	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.4	74.1	81.5	86.1	91.4	96.4	97.3	98.8	93.8	86.5	77.6	72.3
		MCWB	60.4	60.4	62.2	66.7	70.9	73.7	74.5	73.5	71.1	71.0	63.7	61.8
	2%	DB	65.7	69.2	76.6	82.7	88.2	93.3	94.6	94.8	90.7	81.9	72.9	67.8
		MCWB	57.4	57.3	60.5	64.9	70.0	73.2	74.8	74.2	71.2	67.2	60.8	60.6
	5%	DB	62.3	65.2	72.6	80.0	85.6	90.8	92.5	91.5	87.9	79.0	69.8	63.5
		MCWB	55.7	55.4	58.2	63.3	69.3	72.9	74.7	74.0	71.0	65.4	59.5	57.1
	10%	DB	58.0	61.4	68.8	76.3	82.3	88.2	90.1	89.1	84.5	75.3	65.9	59.7
		MCWB	51.6	52.6	56.4	61.5	67.7	72.1	74.3	73.6	70.2	64.1	58.3	54.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.1	64.7	66.0	70.4	74.8	77.9	78.6	78.3	76.1	73.7	68.7	66.3
		MCDB	67.0	70.1	74.0	81.1	85.1	89.9	90.5	89.7	85.7	80.7	71.4	68.9
	2%	WB	60.5	61.7	63.5	68.2	72.9	76.3	77.4	77.2	74.7	71.2	65.2	62.3
		MCDB	63.9	66.4	72.0	77.9	83.0	87.6	88.7	87.5	83.7	77.7	69.4	65.6
	5%	WB	56.9	58.3	61.5	66.2	71.3	75.1	76.6	76.1	73.4	69.0	62.5	59.1
		MCDB	60.8	62.9	69.0	74.7	81.0	85.7	87.2	85.9	81.5	74.9	66.6	62.6
	10%	WB	53.0	54.7	59.1	64.3	69.8	74.0	75.6	75.2	72.4	66.9	59.7	54.8
		MCDB	56.4	59.0	65.9	72.2	78.7	83.7	85.7	84.4	79.7	72.7	64.6	58.3
Mean Daily Temperature Range	5% DB	MDBR	19.4	20.0	22.0	23.0	21.4	19.9	19.1	18.6	18.9	21.0	21.5	18.7
		MCDBR	23.0	24.5	26.7	27.4	24.8	23.8	22.5	22.8	23.5	24.2	25.7	22.5
		MCWBR	15.8	15.2	13.9	12.0	9.6	7.6	6.8	6.6	7.7	11.2	14.4	14.9
	5% WB	MCDBR	18.8	19.4	22.1	21.5	20.3	19.9	19.5	18.6	17.9	18.2	18.3	18.1
		MCWBR	15.2	14.6	13.7	11.3	8.9	7.6	7.1	6.5	7.5	10.3	13.8	14.1
Clear-Sky Solar Irradiance	taub	0.313	0.322	0.358	0.395	0.457	0.484	0.528	0.519	0.421	0.383	0.339	0.309	
	taud	2.508	2.480	2.407	2.298	2.161	2.132	2.029	2.039	2.294	2.380	2.459	2.547	
	Ebn at Noon	285	294	290	283	265	257	245	245	266	268	272	280	
	Edh at Noon	26	30	35	41	48	49	54	53	39	33	28	24	
All-Sky Solar Radiation	RadAvg	855	1052	1395	1746	1933	2036	1919	1767	1517	1262	948	732	
	RadStd	49	125	94	120	148	147	122	88	137	146	91	73	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+1.03	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+279	+178
Regional (48 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+299	+207

Nomenclature: See separate page