

ROME RUSSELL, GA, USA

WMO: 723200

Lat: 34.348N

Lon: 85.161W

Elev: 639

StdP: 14.36

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93801

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.4	23.4	5.0	7.3	26.9	9.3	9.1	30.9	18.9	40.6	17.2	42.0	3.9	340	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	95.8	74.4	93.3	74.0	91.2	73.9	78.2	88.9	77.3	87.9	76.3	86.3	6.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.3	136.0	81.8	74.4	131.6	81.0	73.3	126.7	80.2	42.0	89.0	40.9	88.1	40.0	86.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	13.9	12.0	13.7	98.9	4.2	3.4	10.7	101.3	8.2	103.3	5.9	105.1	2.8	107.6		
(5)			12.1	80.0	4.2	1.2	9.1	80.8	6.7	81.5	4.3	82.1	1.3	83.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	42.0	46.1	53.2	61.7	69.7	77.0	80.0	79.6	73.8	62.5	51.5	45.2	(6)	(7)
	DBStd	15.26	9.85	9.10	8.47	7.21	6.10	4.20	3.43	3.55	5.70	7.88	8.13	8.59	(7)	(8)
	HDD50	810	287	167	65	6	0	0	0	0	0	6	76	203	(8)	(9)
	HDD65	2967	713	532	373	145	30	1	0	0	8	140	410	615	(9)	(10)
	CDD50	5166	39	57	165	355	610	809	929	917	713	395	123	54	(10)	(11)
	CDD65	1847	0	2	8	45	175	360	464	452	270	64	6	1	(11)	(12)
	CDH74	17678	1	12	117	579	1712	3368	4492	4338	2421	591	45	2	(12)	(13)
	CDH80	7679	0	0	13	128	599	1533	2148	2083	1025	144	6	0	(13)	(14)
(14) Wind	WSAvg	4.1	4.9	4.9	5.3	4.8	3.9	3.4	3.3	3.2	3.4	3.7	4.0	4.4	(14)	(15)
(15) Precipitation	PrecAvg	52.7	5.0	4.3	7.2	5.3	4.2	3.6	4.2	3.7	4.5	2.9	3.7	5.0	(15)	(16)
	PrecMax	68.5	8.1	11.2	16.0	11.4	10.2	6.5	7.0	8.5	11.3	6.9	6.3	13.5	(16)	(17)
	PrecMin	41.9	2.2	0.6	1.5	1.0	0.9	0.6	1.3	1.0	1.1	0.0	1.3	1.1	(17)	(18)
	PrecStd	8.2	1.6	2.6	3.6	2.7	2.3	1.9	1.8	2.1	2.5	2.1	1.5	2.8	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.5	75.4	81.9	87.2	92.2	96.8	98.7	99.0	96.2	88.5	79.5	72.5	(19)	(20)
		MCWB	60.0	62.4	62.7	67.1	72.0	73.9	75.5	74.6	71.2	70.5	63.4	63.0	(20)	(21)
	2%	DB	66.3	70.1	77.4	83.6	89.0	93.4	95.1	95.8	92.6	83.7	73.5	67.9	(21)	(22)
		MCWB	58.3	58.8	61.4	65.1	70.3	73.1	75.7	74.8	71.3	67.9	60.0	61.3	(22)	(23)
	5%	DB	62.8	66.0	73.3	80.8	86.2	91.1	92.7	92.8	89.8	80.6	70.3	63.6	(23)	(24)
		MCWB	56.2	56.6	58.9	63.5	69.6	73.3	75.6	74.2	71.5	65.9	59.7	57.3	(24)	(25)
	10%	DB	58.4	62.3	69.2	77.2	83.3	88.6	90.4	90.3	86.2	76.8	66.2	59.8	(25)	(26)
		MCWB	52.4	53.1	56.1	62.2	68.5	72.8	75.2	74.1	71.0	64.6	57.8	54.5	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.7	65.8	66.0	70.3	75.2	78.4	79.9	79.2	76.5	75.0	69.3	66.6	(27)	(28)
		MCDB	67.6	71.8	76.3	81.9	85.2	88.4	89.5	90.9	86.0	82.1	73.0	69.4	(28)	(29)
	2%	WB	60.4	62.7	63.6	68.2	73.5	77.0	78.4	77.9	75.2	71.5	65.3	62.4	(29)	(30)
		MCDB	64.8	68.1	73.7	78.3	84.1	87.6	88.9	89.0	85.0	79.3	70.8	66.0	(30)	(31)
	5%	WB	57.4	59.1	61.5	66.2	72.1	75.8	77.5	76.9	74.0	69.3	62.4	58.9	(31)	(32)
		MCDB	62.1	63.9	69.7	76.0	82.2	86.1	88.6	87.4	83.0	76.0	67.4	62.5	(32)	(33)
	10%	WB	53.4	55.0	59.2	64.4	70.6	74.7	76.6	75.9	72.6	67.2	59.3	54.9	(33)	(34)
		MCDB	57.3	60.1	66.8	73.4	79.9	84.3	86.7	85.6	81.1	73.8	64.9	58.6	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.4	21.4	23.1	24.9	23.4	21.4	20.5	21.0	22.3	24.2	23.7	19.5	(35)	(36)
		MCDBR	24.9	26.7	29.4	29.6	27.0	25.7	23.9	25.1	27.1	27.3	28.4	23.8	(36)	(37)
	5% WB	MCWBR	17.2	17.2	15.6	13.6	11.3	9.2	8.0	8.1	9.5	13.0	16.9	16.9	(37)	(38)
		MCWBR	19.8	21.4	23.2	23.3	21.9	20.7	20.5	20.5	19.4	20.1	19.9	19.0	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.320	0.323	0.360	0.398	0.457	0.490	0.543	0.538	0.429	0.378	0.346	0.321	(39)	(40)
		taud	2.502	2.489	2.410	2.295	2.168	2.115	1.982	1.981	2.277	2.409	2.438	2.517	(40)	(41)
	Ebn at Noon		282	294	290	282	265	256	241	240	264	270	269	275	(41)	(42)
		Edh at Noon	27	30	35	42	48	50	57	56	40	32	28	25	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		807	975	1328	1709	1884	1963	1863	1737	1496	1242	908	683	(43)	(44)
	RadStd		56	127	116	110	149	149	131	96	142	157	103	71	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (39 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+259	+185

Nomenclature: See separate page